

Menesine ataskaita: 03.2023



	UAB Gren Klaipeda						sugeneruota: 1.04.2023
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.03	8.424	7.771	3.603	4.341	0.198	0.015	
2.03	8.472	7.757	6.091	2.738	0.198	0.010	
3.03	8.448	7.736	5.410	3.360	0.241	0.004	
4.03	9.051	7.695	4.239	0.405	0.341	0.001	
5.03	9.032	7.695	3.495	0.693	0.320	0.002	
6.03	9.339	7.651	3.452	0.359	0.376	0.001	
7.03	9.479	7.612	4.956	0.511	0.220	0.000	
8.03	9.470	7.793	9.740	0.005	0.163	0.000	
9.03	9.522	7.754	6.631	0.338	0.147	0.001	
10.03	10.078	7.778	7.245	1.451	0.141	0.002	
11.03	9.871	7.735	6.267	0.103	0.157	0.000	
12.03	9.251	7.840	10.381	0.012	0.141	0.000	
13.03	9.328	7.843	6.967	0.017	0.169	0.000	
14.03	9.417	7.718	4.085	0.307	0.200	0.004	
15.03	8.282	7.595	4.550	0.007	0.160	0.000	
16.03	8.499	7.643	3.122	0.262	0.160	0.000	
17.03	8.779	7.686	4.526	2.157	0.141	0.002	
18.03	8.110	7.791	3.527	1.107	0.161	0.003	
19.03	8.786	7.752	3.753	0.308	0.172	0.002	
20.03	8.867	7.736	3.476	0.218	0.203	0.004	
21.03	8.285	7.753	2.045	0.687	0.175	0.000	
22.03	8.355	7.738	2.948	0.125	0.178	0.001	
23.03	9.307	7.727	3.115	0.497	0.215	0.012	
24.03	10.071	7.699	2.852	0.248	0.287	0.016	
25.03	10.880	7.710	3.173	0.163	0.367	0.002	
26.03	9.425	7.712	2.917	0.017	0.299	0.000	
27.03	8.537	7.776	2.733	0.087	0.228	0.004	
28.03	9.218	7.762	3.606	0.278	0.217	0.003	
29.03	9.125	7.728	3.466	0.169	0.240	0.002	
30.03	9.553	7.625	3.690	2.071	0.434	0.205	
31.03	9.505	7.628	3.496	0.000	0.452	0.232	
min	8.110	7.595	2.045	0.000	0.141	0.000	
max	10.880	7.843	10.381	4.341	0.452	0.232	
MMV	9.123	7.724	4.509	0.741	0.229	0.017	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 03.2023



	UAB Gren Klaipeda						sugeneruota: 1.04.2023
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.03	0.020	0.000	144.754	0.000	0.407	222859.87	
2.03	0.019	0.000	143.629	0.000	0.386	221658.18	
3.03	0.019	0.000	143.880	0.000	0.338	222692.93	
4.03	0.020	0.000	144.531	0.000	0.339	226353.00	
5.03	0.020	0.000	144.235	0.000	0.310	226445.68	
6.03	0.019	0.000	143.084	0.000	0.405	228183.76	
7.03	0.019	0.000	144.167	0.000	0.420	226735.10	
8.03	0.019	0.001	143.626	0.000	0.372	228812.54	
9.03	0.019	0.000	144.011	0.000	0.358	227887.14	
10.03	0.019	0.000	143.840	0.000	0.408	228038.76	
11.03	0.019	0.000	144.613	0.000	0.173	228694.81	
12.03	0.019	0.000	144.071	0.000	0.198	230052.12	
13.03	0.019	0.002	145.360	0.001	0.286	225548.23	
14.03	0.020	0.002	144.978	0.001	0.263	218735.85	
15.03	0.019	0.000	143.105	0.000	0.300	220744.17	
16.03	0.019	0.000	143.949	0.000	0.323	223092.35	
17.03	0.019	0.000	144.010	0.000	0.296	224511.31	
18.03	0.020	0.003	145.919	0.000	0.267	199500.56	
19.03	0.021	0.034	147.085	0.006	0.241	218242.04	
20.03	0.020	0.013	144.126	0.004	0.317	218909.70	
21.03	0.020	0.000	143.960	0.000	0.341	219165.57	
22.03	0.020	0.000	144.079	0.000	0.330	219943.35	
23.03	0.021	0.006	143.467	0.015	0.247	219161.98	
24.03	0.022	0.025	143.644	0.015	0.277	218831.42	
25.03	0.022	0.032	143.997	0.031	0.326	222280.29	
26.03	0.020	0.008	143.322	0.003	0.274	218997.00	
27.03	0.020	0.000	143.818	0.000	0.337	221003.67	
28.03	0.020	0.000	143.580	0.000	0.361	222944.07	
29.03	0.020	0.000	143.357	0.000	0.279	221974.37	
30.03	0.021	0.041	141.369	0.008	0.302	212320.48	
31.03	0.026	0.058	144.266	0.003	0.221	218488.20	
min	0.019	0.000	141.369	0.000	0.173	199500.56	
max	0.026	0.058	147.085	0.031	0.420	230052.12	
MMV	0.020	0.007	144.059	0.003	0.313	222030.17	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 03.2023



	UAB Gren Klaipeda			sugeneruota: 1.04.2023		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.03	43.232	1041.942	6.724	1022.657	1068.394	4.017
2.03	43.291	1038.107	6.597	1019.148	1054.679	6.788
3.03	43.124	1028.319	6.563	1009.955	1061.831	5.990
4.03	44.287	1017.964	6.803	1001.086	1070.079	4.715
5.03	44.234	1017.696	6.630	1000.238	1106.102	3.888
6.03	44.866	1014.890	6.389	997.477	1114.310	3.839
7.03	45.051	1009.430	6.514	992.468	1086.980	5.506
8.03	44.966	1004.566	6.433	987.473	1087.425	10.859
9.03	45.241	1016.261	6.366	998.552	1072.698	7.355
10.03	46.191	1013.086	6.363	996.938	1080.318	8.036
11.03	45.738	1007.716	6.352	990.604	1082.574	6.953
12.03	44.667	1017.499	6.239	999.142	1090.940	11.577
13.03	44.798	1016.560	6.330	998.299	1110.247	7.719
14.03	44.533	1008.301	6.859	988.294	1117.059	4.546
15.03	42.683	1021.454	6.618	1003.632	1072.305	5.080
16.03	43.315	1034.769	6.603	1016.666	1049.091	3.468
17.03	43.930	1039.647	6.491	1021.402	1043.047	5.044
18.03	42.410	1035.196	6.789	1015.923	1093.072	X
19.03	43.844	1034.056	6.852	1014.131	1097.773	4.174
20.03	43.856	1028.519	6.698	1010.390	1090.198	3.862
21.03	42.813	1028.484	6.931	1011.248	1122.592	2.269
22.03	42.891	1025.742	6.891	1007.421	1107.803	3.273
23.03	44.341	1019.788	6.856	1000.775	1119.166	3.462
24.03	45.770	1017.260	6.795	998.719	1132.332	3.174
25.03	47.180	1016.010	6.685	997.506	1129.397	3.528
26.03	44.407	1013.680	6.746	995.867	1135.298	3.255
27.03	43.214	1017.402	6.786	1000.966	1130.571	3.032
28.03	44.762	1025.885	6.757	1009.242	1102.424	4.017
29.03	44.611	1032.875	6.763	1014.924	1113.137	3.849
30.03	45.990	1026.875	6.907	1006.844	1118.726	X
31.03	44.711	1015.959	7.089	997.138	1105.796	3.895
min	42.410	1004.566	6.239	987.473	1043.047	2.269
max	47.180	1041.942	7.089	1022.657	1135.298	11.577
MMV	44.358	1022.103	6.657	1004.016	1095.636	5.013
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 03.2023



	UAB Gren Klaipeda						sugeneruota: 1.04.2023
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.03	5.426	0.026	0.033	180.942	0.001	0.582	
2.03	3.423	0.017	0.032	179.536	0.000	0.551	
3.03	4.200	0.007	0.032	179.850	0.000	0.482	
4.03	0.506	0.002	0.033	180.664	0.000	0.484	
5.03	0.866	0.004	0.033	180.294	0.000	0.443	
6.03	0.449	0.001	0.032	178.855	0.000	0.578	
7.03	0.639	0.000	0.032	180.209	0.000	0.600	
8.03	0.006	0.000	0.032	179.533	0.000	0.531	
9.03	0.423	0.002	0.032	180.013	0.000	0.511	
10.03	1.814	0.003	0.032	179.800	0.000	0.582	
11.03	0.128	0.001	0.032	180.766	0.000	0.248	
12.03	0.015	0.000	0.032	180.089	0.000	0.283	
13.03	0.021	0.000	0.032	181.700	0.001	0.409	
14.03	0.383	0.006	0.034	181.222	0.001	0.375	
15.03	0.009	0.000	0.032	178.882	0.000	0.429	
16.03	0.328	0.001	0.032	179.936	0.000	0.461	
17.03	2.697	0.004	0.032	180.012	0.000	0.423	
18.03	1.384	0.006	0.033	182.399	0.000	0.381	
19.03	0.385	0.004	0.035	183.856	0.009	0.344	
20.03	0.272	0.006	0.033	180.157	0.005	0.453	
21.03	0.859	0.000	0.033	179.951	0.000	0.488	
22.03	0.157	0.001	0.033	180.099	0.000	0.472	
23.03	0.621	0.019	0.035	179.334	0.021	0.353	
24.03	0.310	0.027	0.037	179.555	0.021	0.396	
25.03	0.204	0.003	0.036	179.996	0.044	0.466	
26.03	0.021	0.001	0.034	179.153	0.004	0.391	
27.03	0.108	0.006	0.033	179.772	0.000	0.482	
28.03	0.347	0.004	0.033	179.474	0.000	0.516	
29.03	0.211	0.003	0.033	179.197	0.000	0.398	
30.03	2.588	0.341	0.034	176.712	0.012	0.431	
31.03	0.000	0.386	0.044	180.333	0.004	0.315	
min	0.000	0.000	0.032	176.712	0.000	0.248	
max	5.426	0.386	0.044	183.856	0.044	0.600	
MMV	0.926	0.028	0.033	180.073	0.004	0.447	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							