

Menesine ataskaita: 04.2023



	UAB Gren Klaipeda						sugeneruota: 1.05.2023
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.04	9.643	7.673	4.327	0.000	0.323	0.052	
2.04	8.995	7.700	3.143	0.085	0.222	0.007	
3.04	8.770	7.696	3.442	0.263	0.166	0.002	
4.04	8.908	7.709	5.670	0.000	0.162	0.001	
5.04	8.672	7.727	5.701	0.021	0.163	0.001	
6.04	8.756	7.761	6.003	0.013	0.146	0.015	
7.04	12.739	7.576	4.710	0.000	0.323	0.016	
8.04	11.941	7.676	3.996	0.009	0.216	0.011	
9.04	13.751	7.655	3.877	0.005	0.165	0.028	
10.04	11.986	7.693	5.004	0.002	0.162	0.013	
11.04	13.136	7.588	4.503	0.002	0.160	0.006	
12.04	13.400	7.529	5.504	0.002	0.165	0.006	
13.04	11.075	7.615	4.768	0.001	0.162	0.007	
14.04	12.310	7.597	4.614	0.000	0.169	0.059	
15.04	13.768	7.566	3.451	0.001	0.202	0.061	
16.04	9.882	7.718	4.965	0.022	0.171	0.018	
17.04	8.349	7.746	4.387	0.000	0.151	0.001	
18.04	10.574	7.662	3.732	0.000	0.159	0.009	
19.04	11.098	7.603	3.127	0.000	0.179	0.016	
20.04	13.456	7.547	3.758	0.000	0.240	0.026	
21.04	12.332	7.626	3.296	0.000	0.236	0.034	
22.04	15.287	7.526	3.369	0.000	0.279	0.042	
23.04	16.373	7.452	3.058	0.010	0.339	0.022	
24.04	16.628	7.437	3.344	0.010	0.555	0.006	
25.04	12.963	7.508	2.828	0.012	0.467	0.014	
26.04	9.592	7.654	5.641	0.002	0.163	0.008	
27.04	10.406	7.684	5.862	0.001	0.163	0.004	
28.04	11.597	7.672	4.926	0.000	0.141	0.002	
29.04	13.234	7.629	4.442	0.265	0.135	0.004	
30.04	15.068	7.580	4.863	0.005	0.139	0.035	
min	8.349	7.437	2.828	0.000	0.135	0.001	
max	16.628	7.761	6.003	0.265	0.555	0.061	
MMV	11.823	7.627	4.344	0.024	0.214	0.018	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 04.2023



	UAB Gren Klaipeda						sugeneruota: 1.05.2023
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.04	0.022	0.012	143.988	0.002	0.336	222967.50	
2.04	0.020	0.000	143.599	0.000	0.263	222532.76	
3.04	0.019	0.000	143.322	0.000	0.310	222980.18	
4.04	0.020	0.005	143.539	0.002	0.344	223655.43	
5.04	0.020	0.001	143.632	0.000	0.290	222142.18	
6.04	0.026	0.233	143.402	0.027	0.274	223057.10	
7.04	0.034	0.239	143.405	0.172	0.271	219177.68	
8.04	0.035	0.235	144.072	0.143	0.231	218424.85	
9.04	0.036	0.239	143.251	0.179	0.271	219124.00	
10.04	0.033	0.236	143.640	0.116	0.272	204452.85	
11.04	0.037	0.189	143.863	0.169	0.240	208249.20	
12.04	0.038	0.187	143.771	0.166	0.252	198897.32	
13.04	0.030	0.168	143.885	0.076	0.304	197336.31	
14.04	0.029	0.099	143.941	0.006	0.316	199497.50	
15.04	0.032	0.133	143.790	0.060	0.309	205182.60	
16.04	0.024	0.043	143.657	0.032	0.267	205603.62	
17.04	0.022	0.025	143.440	0.001	0.273	200964.01	
18.04	0.026	0.079	143.801	0.004	0.281	204864.04	
19.04	0.028	0.084	143.870	0.017	0.295	204368.98	
20.04	0.033	0.141	143.633	0.028	0.268	201350.18	
21.04	0.031	0.101	143.662	0.020	0.240	200152.25	
22.04	0.038	0.145	143.918	0.087	0.281	204471.26	
23.04	0.039	0.180	143.581	0.140	0.295	204464.76	
24.04	0.043	0.215	143.601	0.216	0.368	204738.68	
25.04	0.032	0.099	143.879	0.069	0.827	199780.25	
26.04	0.024	0.021	143.868	0.013	0.330	202241.89	
27.04	0.026	0.055	143.552	0.005	0.278	209413.06	
28.04	0.031	0.071	144.126	0.008	0.246	209296.95	
29.04	0.035	0.138	143.569	0.088	0.198	207250.17	
30.04	0.035	0.144	143.564	0.119	0.251	210758.57	
min	0.019	0.000	143.251	0.000	0.198	197336.31	
max	0.043	0.239	144.126	0.216	0.827	223655.43	
MMV	0.030	0.117	143.694	0.065	0.299	209246.28	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 04.2023



	UAB Gren Klaipeda			sugeneruota: 1.05.2023		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.04	45.221	1016.540	6.750	999.905	1110.875	4.818
2.04	44.190	1033.192	6.591	1015.898	1129.574	3.494
3.04	43.979	1042.924	6.589	1025.937	1139.242	3.826
4.04	44.235	1039.246	6.759	1022.030	1091.109	6.293
5.04	43.712	1038.022	6.760	1019.527	1091.735	6.305
6.04	43.793	1039.270	6.679	1021.380	1100.743	6.676
7.04	50.662	1039.143	6.803	1018.467	1096.216	5.236
8.04	49.216	1041.789	6.564	1022.285	1111.681	4.444
9.04	52.217	1041.981	6.496	1023.015	1145.390	4.319
10.04	49.391	1041.282	6.608	1022.380	1083.419	5.551
11.04	51.207	1031.458	6.647	1012.167	1092.469	5.005
12.04	51.708	1026.390	6.910	1007.479	1104.700	6.119
13.04	47.768	1024.367	6.947	1006.606	1068.832	5.309
14.04	50.154	1029.392	6.958	1011.095	1084.027	5.123
15.04	52.450	1032.814	6.758	1014.603	1115.966	3.835
16.04	45.338	1036.404	6.741	1019.006	1086.840	5.531
17.04	42.936	1042.743	6.915	1024.135	1078.468	4.873
18.04	47.065	1045.368	6.806	1026.234	1081.883	4.140
19.04	47.954	1040.852	6.928	1022.137	1110.393	3.478
20.04	52.100	1042.367	7.001	1023.055	1082.012	4.173
21.04	50.426	1037.952	7.028	1019.762	1118.052	3.652
22.04	54.822	1032.385	6.654	1013.475	1149.991	3.755
23.04	56.244	1027.753	6.551	1008.031	1166.735	3.393
24.04	56.506	1021.265	6.554	1003.425	1160.677	3.720
25.04	50.985	1018.613	7.184	1001.631	1161.224	3.146
26.04	45.038	1022.010	6.994	1005.370	1115.174	6.190
27.04	46.823	1030.039	6.829	1012.402	1121.806	6.473
28.04	48.847	1034.597	6.710	1016.142	1143.551	5.473
29.04	51.233	1032.257	6.634	1012.907	1137.868	4.945
30.04	54.100	1031.805	6.497	1014.290	1161.212	5.406
min	42.936	1016.540	6.496	999.905	1068.832	3.146
max	56.506	1045.368	7.184	1026.234	1166.735	6.676
MMV	49.011	1033.807	6.762	1015.493	1114.729	4.823
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 04.2023



	UAB Gren Klaipeda						sugeneruota: 1.05.2023
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.04	0.000	0.086	0.037	179.985	0.003	0.480	
2.04	0.106	0.012	0.033	179.498	0.000	0.376	
3.04	0.328	0.004	0.032	179.152	0.001	0.442	
4.04	0.000	0.001	0.033	179.424	0.003	0.492	
5.04	0.027	0.002	0.033	179.540	0.000	0.414	
6.04	0.016	0.025	0.043	179.253	0.039	0.392	
7.04	0.000	0.027	0.056	179.256	0.246	0.388	
8.04	0.012	0.019	0.059	180.090	0.204	0.329	
9.04	0.006	0.046	0.061	179.064	0.256	0.388	
10.04	0.002	0.021	0.055	179.551	0.166	0.388	
11.04	0.002	0.011	0.061	179.829	0.241	0.343	
12.04	0.003	0.010	0.063	179.714	0.237	0.360	
13.04	0.001	0.011	0.049	179.857	0.108	0.435	
14.04	0.000	0.098	0.049	179.926	0.008	0.452	
15.04	0.001	0.102	0.053	179.738	0.085	0.441	
16.04	0.028	0.031	0.040	179.571	0.046	0.382	
17.04	0.000	0.002	0.036	179.300	0.001	0.390	
18.04	0.000	0.015	0.044	179.752	0.006	0.402	
19.04	0.000	0.027	0.046	179.837	0.024	0.422	
20.04	0.000	0.043	0.055	179.541	0.040	0.384	
21.04	0.000	0.057	0.052	179.578	0.028	0.343	
22.04	0.000	0.070	0.063	179.897	0.124	0.402	
23.04	0.012	0.037	0.066	179.477	0.200	0.421	
24.04	0.012	0.011	0.072	179.501	0.309	0.525	
25.04	0.015	0.023	0.053	179.848	0.098	1.182	
26.04	0.002	0.014	0.040	179.836	0.019	0.471	
27.04	0.001	0.007	0.044	179.440	0.007	0.397	
28.04	0.000	0.003	0.052	180.157	0.011	0.352	
29.04	0.331	0.007	0.058	179.461	0.126	0.282	
30.04	0.006	0.058	0.059	179.455	0.170	0.359	
min	0.000	0.001	0.032	179.064	0.000	0.282	
max	0.331	0.102	0.072	180.157	0.309	1.182	
MMV	0.030	0.029	0.050	179.618	0.094	0.428	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							