

# Menesine ataskaita: 03.2024



	UAB Gren Klaipeda sugeneruota: 15.03.2024					
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.03	17.978	7.522	7.704	1.050	0.414	0.000
2.03	19.248	7.405	8.481	0.354	0.636	0.000
3.03	19.272	7.354	6.893	0.058	0.801	0.000
4.03	16.145	7.472	7.425	1.019	0.724	0.000
5.03	13.370	7.564	8.237	2.492	0.661	0.000
6.03	12.022	7.570	11.499	2.466	2.179	0.001
7.03	10.942	7.691	13.188	2.609	0.297	0.002
8.03	11.230	7.740	8.445	2.937	0.390	0.002
9.03	10.970	7.754	7.055	2.578	0.475	0.003
10.03	11.141	7.726	7.879	1.990	0.782	0.011
11.03	13.289	7.687	7.690	1.467	1.292	0.007
12.03	10.927	7.727	6.074	1.862	1.218	0.005
13.03	14.498	7.459	5.776	2.735	2.927	0.001
14.03	16.772	7.419	6.303	2.197	1.512	0.000
min	10.927	7.354	5.776	0.058	0.297	0.000
max	19.272	7.754	13.188	2.937	2.927	0.011
MMV	14.129	7.578	8.046	1.844	1.022	0.002
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV                                                  A = Start-up/shut down						

# Menesine ataskaita: 03.2024



	UAB Gren Klaipeda sugeneruota: 15.03.2024					
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.03	0.118	0.000	135.356	0.010	0.613	234491.48
2.03	0.120	0.000	135.577	0.004	0.571	236624.18
3.03	0.104	0.000	135.544	0.004	0.744	235706.75
4.03	0.107	0.000	135.585	0.004	0.626	229501.26
5.03	0.088	0.000	135.894	0.000	0.646	225130.45
6.03	0.096	0.000	135.680	0.041	0.598	218506.95
7.03	0.095	0.000	135.555	0.099	0.632	217416.62
8.03	0.093	0.014	135.467	0.008	0.578	224705.14
9.03	0.085	0.000	135.706	0.000	0.605	224986.20
10.03	0.090	0.000	135.646	0.000	0.579	222797.17
11.03	0.097	0.000	135.621	0.000	0.464	227878.12
12.03	0.093	0.000	135.565	0.000	0.579	224883.95
13.03	0.111	0.000	135.492	0.000	0.679	228173.04
14.03	0.107	0.000	135.472	0.001	0.682	228156.04
min	0.085	0.000	135.356	0.000	0.464	217416.62
max	0.120	0.014	135.894	0.099	0.744	236624.18
MMV	0.100	0.001	135.583	0.012	0.614	227068.46
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV                                                  A = Start-up/shut down						

# Menesine ataskaita: 03.2024



	UAB Gren Klaipeda			sugeneruota: 15.03.2024		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.03	57.646	1035.019	6.431	1014.812	1003.719	8.372
2.03	59.245	1032.966	6.533	1013.764	994.232	9.231
3.03	59.284	1032.953	6.517	1013.950	1009.070	7.424
4.03	54.900	1033.368	6.888	1015.804	995.006	8.043
5.03	51.013	1037.099	7.318	1018.872	972.266	8.966
6.03	49.177	1044.234	7.765	1026.052	968.298	12.617
7.03	47.417	1045.196	7.608	1026.741	973.732	14.528
8.03	47.877	1039.368	7.239	1021.552	1003.169	9.185
9.03	47.284	1036.192	7.044	1018.265	1011.418	7.643
10.03	47.423	1037.039	7.078	1018.118	1008.224	8.577
11.03	50.667	1036.400	6.810	1016.732	1021.083	8.336
12.03	46.885	1033.517	7.216	1014.126	1024.063	6.546
13.03	52.579	1035.098	7.375	1014.820	1012.837	6.170
14.03	56.111	1034.043	7.069	1013.251	1008.005	6.769
min	46.885	1032.953	6.431	1013.251	968.298	6.170
max	59.284	1045.196	7.765	1026.741	1024.063	14.528
MMV	51.965	1036.606	7.064	1017.634	1000.366	8.743
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV                                                  A = Start-up/shut down						

# Menesine ataskaita: 03.2024



	UAB Gren Klaipeda						sugeneruota: 15.03.2024
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.03	1.312	0.000	0.147	176.381	0.000	0.460	
2.03	0.443	0.000	0.148	176.774	0.001	0.386	
3.03	0.072	0.000	0.121	176.728	0.000	0.640	
4.03	1.274	0.000	0.126	176.726	0.000	0.478	
5.03	3.115	0.000	0.095	177.106	0.000	0.514	
6.03	3.082	0.001	0.108	176.942	0.047	0.441	
7.03	3.262	0.003	0.106	176.660	0.119	0.503	
8.03	3.671	0.003	0.104	176.412	0.011	0.433	
9.03	3.222	0.005	0.092	176.629	0.000	0.479	
10.03	2.488	0.019	0.100	176.578	0.000	0.439	
11.03	1.834	0.011	0.112	176.574	0.000	0.263	
12.03	2.327	0.008	0.106	176.514	0.000	0.434	
13.03	3.419	0.002	0.133	176.687	0.000	0.552	
14.03	2.746	0.000	0.125	176.683	0.000	0.550	
min	0.072	0.000	0.092	176.381	0.000	0.263	
max	3.671	0.019	0.148	177.106	0.119	0.640	
MMV	2.305	0.004	0.116	176.671	0.013	0.469	
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV                                                  A = Start-up/shut down							