

Menesine ataskaita: 10.2024



	UAB Gren Klaipeda						sugeneruota: 14.10.2024
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.10	15.972	7.597	7.485	0.014	0.095	0.003	
2.10	15.391	7.553	8.220	0.428	0.053	0.035	
3.10	16.144	7.576	8.038	0.366	0.094	0.011	
4.10	15.954	7.527	8.453	0.164	0.067	0.007	
5.10	17.217	7.496	7.124	0.004	0.072	0.003	
6.10	17.366	7.521	5.801	0.000	0.070	0.002	
7.10	16.846	7.576	7.113	0.026	0.018	0.003	
8.10	15.372	7.556	7.659	0.019	0.029	0.004	
9.10	16.553	7.555	7.511	0.007	0.072	0.001	
10.10	12.332	X	X	X	X	X	
11.10	17.512	7.408	12.530	0.004	0.989	0.001	
12.10	17.659	7.458	6.968	0.000	0.852	0.000	
13.10	16.696	7.497	8.305	0.023	0.434	0.006	
min	12.332	7.408	5.801	0.000	0.018	0.000	
max	17.659	7.597	12.530	0.428	0.989	0.035	
MMV	16.450	7.521	8.320	0.088	0.236	0.006	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 10.2024



	UAB Gren Klaipeda						sugeneruota: 14.10.2024
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m ³ iN.	mg/m ³ iN.	mg/m ³ iN.	mg/m ³ iN.	mg/m ³ iN.		Nm ³ /h
1.10	0.064	0.000	135.591	0.087	0.554		230571.23
2.10	0.068	0.000	135.732	0.054	0.496		232858.45
3.10	0.067	0.000	135.610	0.200	0.519		234048.73
4.10	0.065	0.000	135.839	0.256	0.479		225062.82
5.10	0.067	0.000	135.779	0.264	0.508		236932.29
6.10	0.063	0.000	135.861	0.272	0.544		234303.56
7.10	0.064	0.000	135.577	0.242	0.454		233704.42
8.10	0.068	0.000	136.475	0.117	0.490		227075.04
9.10	0.064	0.000	135.905	0.267	0.521		233641.75
10.10	X	X	X	X	X		139852.40
11.10	0.069	0.000	135.689	0.458	0.507		226974.45
12.10	0.066	0.000	135.722	0.313	0.489		240102.51
13.10	0.066	0.000	135.843	0.213	0.534		234649.67
min	0.063	0.000	135.577	0.054	0.454		139852.40
max	0.069	0.000	136.475	0.458	0.554		240102.51
MMV	0.066	0.006	135.673	0.232	0.508		230142.40
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 10.2024



	UAB Gren Klaipeda						sugeneruota: 14.10.2024
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc	
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h	
1.10	55.102	1037.876	6.659	1018.942	1005.375	8.134	
2.10	54.252	1032.555	6.766	1010.602	1016.226	8.953	
3.10	55.205	1032.308	6.619	1011.876	1024.516	8.737	
4.10	55.044	1036.611	6.669	1015.397	1018.228	9.222	
5.10	56.594	1039.286	6.557	1018.216	1019.423	7.710	
6.10	56.731	1034.188	6.309	1013.652	1034.108	6.220	
7.10	56.043	1030.458	6.400	1009.316	1041.626	7.706	
8.10	54.192	1030.199	6.709	1008.334	1003.327	12.734	
9.10	55.538	1019.820	6.414	997.988	1017.724	8.167	
10.10	49.298	1015.236	10.777	993.700	X	X	
11.10	56.756	1022.877	6.857	1002.587	972.636	13.723	
12.10	57.098	1037.933	6.485	1016.834	1001.081	7.523	
13.10	55.748	1026.483	6.615	1006.828	1015.472	9.001	
min	49.298	1015.236	6.309	993.700	972.636	6.220	
max	57.098	1039.286	10.777	1018.942	1041.626	13.723	
MMV	55.530	1031.298	6.694	1010.446	1013.375	9.450	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							

Menesine ataskaita: 10.2024



	UAB Gren Klaipeda						sugeneruota: 14.10.2024
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.10	0.017	0.004	0.054	176.633	0.023	0.381	
2.10	0.535	0.059	0.061	176.815	0.006	0.296	
3.10	0.458	0.019	0.059	176.653	0.081	0.328	
4.10	0.205	0.012	0.056	176.954	0.129	0.271	
5.10	0.005	0.005	0.059	176.910	0.171	0.309	
6.10	0.000	0.003	0.052	176.937	0.154	0.366	
7.10	0.032	0.004	0.055	176.577	0.121	0.234	
8.10	0.024	0.006	0.062	177.721	0.022	0.289	
9.10	0.009	0.002	0.055	176.980	0.155	0.329	
10.10	X	X	X	X	X	X	
11.10	0.005	0.002	0.061	176.927	0.381	0.289	
12.10	0.000	0.000	0.057	176.840	0.213	0.280	
13.10	0.029	0.010	0.057	176.980	0.119	0.344	
min	0.000	0.000	0.052	176.577	0.006	0.234	
max	0.535	0.059	0.062	177.721	0.381	0.381	
MMV	0.109	0.011	0.058	176.755	0.136	0.309	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							