

Menesine ataskaita: 01.2014



	UAB Fortum Klaipeda						sugeneruota: 1.02.2014	
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc		
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.		
1.01	9.021	11.095	5.359	3.962	1.547	4.672		
2.01	13.649	11.172	7.316	0.603	1.501	1.607		
3.01	12.039	11.566	10.351	0.786	1.013	0.924		
4.01	14.433	11.956	7.904	3.151	1.015	0.872		
5.01	13.586	12.073	6.572	2.470	1.053	0.823		
6.01	15.447	12.164	5.627	3.893	0.999	0.887		
7.01	16.497	12.617	4.671	4.892	0.829	0.817		
8.01	13.277	12.482	5.800	23.075	0.700	0.781		
9.01	13.123	12.629	6.177	29.236	0.808	0.752		
10.01	11.986	12.677	5.750	1.763	0.793	0.729		
11.01	10.277	12.172	5.080	0.618	0.694	0.803		
12.01	11.985	12.293	4.875	1.962	0.764	0.728		
13.01	10.789	12.233	5.167	0.930	0.724	0.764		
14.01	13.888	12.499	7.182	3.149	0.923	0.795		
15.01	10.373	12.285	6.873	0.584	0.664	0.722		
16.01	10.460	12.251	6.747	0.802	0.617	0.744		
17.01	8.439	10.327	27.251	3.955	1.573	4.014		
18.01	9.644	9.155	8.023	1.625	0.988	2.647		
19.01	13.285	11.672	8.679	2.194	0.607	0.887		
20.01	13.491	12.553	6.161	2.623	0.620	0.822		
21.01	D 223.044	12.695	6.927	3.083	0.630	0.831		
22.01	13.652	12.565	7.301	4.071	0.639	0.827		
23.01	14.446	12.409	7.601	3.949	0.841	0.934		
24.01	14.414	12.362	8.578	3.290	0.795	0.814		
25.01	14.458	12.114	10.049	3.441	0.847	0.842		
26.01	14.180	12.377	10.005	2.547	0.770	0.907		
27.01	13.269	12.042	10.989	1.297	1.063	0.890		
28.01	13.658	12.074	9.664	1.377	0.969	0.946		
29.01	14.145	12.223	9.587	4.022	0.968	0.853		
30.01	15.279	12.254	7.655	3.418	1.068	0.790		
31.01	15.097	12.209	7.282	0.799	1.075	1.072		
min	8.439	9.155	4.671	0.584	0.607	0.722		
max	D 223.044	12.695	27.251	29.236	1.573	4.672		
MMV	19.936	12.155	7.551	4.058	0.872	0.956		
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down								

Menesine ataskaita: 01.2014



	UAB Fortum Klaipeda sugeneruota: 1.02.2014					
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.01	0.466	0.000	167.843	1.930	0.128	83839.469
2.01	0.204	0.000	138.247	1.221	0.311	173072.82
3.01	0.158	0.000	149.916	0.985	0.320	196067.98
4.01	0.254	0.000	145.876	1.032	0.235	200597.20
5.01	0.204	0.000	145.919	0.989	0.247	198843.92
6.01	0.308	0.000	150.934	1.102	0.284	201611.39
7.01	0.343	0.000	149.470	1.128	0.327	203558.06
8.01	0.222	0.000	141.809	1.011	0.332	186834.37
9.01	0.251	0.000	140.933	0.985	0.398	184951.92
10.01	0.196	0.000	132.204	0.917	0.348	179007.95
11.01	0.148	0.000	134.138	0.827	0.287	177798.82
12.01	0.272	0.000	137.220	0.891	0.331	182976.87
13.01	0.192	0.000	133.703	0.774	0.404	189974.85
14.01	0.305	0.000	143.663	0.966	0.307	203538.68
15.01	0.184	0.000	144.367	0.819	0.496	200763.48
16.01	0.175	0.000	147.492	0.877	0.502	199765.20
17.01	0.397	0.797	142.236	1.930	0.550	43703.605
18.01	0.327	0.000	147.533	1.168	0.515	0.000
19.01	0.383	0.000	143.752	0.941	0.486	0.000
20.01	0.342	0.000	148.321	0.890	0.389	0.000
21.01	0.375	0.000	156.227	0.886	0.452	58265.387
22.01	0.376	0.000	150.588	0.899	0.493	194173.18
23.01	0.421	0.000	161.476	1.017	0.400	190082.93
24.01	0.413	0.000	151.627	0.974	0.370	205831.01
25.01	0.432	0.000	153.914	0.914	0.372	209281.85
26.01	0.442	0.000	147.628	0.959	0.413	202605.57
27.01	0.404	0.145	137.070	0.943	0.313	200432.82
28.01	0.447	0.000	142.145	0.995	0.450	204960.14
29.01	0.443	0.008	146.944	1.046	0.450	187790.23
30.01	0.505	0.000	144.569	1.077	0.347	174751.73
31.01	0.493	0.000	149.377	1.081	0.519	153933.14
min	0.148	0.000	132.204	0.774	0.128	0.000
max	0.505	0.797	167.843	1.930	0.550	209281.85
MMV	0.318	0.013	145.491	0.990	0.379	160917.89
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 01.2014



UAB Fortum Klaipeda		sugeneruota: 1.02.2014				
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc		
Diena	°C	mbar	Vol%	mbar		
1.01	135.814	1013.793	12.769	1017.571		
2.01	80.940	1010.062	6.898	1012.628		
3.01	48.944	1007.876	7.026	1010.173		
4.01	53.010	1006.468	6.424	1008.119		
5.01	51.666	1002.866	6.440	1005.175		
6.01	54.588	1006.737	6.146	1008.760		
7.01	56.064	1007.334	5.736	1008.745		
8.01	51.029	1006.344	5.871	1007.982		
9.01	50.677	1000.606	5.694	1002.682		
10.01	48.089	986.585	5.725	989.496		
11.01	45.431	999.610	6.267	1001.921		
12.01	48.501	995.330	6.159	998.376		
13.01	46.596	1005.701	6.260	1009.804		
14.01	52.066	1009.625	5.974	1012.814		
15.01	45.703	1006.639	6.306	1011.108		
16.01	45.903	1009.888	6.190	1014.943		
17.01	98.660	1006.746	12.486	1013.367		
18.01	99.676	1010.119	9.935	1016.239		
19.01	51.225	1018.382	6.588	1023.620		
20.01	51.608	1017.060	5.733	1022.554		
21.01	179.616	D 1218.285	D 86.210	1019.223		
22.01	51.913	1014.841	5.974	1020.626		
23.01	58.771	1018.952	6.140	1024.079		
24.01	53.240	1023.773	6.163	1029.124		
25.01	53.334	1025.855	6.396	1030.495		
26.01	52.697	1018.001	6.044	1021.662		
27.01	51.140	1011.100	6.424	1012.440		
28.01	51.627	1014.681	6.334	1017.230		
29.01	52.690	1018.899	6.232	1023.168		
30.01	54.394	1023.855	6.298	1028.313		
31.01	62.582	1021.357	6.319	1024.066		
min	45.431	986.585	5.694	989.496		
max	179.616	D 1218.285	D 86.210	1030.495		
MMV	62.105	1017.456	9.325	1014.416		
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						