

Menesine ataskaita: 01.2021



	UAB Fortum Klaipeda						sugeneruota: 1.02.2021
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.01	16.661	7.392	4.388	0.000	0.507	0.024	
2.01	16.866	7.352	3.784	0.000	0.592	0.009	
3.01	16.542	7.425	3.922	0.000	0.592	0.022	
4.01	17.506	7.409	4.427	0.000	0.776	0.023	
5.01	14.444	7.392	3.979	0.000	0.584	0.075	
6.01	15.260	7.396	3.651	0.000	0.265	0.041	
7.01	12.792	7.488	5.050	0.000	0.261	0.030	
8.01	12.740	7.533	4.710	0.000	0.382	0.023	
9.01	10.622	7.613	4.441	0.000	0.217	0.022	
10.01	10.135	7.587	3.379	0.000	0.214	0.021	
11.01	10.853	7.550	3.106	0.000	0.238	0.023	
12.01	10.964	7.517	3.973	0.000	0.282	0.035	
13.01	11.666	7.528	7.756	0.000	0.301	0.046	
14.01	10.125	7.596	9.332	0.000	0.239	0.018	
15.01	11.912	7.566	8.591	0.000	0.255	0.006	
16.01	13.820	7.541	9.094	0.000	0.385	0.014	
17.01	15.976	7.525	7.134	0.000	0.476	0.038	
18.01	14.339	7.457	4.849	0.000	0.733	0.056	
19.01	12.761	7.571	6.060	0.000	0.337	0.019	
20.01	12.023	7.558	8.108	0.000	0.213	0.013	
21.01	9.382	7.614	16.459	0.000	0.210	0.003	
22.01	9.101	7.699	5.439	0.000	0.220	0.005	
23.01	10.169	7.568	4.553	0.000	0.200	0.010	
24.01	10.175	7.604	4.958	0.000	0.213	0.008	
25.01	11.450	7.558	8.211	0.000	0.227	0.011	
26.01	13.897	7.411	6.818	0.430	0.256	0.048	
27.01	17.040	7.382	3.789	0.002	0.375	0.062	
28.01	16.785	7.399	3.854	0.000	0.396	0.043	
29.01	16.354	7.403	4.653	0.214	0.373	0.075	
30.01	17.160	7.468	6.150	0.000	0.443	0.063	
31.01	17.562	7.436	4.398	0.000	0.464	0.050	
min	9.101	7.352	3.106	0.000	0.200	0.003	
max	17.562	7.699	16.459	0.430	0.776	0.075	
MMV	13.454	7.501	5.775	0.021	0.362	0.030	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 01.2021



UAB Fortum Klaipeda		sugeneruota: 1.02.2021				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.01	0.028	0.000	131.855	0.111	0.209	219967.60
2.01	0.029	0.000	131.692	0.115	0.182	221648.04
3.01	0.022	0.000	131.651	0.014	0.195	218934.81
4.01	0.024	0.000	131.724	0.047	0.198	223368.67
5.01	0.021	0.000	132.306	0.013	0.186	215350.68
6.01	0.021	0.000	132.059	0.002	0.209	216883.79
7.01	0.021	0.000	131.521	0.001	0.239	213861.39
8.01	0.022	0.000	132.043	0.017	0.204	206775.17
9.01	0.021	0.000	131.882	0.007	0.205	198225.35
10.01	0.021	0.000	131.767	0.007	0.162	196913.60
11.01	0.022	0.000	131.587	0.009	0.187	200040.73
12.01	0.023	0.000	131.242	0.021	0.193	202089.29
13.01	0.023	0.000	131.835	0.007	0.185	204073.54
14.01	0.021	0.000	131.733	0.005	0.238	197838.51
15.01	0.021	0.000	131.760	0.001	0.221	202728.10
16.01	0.022	0.000	132.055	0.005	0.275	209086.01
17.01	0.022	0.000	131.500	0.004	0.273	210375.35
18.01	0.021	0.000	131.423	0.007	0.229	209589.29
19.01	0.021	0.000	132.093	0.010	0.210	205175.45
20.01	0.022	0.000	131.858	0.003	0.216	204216.62
21.01	0.022	0.000	130.980	0.001	0.245	197096.82
22.01	0.022	0.000	132.009	0.000	0.211	197102.29
23.01	0.024	0.000	132.057	0.002	0.168	199331.31
24.01	0.023	0.000	131.528	0.008	0.146	198835.60
25.01	0.023	0.000	131.731	0.155	0.200	205605.43
26.01	0.024	0.000	132.019	0.191	0.213	214230.57
27.01	0.025	0.000	131.668	0.030	0.304	224427.64
28.01	0.023	0.000	132.149	0.021	0.186	223695.57
29.01	0.024	0.000	130.504	0.011	0.227	221759.42
30.01	0.025	0.000	131.962	0.037	0.176	224714.39
31.01	0.026	0.000	131.717	0.037	0.186	226168.57
min	0.021	0.000	130.504	0.000	0.146	196913.60
max	0.029	0.000	132.306	0.191	0.304	226168.57
MMV	0.023	0.000	131.739	0.029	0.209	210003.60
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 01.2021



	UAB Fortum Klaipeda			sugeneruota: 1.02.2021		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.01	56.393	1022.496	5.759	1009.114	1020.170	4.879
2.01	56.710	1028.134	5.939	1013.526	1036.129	4.203
3.01	56.455	1035.009	5.892	1021.065	1019.200	4.370
4.01	57.584	1034.888	5.751	1020.873	990.997	4.920
5.01	54.985	1033.025	6.509	1018.573	1016.802	4.420
6.01	54.646	1028.442	6.269	1013.554	1036.443	4.050
7.01	50.331	1023.105	6.426	1007.913	1002.228	5.631
8.01	50.081	1024.878	6.328	1009.717	986.082	5.235
9.01	47.431	1028.093	6.458	1014.596	997.583	4.938
10.01	46.601	1033.052	6.603	1018.532	1007.068	3.758
11.01	47.830	1027.162	6.345	1011.920	1013.287	3.455
12.01	47.369	1013.693	6.463	999.327	1011.254	4.405
13.01	48.599	1014.816	6.472	1000.225	978.587	8.620
14.01	46.526	1023.229	6.533	1010.092	956.603	10.397
15.01	49.745	1027.410	6.477	1015.823	968.904	9.577
16.01	52.477	1025.899	6.312	1014.304	982.565	10.130
17.01	55.501	1032.308	5.888	1020.106	985.524	7.933
18.01	53.184	1030.344	6.239	1016.826	994.354	5.392
19.01	50.829	1025.314	6.346	1011.841	982.428	6.748
20.01	49.537	1017.823	6.415	1003.242	1011.960	9.007
21.01	44.752	1014.731	6.999	997.581	989.342	18.373
22.01	44.140	1009.628	6.915	993.258	1008.456	6.035
23.01	46.430	1010.976	6.605	995.577	1021.344	5.050
24.01	46.342	1006.974	6.610	991.931	1014.025	5.515
25.01	48.322	1009.997	6.891	995.115	1024.589	9.183
26.01	52.222	1013.525	6.758	998.909	1058.819	7.609
27.01	56.771	1017.219	5.916	1002.473	1060.839	4.199
28.01	56.384	1013.971	5.990	999.699	1067.925	4.285
29.01	55.784	1007.339	6.103	993.613	1061.539	5.174
30.01	56.785	1007.312	5.974	992.906	1040.536	6.833
31.01	57.308	1010.700	5.778	995.925	1050.126	4.890
min	44.140	1006.974	5.751	991.931	956.603	3.455
max	57.584	1035.009	6.999	1021.065	1067.925	18.373
MMV	51.550	1021.016	6.321	1006.716	1012.765	6.426
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 01.2021



	UAB Fortum Klaipeda sugeneruota: 1.02.2021					
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.01	0.000	0.039	0.047	164.819	0.159	0.299
2.01	0.000	0.016	0.048	164.615	0.165	0.260
3.01	0.000	0.036	0.037	164.563	0.020	0.279
4.01	0.000	0.038	0.039	164.655	0.067	0.283
5.01	0.000	0.126	0.035	165.382	0.018	0.266
6.01	0.000	0.068	0.035	165.074	0.003	0.299
7.01	0.000	0.050	0.034	164.401	0.001	0.342
8.01	0.000	0.038	0.036	165.054	0.024	0.291
9.01	0.000	0.037	0.036	164.853	0.010	0.292
10.01	0.000	0.035	0.035	164.709	0.009	0.232
11.01	0.000	0.039	0.036	164.484	0.013	0.267
12.01	0.000	0.059	0.039	164.053	0.030	0.276
13.01	0.000	0.076	0.039	164.794	0.010	0.264
14.01	0.000	0.030	0.035	164.666	0.008	0.340
15.01	0.000	0.010	0.035	164.700	0.001	0.316
16.01	0.000	0.024	0.037	165.069	0.007	0.393
17.01	0.000	0.064	0.037	164.375	0.005	0.390
18.01	0.000	0.093	0.036	164.279	0.010	0.328
19.01	0.000	0.032	0.035	165.116	0.014	0.300
20.01	0.000	0.022	0.036	164.822	0.005	0.309
21.01	0.000	0.005	0.036	163.725	0.001	0.350
22.01	0.000	0.008	0.037	165.011	0.000	0.301
23.01	0.000	0.016	0.041	165.071	0.003	0.239
24.01	0.000	0.013	0.038	164.410	0.011	0.209
25.01	0.000	0.018	0.038	164.664	0.221	0.285
26.01	0.537	0.081	0.039	165.023	0.272	0.304
27.01	0.003	0.103	0.041	164.585	0.043	0.434
28.01	0.000	0.071	0.039	165.186	0.030	0.266
29.01	0.268	0.126	0.039	163.129	0.015	0.324
30.01	0.000	0.105	0.041	164.953	0.052	0.251
31.01	0.000	0.083	0.044	164.646	0.053	0.265
min	0.000	0.005	0.034	163.129	0.000	0.209
max	0.537	0.126	0.048	165.382	0.272	0.434
MMV	0.026	0.050	0.038	164.674	0.041	0.298
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						