

Menesine ataskaita: 01.2022



	UAB Fortum Klaipeda						sugeneruota: 1.02.2022
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.01	8.654	7.689	4.702	0.000	0.314	0.026	
2.01	9.413	7.650	4.625	0.000	0.356	0.008	
3.01	8.457	7.688	5.687	0.005	0.360	0.008	
4.01	8.724	7.721	5.639	0.000	0.669	0.015	
5.01	9.053	7.656	6.620	0.000	0.394	0.010	
6.01	9.341	7.685	4.818	0.000	0.440	0.014	
7.01	9.342	7.613	7.030	0.000	0.464	0.028	
8.01	9.768	7.630	5.231	0.000	0.339	0.017	
9.01	9.703	7.633	6.447	0.000	0.476	0.007	
10.01	10.457	7.625	5.414	0.000	0.549	0.017	
11.01	10.117	7.698	4.007	0.000	0.343	0.040	
12.01	10.244	7.695	3.676	0.000	0.304	0.079	
13.01	8.637	7.742	5.415	0.000	0.265	0.064	
14.01	8.577	7.710	5.887	0.000	0.290	0.021	
15.01	8.951	7.673	5.155	0.000	0.286	0.043	
16.01	9.402	7.650	4.077	0.000	0.305	0.027	
17.01	9.289	7.670	6.825	0.000	0.635	0.020	
18.01	9.001	7.705	4.827	0.000	0.339	0.022	
19.01	8.875	7.705	4.954	0.000	0.221	0.012	
20.01	9.588	7.651	11.020	0.000	0.312	0.015	
21.01	9.377	7.623	8.329	0.000	0.430	0.024	
22.01	9.701	7.674	5.836	0.000	0.360	0.025	
23.01	9.296	7.695	5.376	0.000	0.300	0.032	
24.01	9.225	7.695	4.851	0.000	0.289	0.028	
25.01	8.650	7.683	5.017	0.000	0.302	0.052	
26.01	9.169	7.622	8.157	0.000	0.290	0.047	
27.01	8.879	7.675	12.269	0.000	0.281	0.035	
28.01	9.127	7.676	9.129	0.000	0.285	0.067	
29.01	9.187	7.830	6.809	0.003	0.269	0.033	
30.01	9.072	7.669	6.438	0.000	0.310	0.024	
31.01	9.563	7.650	6.185	0.000	0.577	0.038	
min	8.457	7.613	3.676	0.000	0.221	0.007	
max	10.457	7.830	12.269	0.005	0.669	0.079	
MMV	9.253	7.677	6.144	0.000	0.366	0.029	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							

Menesine ataskaita: 01.2022



UAB Fortum Klaipeda		sugeneruota: 1.02.2022				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.01	0.019	0.000	131.822	0.003	X	220093.60
2.01	0.019	0.000	131.811	0.002	X	222116.73
3.01	0.019	0.000	131.005	0.002	X	220492.25
4.01	0.019	0.001	131.113	0.011	X	219970.95
5.01	0.019	0.013	130.508	0.013	X	221114.73
6.01	0.020	0.000	132.176	0.001	X	215774.12
7.01	0.019	0.000	131.326	0.006	X	219065.45
8.01	0.019	0.000	132.070	0.007	X	220849.60
9.01	0.019	0.001	131.279	0.006	X	221767.89
10.01	0.020	0.000	131.663	0.014	X	221578.60
11.01	0.020	0.000	131.650	0.008	X	219840.07
12.01	0.020	0.000	131.412	0.003	X	221833.39
13.01	0.020	0.000	131.525	0.001	X	220277.68
14.01	0.019	0.000	131.463	0.001	X	219430.37
15.01	0.019	0.000	131.756	0.007	0.102	222584.48
16.01	0.019	0.000	131.279	0.006	0.105	222709.14
17.01	0.019	0.003	130.996	0.033	0.105	219951.64
18.01	0.020	0.000	131.620	0.027	0.104	219383.07
19.01	0.019	0.000	131.732	0.009	0.105	221078.98
20.01	0.020	0.000	131.522	0.005	0.109	219789.54
21.01	0.020	0.000	131.810	0.008	0.110	213169.54
22.01	0.021	0.000	131.576	0.006	X	222098.20
23.01	0.020	0.000	131.909	0.008	X	222544.62
24.01	0.020	0.000	130.929	0.006	X	223149.43
25.01	0.020	0.000	131.957	0.000	X	220225.79
26.01	0.020	0.000	131.736	0.025	X	220869.37
27.01	0.019	0.010	131.860	0.018	X	221895.20
28.01	0.020	0.000	131.653	0.006	X	223870.81
29.01	0.020	0.002	132.879	0.006	X	221785.95
30.01	0.019	0.000	131.303	0.003	X	221952.00
31.01	0.020	0.000	131.455	0.019	X	219469.29
min	0.019	0.000	130.508	0.000	0.102	213169.54
max	0.021	0.013	132.879	0.033	0.110	223870.81
MMV	0.020	0.001	131.574	0.009	0.105	220668.68
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 01.2022



	UAB Fortum Klaipeda			sugeneruota: 1.02.2022		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.01	43.460	1029.128	6.393	1012.049	1034.315	5.227
2.01	45.046	1023.989	6.135	1007.090	1053.931	5.127
3.01	42.807	1012.323	6.254	994.793	1063.923	6.325
4.01	43.168	1008.323	6.292	991.423	1054.185	6.264
5.01	44.037	1004.798	6.069	988.838	1046.167	7.394
6.01	44.824	1014.667	6.549	999.401	1024.959	5.363
7.01	44.950	1026.137	6.242	1009.805	1001.824	7.795
8.01	45.753	1021.593	5.990	1006.348	1032.904	5.805
9.01	45.658	1021.367	5.958	1005.422	1027.467	7.158
10.01	47.266	1037.002	6.137	1021.466	1034.877	6.014
11.01	46.759	1049.363	6.148	1033.548	1022.633	4.449
12.01	46.836	1045.844	6.142	1028.776	1031.620	4.084
13.01	43.438	1033.149	6.303	1014.603	1038.890	6.027
14.01	43.224	1023.912	6.260	1006.154	997.480	6.551
15.01	44.160	1033.811	6.016	1016.899	1029.022	5.716
16.01	45.005	1026.748	6.014	1010.366	1037.715	4.543
17.01	44.665	1014.703	6.149	998.332	998.815	7.573
18.01	44.374	1039.019	6.268	1022.058	1007.870	5.373
19.01	43.960	1029.561	6.181	1012.435	1005.143	5.484
20.01	45.240	1007.855	6.336	992.474	970.419	12.205
21.01	44.935	1018.423	6.381	1002.702	988.783	9.272
22.01	45.783	1031.863	6.007	1016.310	1037.599	6.486
23.01	45.029	1043.642	5.999	1026.636	1051.605	5.975
24.01	44.877	1043.712	6.002	1026.361	1047.306	5.389
25.01	43.556	1037.919	6.223	1020.099	1026.349	5.580
26.01	44.636	1031.564	6.163	1015.124	1006.529	9.066
27.01	43.803	1016.537	6.149	999.388	1001.809	13.699
28.01	44.357	1018.005	5.920	1001.578	1014.172	10.116
29.01	44.523	1019.531	6.042	1003.051	1036.365	7.603
30.01	43.997	998.044	5.971	982.055	1039.732	7.158
31.01	45.239	1012.743	6.101	997.288	1028.262	6.882
min	42.807	998.044	5.920	982.055	970.419	4.084
max	47.266	1049.363	6.549	1033.548	1063.923	13.699
MMV	44.689	1025.008	6.155	1008.480	1025.570	6.827
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 01.2022



	UAB Fortum Klaipeda						sugeneruota: 1.02.2022
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.01	0.000	0.043	0.032	164.777	0.004	X	
2.01	0.000	0.014	0.032	164.763	0.003	X	
3.01	0.006	0.013	0.032	163.756	0.002	X	
4.01	0.000	0.025	0.032	163.891	0.016	X	
5.01	0.000	0.017	0.032	163.136	0.019	X	
6.01	0.000	0.024	0.033	165.220	0.002	X	
7.01	0.000	0.047	0.032	164.158	0.008	X	
8.01	0.000	0.028	0.032	165.087	0.010	X	
9.01	0.000	0.011	0.032	164.098	0.009	X	
10.01	0.000	0.028	0.033	164.578	0.020	X	
11.01	0.000	0.066	0.033	164.563	0.011	X	
12.01	0.000	0.132	0.033	164.265	0.004	X	
13.01	0.000	0.106	0.033	164.407	0.001	X	
14.01	0.000	0.036	0.032	164.329	0.001	X	
15.01	0.000	0.072	0.032	164.695	0.010	0.145	
16.01	0.000	0.044	0.032	164.099	0.009	0.149	
17.01	0.000	0.034	0.032	163.746	0.047	0.150	
18.01	0.000	0.036	0.033	164.524	0.038	0.148	
19.01	0.000	0.021	0.032	164.665	0.013	0.150	
20.01	0.000	0.025	0.034	164.403	0.007	0.156	
21.01	0.000	0.041	0.034	164.762	0.011	0.157	
22.01	0.000	0.041	0.035	164.470	0.008	X	
23.01	0.000	0.054	0.034	164.886	0.011	X	
24.01	0.000	0.047	0.034	163.661	0.009	X	
25.01	0.000	0.086	0.033	164.947	0.000	X	
26.01	0.000	0.078	0.033	164.670	0.036	X	
27.01	0.000	0.058	0.032	164.825	0.026	X	
28.01	0.000	0.111	0.033	164.566	0.008	X	
29.01	0.004	0.055	0.034	166.099	0.009	X	
30.01	0.000	0.041	0.032	164.129	0.005	X	
31.01	0.000	0.064	0.033	164.319	0.027	X	
min	0.000	0.011	0.032	163.136	0.000	0.145	
max	0.006	0.132	0.035	166.099	0.047	0.157	
MMV	0.000	0.048	0.033	164.468	0.012	0.150	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							