

Menesine ataskaita: 01.2024



	UAB Gren Klaipeda						sugeneruota: 1.02.2024	
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc		
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.		
1.01	9.947	7.624	5.972	2.401	0.130	0.000		
2.01	11.727	7.579	7.276	3.266	0.591	0.000		
3.01	13.238	7.524	8.679	3.222	1.984	0.000		
4.01	14.161	7.498	5.744	3.567	0.920	0.000		
5.01	13.334	7.577	5.104	3.703	0.257	0.000		
6.01	12.141	7.656	9.986	2.700	0.175	0.001		
7.01	15.150	7.612	5.155	3.429	0.565	0.000		
8.01	15.423	7.606	4.134	2.343	0.640	0.000		
9.01	10.484	7.736	6.701	1.802	0.184	0.003		
10.01	9.194	7.754	7.586	1.512	0.104	0.001		
11.01	9.391	7.735	4.436	1.844	0.095	0.001		
12.01	10.616	7.669	5.980	4.124	0.126	0.001		
13.01	11.439	7.677	7.968	2.805	0.220	0.002		
14.01	10.121	7.635	8.676	2.462	0.176	0.002		
15.01	10.144	7.644	9.931	2.485	0.257	0.009		
16.01	11.639	7.658	12.004	2.345	1.992	0.004		
17.01	13.321	7.516	13.869	2.559	3.218	0.000		
18.01	11.279	7.617	13.778	2.280	0.720	0.001		
19.01	10.310	7.666	7.973	2.437	0.259	0.007		
20.01	10.473	7.657	8.219	2.072	0.150	0.004		
21.01	10.687	7.725	6.355	1.958	0.167	0.001		
22.01	9.985	7.720	7.518	1.977	0.110	0.009		
23.01	9.465	7.698	8.208	1.887	0.112	0.006		
24.01	9.833	7.663	6.413	2.271	0.116	0.003		
25.01	9.539	7.688	8.172	1.808	0.108	0.003		
26.01	9.877	7.736	8.425	2.578	0.119	0.001		
27.01	9.851	7.672	6.939	2.336	0.121	0.001		
28.01	10.745	7.733	4.533	1.960	0.181	0.002		
29.01	10.035	7.743	5.923	1.905	0.145	0.001		
30.01	9.987	7.759	5.618	1.786	0.187	0.006		
31.01	10.550	7.746	6.186	2.250	0.270	0.010		
min	9.194	7.498	4.134	1.512	0.095	0.000		
max	15.423	7.759	13.869	4.124	3.218	0.010		
MMV	11.098	7.662	7.530	2.453	0.463	0.003		
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down								

Menesine ataskaita: 01.2024



	UAB Gren Klaipeda sugeneruota: 1.02.2024					
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.01	0.084	0.000	143.487	0.000	0.723	184402.79
2.01	0.087	0.000	143.958	0.000	0.837	183207.06
3.01	0.091	0.000	143.569	0.000	0.740	188915.10
4.01	0.089	0.000	143.515	0.000	0.606	186363.51
5.01	0.090	0.000	139.578	0.000	0.481	187802.29
6.01	0.091	0.000	135.992	0.000	0.616	188903.35
7.01	0.093	0.000	135.235	0.000	0.696	185057.40
8.01	0.094	0.000	135.737	0.000	0.738	184693.21
9.01	0.078	0.000	135.477	0.000	0.551	189398.07
10.01	0.078	0.000	135.695	0.000	0.414	187562.14
11.01	0.081	0.000	135.730	0.000	0.569	187999.10
12.01	0.084	0.000	135.682	0.000	0.595	190924.89
13.01	0.076	0.000	135.688	0.000	0.560	189912.64
14.01	0.077	0.000	135.646	0.000	0.518	192476.87
15.01	0.078	0.000	135.456	0.000	0.506	192159.93
16.01	0.100	0.000	135.707	0.000	0.719	188927.93
17.01	0.099	0.000	135.794	0.000	0.805	188546.81
18.01	0.091	0.000	135.319	0.000	0.517	192584.64
19.01	0.084	0.000	135.904	0.000	0.561	191665.54
20.01	0.084	0.000	135.104	0.000	0.537	190957.01
21.01	0.087	0.000	135.008	0.000	0.653	189781.45
22.01	0.080	0.000	135.694	0.000	0.631	191396.79
23.01	0.080	0.000	135.168	0.000	0.567	190274.25
24.01	0.084	0.000	135.843	0.000	X	188674.06
25.01	0.081	0.000	135.637	0.000	X	188161.23
26.01	0.086	0.000	135.704	0.000	0.683	187833.00
27.01	0.086	0.000	135.314	0.000	0.672	188784.81
28.01	0.088	0.000	135.559	0.000	0.640	191027.70
29.01	0.083	0.000	135.559	0.000	0.530	188741.26
30.01	0.087	0.000	135.401	0.000	0.669	188896.50
31.01	0.084	0.000	135.561	0.000	0.578	191125.68
min	0.076	0.000	135.008	0.000	0.414	183207.06
max	0.100	0.000	143.958	0.000	0.837	192584.64
MMV	0.086	0.000	136.728	0.000	0.619	189063.54
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 01.2024



	UAB Gren Klaipeda			sugeneruota: 1.02.2024		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.01	45.558	1024.751	7.041	1007.942	1014.357	6.428
2.01	48.745	1021.876	6.859	1007.260	981.254	7.892
3.01	50.934	1012.876	6.971	999.108	967.485	9.491
4.01	52.224	1009.093	6.818	995.678	1007.947	6.142
5.01	51.161	1019.536	6.954	1003.128	1015.089	5.427
6.01	49.503	1031.653	6.971	1014.243	969.108	10.944
7.01	53.910	1040.128	6.706	1025.979	1013.279	5.475
8.01	54.431	1049.829	6.723	1033.544	1018.156	4.345
9.01	46.774	1050.905	7.304	1029.351	1017.568	7.241
10.01	44.365	1044.841	7.440	1023.920	990.402	8.226
11.01	44.647	1036.495	7.117	1017.339	1002.370	4.688
12.01	46.858	1033.196	6.933	1014.484	993.810	6.452
13.01	48.141	1021.993	6.924	1005.391	994.886	8.692
14.01	45.649	1007.545	6.749	987.997	996.242	9.486
15.01	45.615	997.853	6.797	979.182	999.962	10.880
16.01	48.418	1011.205	6.950	995.004	975.961	13.201
17.01	51.065	1015.181	7.088	1000.044	973.420	15.342
18.01	47.710	1007.271	6.743	988.635	971.447	15.221
19.01	46.189	1019.978	6.858	1000.424	993.393	8.670
20.01	46.568	1029.213	6.962	1010.455	996.243	8.980
21.01	47.021	1042.331	6.807	1023.485	1014.862	6.855
22.01	45.505	1026.218	6.940	1006.462	1001.193	8.194
23.01	44.645	1025.271	7.433	1004.962	992.693	8.930
24.01	44.972	1016.428	7.031	997.075	991.584	6.932
25.01	44.528	1021.289	7.118	1002.497	981.248	8.891
26.01	45.463	1033.490	7.050	1014.965	979.327	9.193
27.01	45.407	1033.981	7.090	1014.806	985.138	7.502
28.01	47.311	1049.840	6.823	1029.745	1013.312	4.817
29.01	45.924	1048.506	7.102	1029.278	1003.845	6.369
30.01	45.817	1044.914	7.076	1025.257	1005.546	6.028
31.01	46.779	1038.422	6.810	1018.897	1008.122	6.698
min	44.365	997.853	6.706	979.182	967.485	4.345
max	54.431	1050.905	7.440	1033.544	1018.156	15.342
MMV	47.479	1027.937	6.974	1009.889	995.783	8.181
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 01.2024



	UAB Gren Klaipeda						sugeneruota: 1.02.2024
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.01	3.001	0.001	0.090	186.419	0.000	0.654	
2.01	4.083	0.000	0.096	187.052	0.000	0.814	
3.01	4.027	0.000	0.101	186.681	0.000	0.650	
4.01	4.458	0.000	0.098	186.612	0.000	0.454	
5.01	4.628	0.000	0.099	181.629	0.000	0.275	
6.01	3.375	0.001	0.102	177.030	0.000	0.487	
7.01	4.286	0.000	0.104	176.150	0.000	0.595	
8.01	2.929	0.000	0.106	176.809	0.000	0.658	
9.01	2.252	0.005	0.080	176.404	0.000	0.401	
10.01	1.890	0.002	0.080	176.657	0.000	0.202	
11.01	2.305	0.001	0.087	176.597	0.000	0.434	
12.01	5.155	0.001	0.091	176.540	0.000	0.469	
13.01	3.507	0.003	0.077	176.589	0.000	0.408	
14.01	3.077	0.003	0.081	176.405	0.000	0.355	
15.01	3.106	0.015	0.082	176.182	0.000	0.332	
16.01	2.932	0.006	0.117	176.632	0.000	0.634	
17.01	3.199	0.001	0.113	176.888	0.000	0.746	
18.01	2.849	0.001	0.103	176.052	0.000	0.345	
19.01	3.047	0.012	0.091	176.777	0.000	0.417	
20.01	2.590	0.007	0.091	175.809	0.000	0.382	
21.01	2.447	0.001	0.097	175.647	0.000	0.560	
22.01	2.471	0.016	0.084	176.523	0.000	0.522	
23.01	2.359	0.009	0.083	176.005	0.000	0.417	
24.01	2.839	0.004	0.091	176.739	0.000	X	
25.01	2.260	0.005	0.086	176.490	0.000	X	
26.01	3.223	0.002	0.095	176.568	0.000	0.600	
27.01	2.920	0.001	0.094	176.086	0.000	0.582	
28.01	2.450	0.003	0.098	176.353	0.000	0.542	
29.01	2.381	0.002	0.089	176.413	0.000	0.378	
30.01	2.232	0.011	0.095	176.199	0.000	0.581	
31.01	2.812	0.016	0.092	176.343	0.000	0.449	
min	1.890	0.000	0.077	175.647	0.000	0.202	
max	5.155	0.016	0.117	187.052	0.000	0.814	
MMV	3.067	0.004	0.093	177.906	0.000	0.496	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							