

Menesine ataskaita: 02.2014



		UAB Fortum Klaipeda					sugeneruota: 1.03.2014	
		KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena		Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.02		11.467	11.979	7.295	0.244	0.769	0.877	
2.02		10.712	11.939	7.458	0.366	0.698	0.714	
3.02		11.133	12.000	9.164	0.669	0.671	0.826	
4.02		11.984	12.040	11.989	0.835	0.739	0.797	
5.02		12.362	12.290	13.570	1.032	0.693	0.798	
6.02	D	706.869	12.389	12.714	4.075	0.711	0.761	
7.02		15.620	12.240	11.546	2.137	0.872	0.939	
8.02		16.676	12.080	9.161	0.167	1.003	0.903	
9.02		17.995	12.084	9.314	3.971	0.978	0.821	
10.02		8.759	10.260	25.157	3.403	1.147	0.822	
11.02		11.188	11.556	17.745	2.165	0.867	0.906	
12.02		13.367	11.774	12.443	3.787	0.737	0.963	
13.02		11.248	12.277	11.471	0.889	0.776	0.734	
14.02		11.055	12.374	10.412	3.449	0.767	0.723	
15.02		15.301	12.500	10.058	3.715	0.915	0.709	
16.02		15.539	12.196	8.773	2.922	0.833	0.856	
17.02		14.882	12.256	9.492	2.951	1.218	0.819	
18.02		14.338	12.486	9.593	2.524	0.956	0.619	
19.02		16.482	12.394	8.361	5.908	0.897	0.771	
20.02		16.810	12.489	8.786	4.601	0.805	0.829	
21.02		16.902	12.370	9.413	3.713	0.894	0.962	
22.02		14.593	12.288	10.151	3.828	0.883	0.853	
23.02		13.367	12.312	8.297	2.591	0.877	0.819	
24.02		16.034	12.252	7.542	2.652	1.300	0.763	
25.02		X	X	X	X	X	X	
26.02		X	X	X	X	X	X	
27.02		X	X	X	X	X	X	
28.02		X	X	X	X	X	X	
min		8.759	10.260	7.295	0.167	0.671	0.619	
max	D	706.869	12.500	25.157	5.908	1.300	0.963	
MMV		41.199	12.183	10.187	3.206	0.854	0.778	
		- = Out of op < = <2/3		X = no daily classing		N = No Data		
		M = Maintenance		S = Fault				
		D = >DLV		A = Start-up/shut down				

Menesine ataskaita: 02.2014



UAB Fortum Klaipeda		sugeneruota: 1.03.2014				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.02	0.279	0.000	142.670	1.043	0.403	168685.26
2.02	0.263	0.000	139.685	0.942	0.511	176084.39
3.02	0.249	0.000	148.899	0.808	0.367	192406.56
4.02	0.336	0.000	141.625	0.956	0.502	202625.04
5.02	0.331	0.000	147.015	0.959	0.439	201399.23
6.02	0.401	0.000	151.832	1.126	0.441	199546.54
7.02	0.559	0.000	150.089	1.273	0.405	199438.51
8.02	0.573	0.000	150.411	1.289	0.252	196100.70
9.02	0.609	0.000	152.346	1.389	0.297	201896.87
10.02	0.353	0.165	136.171	1.349	0.348	87893.555
11.02	0.254	0.000	152.924	0.953	0.424	145317.90
12.02	0.473	0.000	144.185	1.082	0.284	196870.43
13.02	0.351	0.000	147.407	0.882	0.338	192313.31
14.02	0.311	0.000	139.971	1.085	0.316	194264.10
15.02	0.578	0.000	152.374	1.255	0.343	201938.26
16.02	0.613	0.000	142.603	1.345	0.261	198715.82
17.02	0.575	0.000	142.649	1.188	0.191	195691.73
18.02	0.511	0.000	144.745	1.106	0.180	193747.95
19.02	0.700	0.000	149.307	1.195	0.210	198733.57
20.02	0.708	0.000	153.231	1.303	0.280	201538.87
21.02	0.583	0.000	153.439	1.223	0.369	203169.01
22.02	0.459	0.000	144.149	1.150	0.275	197392.73
23.02	0.441	0.000	131.420	0.979	0.222	193742.62
24.02	0.579	0.000	138.453	1.111	0.211	202671.35
25.02	X	X	X	X	0.201	172972.46
26.02	X	X	X	X	0.345	159895.20
27.02	X	X	X	X	0.373	151549.89
28.02	X	X	X	X	0.250	173065.54
min	0.249	0.000	131.420	0.808	0.180	87893.555
max	0.708	0.165	153.439	1.389	0.511	203169.01
MMV	0.444	0.013	143.152	1.086	0.321	185702.42
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data						

Menesine ataskaita: 02.2014



UAB Fortum Klaipeda		sugeneruota: 1.03.2014				
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	
Diena	°C	mbar	Vol%	mbar	°C	
1.02	47.890	1014.300	6.726	1014.476	1023.475	
2.02	46.521	1015.980	6.774	1016.016	1025.586	
3.02	47.387	1021.542	6.691	1021.992	1029.818	
4.02	48.963	1016.399	6.532	1018.243	1035.344	
5.02	49.553	1007.689	6.306	1009.708	1031.995	
6.02	51.260	1002.357	6.047	1003.667	1019.587	
7.02	54.602	1000.541	5.849	1001.354	995.381	
8.02	56.283	996.898	5.772	998.199	1015.617	
9.02	58.077	995.459	5.689	997.620	1019.303	
10.02	76.247	998.873	11.537	1001.516	920.823	
11.02	71.539	999.385	7.422	1002.388	944.049	
12.02	51.062	1002.518	6.423	1004.062	968.302	
13.02	47.307	1000.261	6.245	1003.042	990.344	
14.02	46.878	999.067	6.228	1001.780	994.987	
15.02	54.254	1004.587	5.903	1006.303	1004.514	
16.02	54.558	998.259	5.834	999.897	996.873	
17.02	53.707	1001.391	5.912	1003.709	999.067	
18.02	52.884	1008.816	5.939	1010.952	1029.241	
19.02	56.052	1004.702	5.754	1006.417	1041.088	
20.02	56.575	1003.869	5.734	1006.258	1028.260	
21.02	56.635	1005.641	5.717	1006.770	1006.358	
22.02	53.267	1007.293	5.918	1009.712	1007.522	
23.02	51.443	1017.762	6.006	1019.935	1018.184	
24.02	55.519	1023.096	5.860	1024.863	1023.481	
25.02	55.117	1019.390	X	1019.558	1033.817	
26.02	53.207	1016.019	X	1017.108	1041.944	
27.02	53.869	1016.303	X	1018.564	1060.475	
28.02	51.602	1001.208	X	1003.506	1057.090	
min	46.521	995.459	5.689	997.620	920.823	
max	76.247	1023.096	11.537	1024.863	1060.475	
MMV	53.811	1007.207	6.259	1008.910	1015.833	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						