

# Menesine ataskaita: 02.2017



	UAB Fortum Klaipeda sugeneruota: 1.03.2017					
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.02	9.161	18.605	2.943	0.405	0.000	0.288
2.02	8.720	18.829	1.518	0.598	0.000	0.244
3.02	8.400	18.802	3.905	0.780	0.000	0.449
4.02	8.356	18.801	5.985	1.440	0.000	0.319
5.02	8.572	18.808	5.085	0.861	0.000	0.296
6.02	9.000	18.833	3.413	0.815	0.000	0.307
7.02	11.258	19.123	3.252	7.507	0.000	0.352
8.02	11.646	18.680	4.695	2.094	0.000	0.388
9.02	10.299	18.128	5.421	0.486	0.000	0.338
10.02	9.283	18.109	3.222	0.730	0.000	0.275
11.02	9.618	18.262	6.034	0.798	0.000	0.370
12.02	9.472	18.271	4.718	5.099	0.000	0.344
13.02	9.753	18.302	4.070	1.989	0.000	0.373
14.02	8.133	18.331	4.212	0.544	0.000	0.409
15.02	7.976	18.318	4.294	0.240	0.000	0.362
16.02	8.109	18.283	4.626	0.134	0.000	0.322
17.02	8.412	18.416	4.945	2.659	0.000	0.285
18.02	8.842	18.286	5.703	0.563	0.000	0.402
19.02	8.486	18.274	3.271	1.667	0.000	0.418
20.02	7.963	18.339	3.675	4.715	0.000	0.398
21.02	7.986	18.408	3.113	2.117	0.000	0.341
22.02	8.818	18.429	3.078	1.188	0.000	0.247
23.02	7.911	18.433	4.000	1.011	0.000	0.268
24.02	8.419	18.299	3.570	3.400	0.000	0.341
25.02	8.224	18.483	4.709	0.975	0.000	0.401
26.02	10.071	18.444	3.329	1.666	0.000	0.429
27.02	11.203	18.259	2.704	1.252	0.000	0.444
28.02	9.738	18.471	1.701	1.219	0.000	0.382
min	7.911	18.109	1.518	0.134	0.000	0.244
max	11.646	19.123	6.034	7.507	0.000	0.449
MMV	9.064	18.465	3.972	1.679	0.000	0.350
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                S = Fault D = >DLV                            A = Start-up/shut down						

# Menesine ataskaita: 02.2017



	UAB Fortum Klaipeda						sugeneruota: 1.03.2017
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.02	0.074	0.000	182.727	0.092	0.514	210513.26	
2.02	0.074	0.000	180.902	0.179	0.559	210586.26	
3.02	0.074	0.000	174.521	0.124	0.530	208104.37	
4.02	0.075	0.000	172.933	0.136	0.605	208343.57	
5.02	0.074	0.000	175.431	0.119	0.617	209928.25	
6.02	0.073	0.000	175.400	0.129	0.776	211320.57	
7.02	0.075	0.014	175.386	0.301	0.803	213591.29	
8.02	0.075	0.001	172.454	0.253	0.643	214109.07	
9.02	0.078	0.000	174.521	0.196	0.452	217291.12	
10.02	0.081	0.000	174.122	0.113	0.612	217036.89	
11.02	0.080	0.000	174.866	0.134	0.545	216853.01	
12.02	0.081	0.001	175.439	0.097	0.555	216642.76	
13.02	0.080	0.001	173.564	0.151	0.584	218010.01	
14.02	0.079	0.002	174.577	0.168	0.520	216828.17	
15.02	0.079	0.001	175.075	0.170	0.637	214345.82	
16.02	0.085	0.002	175.374	0.124	0.579	216182.76	
17.02	0.090	0.000	174.049	0.158	0.503	216737.82	
18.02	0.086	0.001	172.456	0.230	0.720	217208.67	
19.02	0.085	0.000	176.867	0.189	0.582	216840.45	
20.02	0.087	0.000	175.206	0.174	0.570	216641.12	
21.02	0.090	0.000	177.877	0.242	0.597	216524.12	
22.02	0.086	0.000	177.466	0.206	0.708	213439.12	
23.02	0.089	0.000	178.153	0.233	0.518	214077.39	
24.02	0.085	0.000	173.740	0.168	0.541	216577.51	
25.02	0.085	0.000	174.473	0.183	0.615	218725.10	
26.02	0.090	0.000	178.531	0.163	0.642	220974.57	
27.02	0.098	0.000	176.584	0.140	0.725	223387.25	
28.02	0.088	0.000	182.656	0.119	0.654	221003.56	
min	0.073	0.000	172.454	0.092	0.452	208104.37	
max	0.098	0.014	182.727	0.301	0.803	223387.25	
MMV	0.082	0.001	175.902	0.167	0.604	215422.17	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 02.2017



	UAB Fortum Klaipeda			sugeneruota: 1.03.2017		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.02	45.118	1027.095	5.383	1023.577	1037.373	2.952
2.02	44.099	1022.551	5.245	1017.675	1063.391	1.519
3.02	43.350	1017.371	5.268	1012.534	1091.413	3.870
4.02	43.235	1014.922	5.254	1010.828	1076.167	5.994
5.02	43.673	1015.171	5.266	1011.206	1051.601	5.087
6.02	44.691	1023.878	5.202	1021.401	1067.200	3.419
7.02	48.934	1031.240	5.050	1030.508	1100.556	3.232
8.02	49.598	1038.059	5.299	1036.377	1072.018	4.635
9.02	47.312	1041.570	5.663	1037.617	1056.413	5.334
10.02	45.550	1043.147	5.773	1038.322	1084.334	3.228
11.02	46.106	1042.694	5.762	1038.603	1055.682	6.044
12.02	45.904	1043.472	5.719	1039.603	1052.226	4.718
13.02	46.332	1040.365	5.621	1035.724	1059.428	4.070
14.02	42.995	1036.041	5.695	1029.245	1058.046	4.216
15.02	42.690	1037.212	5.640	1032.055	1049.239	4.289
16.02	42.824	1027.405	5.690	1022.228	1072.580	4.623
17.02	43.389	1018.592	5.572	1013.534	1052.964	4.954
18.02	44.051	1021.180	5.578	1016.406	1051.825	5.690
19.02	43.359	1015.942	5.579	1011.160	1070.109	3.270
20.02	42.180	1003.607	5.494	998.809	1072.082	3.671
21.02	42.152	993.299	5.481	988.995	1049.862	3.119
22.02	44.004	994.700	5.420	991.144	1054.033	3.073
23.02	41.915	988.820	5.499	984.192	1077.982	3.980
24.02	43.159	992.311	5.550	989.270	1063.993	3.582
25.02	42.922	1010.707	5.522	1006.269	1049.040	4.712
26.02	46.416	1005.633	5.292	1001.141	1057.464	3.338
27.02	48.496	1009.162	5.253	1003.534	1056.927	2.694
28.02	45.803	999.684	5.304	994.540	1077.917	1.707
min	41.915	988.820	5.050	984.192	1037.373	1.519
max	49.598	1043.472	5.773	1039.603	1100.556	6.044
MMV	44.652	1019.851	5.467	1015.590	1063.638	3.965
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 02.2017



	UAB Fortum Klaipeda						sugeneruota: 1.03.2017
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.02	0.405	0.288	0.074	182.727	0.092	0.514	
2.02	0.598	0.244	0.074	180.902	0.179	0.559	
3.02	0.780	0.449	0.074	174.521	0.124	0.530	
4.02	1.440	0.319	0.075	172.933	0.136	0.605	
5.02	0.861	0.296	0.074	175.431	0.119	0.617	
6.02	0.815	0.307	0.073	175.400	0.129	0.776	
7.02	7.507	0.352	0.075	175.386	0.301	0.803	
8.02	2.094	0.388	0.075	172.454	0.253	0.643	
9.02	0.486	0.338	0.078	174.521	0.196	0.452	
10.02	0.730	0.275	0.081	174.122	0.113	0.612	
11.02	0.798	0.370	0.080	174.866	0.134	0.545	
12.02	5.099	0.344	0.081	175.439	0.097	0.555	
13.02	1.989	0.373	0.080	173.564	0.151	0.584	
14.02	0.544	0.409	0.079	174.577	0.168	0.520	
15.02	0.240	0.362	0.079	175.075	0.170	0.637	
16.02	0.134	0.322	0.085	175.374	0.124	0.579	
17.02	2.659	0.285	0.090	174.049	0.158	0.503	
18.02	0.563	0.402	0.086	172.456	0.230	0.720	
19.02	1.667	0.418	0.085	176.867	0.189	0.582	
20.02	4.715	0.398	0.087	175.206	0.174	0.570	
21.02	2.117	0.341	0.090	177.877	0.242	0.597	
22.02	1.188	0.247	0.086	177.466	0.206	0.708	
23.02	1.011	0.268	0.089	178.153	0.233	0.518	
24.02	3.400	0.341	0.085	173.740	0.168	0.541	
25.02	0.975	0.401	0.085	174.473	0.183	0.615	
26.02	1.666	0.429	0.090	178.531	0.163	0.642	
27.02	1.252	0.444	0.098	176.584	0.140	0.725	
28.02	1.219	0.382	0.088	182.656	0.119	0.654	
min	0.134	0.244	0.073	172.454	0.092	0.452	
max	7.507	0.449	0.098	182.727	0.301	0.803	
MMV	1.679	0.350	0.082	175.902	0.167	0.604	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							