

# Menesine ataskaita: 02.2020



	UAB Fortum Klaipeda						sugeneruota: 1.03.2020
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.02	8.025	7.651	7.057	0.000	0.210	0.003	
2.02	8.035	7.677	4.666	0.000	0.239	0.010	
3.02	8.292	7.634	3.622	0.000	0.216	0.005	
4.02	8.829	7.713	6.946	0.000	0.190	0.007	
5.02	9.570	7.648	12.104	0.000	0.202	0.006	
6.02	8.241	7.703	8.136	0.008	0.241	0.009	
7.02	9.121	7.717	5.954	0.014	0.207	0.006	
8.02	8.509	7.754	4.634	0.000	0.226	0.007	
9.02	8.293	7.737	3.593	0.000	0.244	0.003	
10.02	8.212	7.633	8.481	0.000	0.262	0.001	
11.02	8.367	7.684	5.935	0.000	0.273	0.007	
12.02	8.339	7.659	4.572	0.000	0.281	0.004	
13.02	8.111	7.702	5.631	0.000	0.246	0.005	
14.02	8.874	7.732	7.165	0.211	0.255	0.007	
15.02	8.625	7.748	4.632	0.050	0.281	0.003	
16.02	8.204	7.763	4.377	0.037	0.299	0.009	
17.02	8.740	7.670	6.105	0.000	0.393	0.008	
18.02	7.925	7.718	6.094	0.000	0.267	0.002	
19.02	7.912	7.736	4.229	0.000	0.242	0.001	
20.02	7.922	7.718	7.177	0.000	0.257	0.001	
21.02	8.059	7.625	9.328	0.000	0.265	0.014	
22.02	7.981	7.665	9.668	0.000	0.226	0.010	
23.02	7.931	7.724	8.259	0.000	0.222	0.010	
24.02	8.128	7.673	5.262	0.143	0.246	0.003	
25.02	8.524	7.647	8.451	0.000	0.227	0.004	
26.02	8.131	7.656	6.722	0.000	0.227	0.002	
27.02	8.768	7.680	5.641	0.006	0.230	0.001	
28.02	8.551	7.741	5.370	0.103	0.200	0.003	
29.02	8.500	7.741	4.826	0.067	0.228	0.006	
min	7.912	7.625	3.593	0.000	0.190	0.001	
max	9.570	7.763	12.104	0.211	0.393	0.014	
MMV	8.370	7.695	6.365	0.022	0.245	0.005	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 02.2020



	UAB Fortum Klaipeda						sugeneruota: 1.03.2020
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.02	0.069	0.217	127.741	0.001	0.222	214300.48	
2.02	0.066	0.222	127.602	0.000	0.161	214646.92	
3.02	0.067	0.231	127.412	0.000	0.204	214914.92	
4.02	0.063	0.175	127.694	0.000	0.243	215348.56	
5.02	0.059	0.131	127.360	0.000	0.144	218909.10	
6.02	0.055	0.182	127.432	0.000	0.212	214858.81	
7.02	0.035	0.019	127.717	0.000	0.172	216589.54	
8.02	0.046	0.040	128.238	0.000	0.273	213563.26	
9.02	0.050	0.117	127.426	0.000	0.165	213760.85	
10.02	0.074	0.209	127.710	0.001	0.176	214517.39	
11.02	0.074	0.205	127.751	0.000	0.203	213243.37	
12.02	0.069	0.189	127.587	0.000	0.207	213856.70	
13.02	0.064	0.213	127.180	0.000	0.222	213774.68	
14.02	0.064	0.198	127.564	0.000	0.120	216707.70	
15.02	0.055	0.189	127.744	0.000	0.227	214660.68	
16.02	0.064	0.202	127.589	0.000	0.253	214417.54	
17.02	0.074	0.228	127.290	0.000	0.156	213610.45	
18.02	0.061	0.209	127.610	0.000	0.165	210657.04	
19.02	0.070	0.182	126.831	0.000	0.216	212255.01	
20.02	0.069	0.214	127.983	0.000	0.174	212746.62	
21.02	0.060	0.207	128.486	0.000	0.246	213128.14	
22.02	0.062	0.193	128.007	0.000	0.176	212794.54	
23.02	0.072	0.240	127.444	0.002	0.134	213622.85	
24.02	0.067	0.232	126.983	0.000	0.153	212079.37	
25.02	0.066	0.214	127.805	0.000	0.176	212551.48	
26.02	0.071	0.218	127.294	0.000	0.210	213933.92	
27.02	0.073	0.179	127.504	0.000	0.171	216148.73	
28.02	0.063	0.198	127.472	0.000	0.169	216656.76	
29.02	0.052	0.130	126.810	0.000	0.196	214446.76	
min	0.035	0.019	126.810	0.000	0.120	210657.04	
max	0.074	0.240	128.486	0.002	0.273	218909.10	
MMV	0.063	0.186	127.560	0.000	0.191	214231.01	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 02.2020



	UAB Fortum Klaipeda			sugeneruota: 1.03.2020		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.02	41.650	1008.146	6.766	994.230	993.504	7.909
2.02	41.590	1002.483	6.572	989.677	1021.206	5.199
3.02	42.323	1009.963	6.624	997.032	1033.134	4.036
4.02	43.362	1010.947	6.724	999.222	1012.570	7.688
5.02	45.215	1028.958	6.537	1016.557	991.511	13.512
6.02	42.410	1027.256	6.964	1014.097	969.397	9.048
7.02	44.309	1038.095	6.646	1025.823	995.117	6.662
8.02	43.102	1035.358	6.829	1021.544	1003.269	5.199
9.02	42.475	1022.968	6.733	1009.628	1025.562	4.005
10.02	41.907	993.420	6.616	980.069	992.903	9.480
11.02	42.325	994.713	6.654	982.287	1007.833	6.585
12.02	42.349	1002.952	6.736	990.094	1024.185	5.084
13.02	41.949	1015.452	6.774	1002.243	1016.807	6.303
14.02	43.724	1027.133	6.671	1013.715	990.557	7.951
15.02	43.317	1032.535	6.717	1019.859	1011.850	5.177
16.02	42.199	1019.986	6.786	1006.200	1019.357	4.878
17.02	43.101	1015.544	6.806	1001.407	1023.336	6.796
18.02	41.577	1018.781	6.813	1005.743	980.924	6.775
19.02	41.523	1018.786	6.857	1005.848	1028.958	4.703
20.02	41.633	1026.249	6.898	1012.808	985.114	7.767
21.02	41.942	1021.573	6.988	1008.744	985.305	10.456
22.02	41.696	1018.076	7.034	1004.924	978.854	10.796
23.02	41.445	1008.557	6.704	995.601	1007.381	9.202
24.02	42.016	1015.544	6.854	1002.097	1029.034	5.869
25.02	42.805	1006.074	6.676	993.509	970.399	9.386
26.02	41.794	999.210	6.697	986.209	1007.051	7.492
27.02	43.270	1002.347	6.554	990.509	1003.488	6.281
28.02	42.940	1013.262	6.571	1000.321	1027.324	5.952
29.02	42.856	1014.758	6.945	1001.288	987.256	5.328
min	41.445	993.420	6.537	980.069	969.397	4.005
max	45.215	1038.095	7.034	1025.823	1033.134	13.512
MMV	42.510	1015.487	6.750	1002.460	1004.248	7.087
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 02.2020



	UAB Fortum Klaipeda						sugeneruota: 1.03.2020
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.02	0.000	0.005	0.115	159.676	0.002	0.317	
2.02	0.000	0.017	0.111	159.502	0.000	0.230	
3.02	0.000	0.008	0.111	159.265	0.000	0.291	
4.02	0.000	0.011	0.105	159.618	0.000	0.348	
5.02	0.000	0.010	0.099	159.200	0.000	0.206	
6.02	0.010	0.014	0.092	159.290	0.000	0.303	
7.02	0.017	0.010	0.059	159.646	0.000	0.246	
8.02	0.000	0.012	0.076	160.297	0.000	0.390	
9.02	0.000	0.004	0.084	159.282	0.000	0.236	
10.02	0.000	0.002	0.123	159.638	0.002	0.251	
11.02	0.000	0.012	0.124	159.689	0.000	0.290	
12.02	0.000	0.007	0.115	159.484	0.000	0.296	
13.02	0.000	0.008	0.106	158.975	0.000	0.317	
14.02	0.263	0.011	0.106	159.455	0.000	0.172	
15.02	0.062	0.005	0.091	159.680	0.000	0.324	
16.02	0.047	0.015	0.107	159.486	0.000	0.361	
17.02	0.000	0.014	0.124	159.113	0.000	0.223	
18.02	0.000	0.003	0.102	159.512	0.000	0.236	
19.02	0.000	0.001	0.117	158.539	0.000	0.309	
20.02	0.000	0.002	0.114	159.979	0.000	0.249	
21.02	0.000	0.024	0.100	160.607	0.000	0.352	
22.02	0.000	0.016	0.103	160.008	0.000	0.251	
23.02	0.000	0.017	0.120	159.305	0.003	0.191	
24.02	0.179	0.005	0.112	158.729	0.000	0.218	
25.02	0.000	0.006	0.111	159.756	0.000	0.251	
26.02	0.000	0.003	0.118	159.118	0.000	0.300	
27.02	0.007	0.002	0.121	159.381	0.000	0.244	
28.02	0.128	0.005	0.105	159.340	0.000	0.241	
29.02	0.084	0.010	0.086	158.513	0.000	0.280	
min	0.000	0.001	0.059	158.513	0.000	0.172	
max	0.263	0.024	0.124	160.607	0.003	0.390	
MMV	0.028	0.009	0.105	159.451	0.000	0.273	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							