

Menesine ataskaita: 02.2021



	UAB Fortum Klaipeda						sugeneruota: 1.03.2021
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.02	16.088	7.433	3.366	0.000	0.978	0.036	
2.02	16.337	7.438	6.219	0.003	0.725	0.079	
3.02	16.460	7.466	7.555	0.000	0.340	0.056	
4.02	17.087	7.537	6.302	0.192	0.412	0.058	
5.02	16.947	7.530	7.052	2.768	0.473	0.121	
6.02	16.800	7.546	7.467	0.000	0.748	0.067	
7.02	17.762	7.541	4.649	0.025	0.784	0.033	
8.02	16.061	7.509	3.593	0.024	0.636	0.011	
9.02	16.060	7.386	5.007	0.105	0.684	0.056	
10.02	14.940	7.399	4.294	0.000	0.553	0.109	
11.02	16.181	7.459	5.969	0.000	0.671	0.048	
12.02	16.258	7.518	6.965	0.173	0.635	0.026	
13.02	15.943	7.435	5.305	0.000	0.544	0.019	
14.02	18.046	7.479	4.225	0.000	0.577	0.035	
15.02	16.737	7.460	4.070	0.164	0.529	0.080	
16.02	16.671	7.528	8.061	2.431	0.561	0.058	
17.02	16.645	7.459	5.937	0.110	1.634	0.024	
18.02	15.342	7.484	3.662	0.000	0.703	0.066	
19.02	16.568	7.432	6.410	0.272	0.506	0.047	
20.02	17.060	7.458	5.073	0.000	0.524	0.012	
21.02	17.299	7.465	4.013	0.000	0.889	0.014	
22.02	16.550	7.427	7.259	0.001	0.761	0.040	
23.02	15.775	7.445	4.352	0.000	0.661	0.025	
24.02	16.321	7.518	5.413	0.000	1.190	0.020	
25.02	16.788	7.609	4.433	0.268	0.495	0.018	
26.02	15.837	7.592	9.055	4.413	0.314	0.091	
27.02	16.853	7.645	7.933	1.417	0.630	0.057	
28.02	17.017	7.581	4.236	0.009	0.621	0.032	
min	14.940	7.386	3.366	0.000	0.314	0.011	
max	18.046	7.645	9.055	4.413	1.634	0.121	
MMV	16.516	7.492	5.638	0.442	0.671	0.048	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 02.2021



	UAB Fortum Klaipeda						sugeneruota: 1.03.2021
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.02	0.023	0.000	131.899	0.010	0.210	221606.79	
2.02	0.023	0.000	130.853	0.003	0.237	221169.45	
3.02	0.024	0.000	132.309	0.003	0.214	221691.50	
4.02	0.024	0.000	131.116	0.013	0.205	223534.31	
5.02	0.022	0.000	131.799	0.010	0.211	223457.25	
6.02	0.023	0.000	132.336	0.006	0.161	222890.98	
7.02	0.025	0.000	131.895	0.019	0.232	225771.87	
8.02	0.022	0.000	131.596	0.003	0.227	220000.18	
9.02	0.022	0.000	131.796	0.001	0.168	219205.67	
10.02	0.022	0.000	131.979	0.012	0.217	217228.98	
11.02	0.022	0.000	131.902	0.015	0.210	220469.48	
12.02	0.022	0.000	130.780	0.008	0.198	220822.54	
13.02	0.025	0.000	131.913	0.041	0.263	220856.10	
14.02	0.027	0.000	132.233	0.074	0.208	228096.82	
15.02	0.026	0.000	131.533	0.063	0.179	223060.56	
16.02	0.028	0.000	131.736	0.043	0.224	222755.79	
17.02	0.028	0.000	131.544	0.046	0.241	221798.39	
18.02	0.025	0.000	131.722	0.007	0.201	217678.51	
19.02	0.027	0.000	131.389	0.066	0.177	222406.04	
20.02	0.029	0.000	132.337	0.103	0.227	224951.32	
21.02	0.031	0.000	131.742	0.122	0.214	226463.95	
22.02	0.027	0.000	131.385	0.070	0.174	223515.50	
23.02	0.026	0.000	132.012	0.100	0.208	219768.20	
24.02	0.029	0.000	131.852	0.077	0.220	222795.04	
25.02	0.031	0.000	131.901	0.115	0.160	224360.62	
26.02	0.034	0.000	130.293	0.056	0.224	221568.85	
27.02	0.028	0.000	131.571	0.033	0.175	225307.54	
28.02	0.027	0.000	131.857	0.109	0.173	224487.04	
min	0.022	0.000	130.293	0.001	0.160	217228.98	
max	0.034	0.000	132.337	0.122	0.263	228096.82	
MMV	0.026	0.000	131.689	0.044	0.206	222418.42	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 02.2021



	UAB Fortum Klaipeda			sugeneruota: 1.03.2021		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.02	55.568	1017.078	6.101	1002.578	1083.810	3.733
2.02	55.806	1015.545	6.079	1002.412	1014.137	6.911
3.02	56.072	1017.852	6.050	1002.796	978.745	8.383
4.02	56.846	1021.911	5.961	1009.544	999.561	7.002
5.02	56.808	1030.960	6.068	1018.211	991.691	7.870
6.02	56.624	1034.228	6.004	1022.735	999.031	8.321
7.02	57.777	1034.569	5.923	1022.258	1034.116	5.167
8.02	55.580	1028.789	6.117	1016.378	1065.682	3.989
9.02	55.495	1021.478	6.114	1008.102	1011.436	5.557
10.02	54.044	1023.438	6.239	1010.544	1032.067	4.760
11.02	55.819	1034.017	6.158	1021.186	1044.965	6.639
12.02	56.057	1041.604	6.210	1027.932	1035.477	7.769
13.02	55.727	1043.143	6.251	1026.964	1011.755	5.892
14.02	58.341	1043.057	5.842	1026.748	1037.603	4.689
15.02	56.779	1045.360	6.033	1029.639	1055.878	4.521
16.02	56.508	1035.442	6.101	1021.018	1018.681	8.953
17.02	56.395	1029.099	5.932	1015.980	1024.604	6.589
18.02	54.762	1035.281	6.290	1023.229	1034.276	4.075
19.02	56.230	1030.150	6.028	1016.395	994.008	7.121
20.02	57.010	1035.927	5.916	1019.188	1003.654	5.632
21.02	57.394	1035.857	5.892	1019.055	1036.596	4.461
22.02	56.482	1037.425	6.086	1020.999	1047.773	8.085
23.02	55.519	1040.121	6.183	1024.802	987.278	4.839
24.02	56.239	1041.541	6.085	1025.415	1012.471	6.006
25.02	56.812	1036.273	6.043	1020.425	1016.834	4.933
26.02	55.341	1029.770	6.335	1015.627	1014.209	10.151
27.02	56.878	1038.474	6.124	1023.577	992.464	8.801
28.02	57.169	1040.312	5.916	1025.012	1016.872	4.714
min	54.044	1015.545	5.842	1002.412	978.745	3.733
max	58.341	1045.360	6.335	1029.639	1083.810	10.151
MMV	56.289	1032.812	6.074	1018.528	1021.275	6.268
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 02.2021



	UAB Fortum Klaipeda						sugeneruota: 1.03.2021
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.02	0.000	0.060	0.039	164.873	0.015	0.300	
2.02	0.004	0.132	0.039	163.566	0.004	0.339	
3.02	0.000	0.093	0.039	165.386	0.004	0.305	
4.02	0.241	0.096	0.040	163.895	0.018	0.294	
5.02	3.460	0.201	0.037	164.749	0.015	0.301	
6.02	0.000	0.112	0.039	165.420	0.009	0.231	
7.02	0.031	0.054	0.041	164.868	0.027	0.332	
8.02	0.029	0.019	0.037	164.495	0.005	0.325	
9.02	0.131	0.093	0.037	164.745	0.002	0.240	
10.02	0.000	0.182	0.037	164.974	0.018	0.309	
11.02	0.000	0.079	0.037	164.878	0.021	0.300	
12.02	0.216	0.043	0.037	163.475	0.011	0.283	
13.02	0.000	0.032	0.042	164.892	0.058	0.376	
14.02	0.000	0.059	0.046	165.291	0.105	0.297	
15.02	0.205	0.134	0.044	164.416	0.089	0.256	
16.02	3.038	0.096	0.046	164.670	0.062	0.320	
17.02	0.138	0.040	0.046	164.429	0.065	0.344	
18.02	0.000	0.110	0.041	164.653	0.010	0.287	
19.02	0.340	0.079	0.046	164.236	0.094	0.253	
20.02	0.000	0.020	0.048	165.422	0.148	0.325	
21.02	0.000	0.023	0.051	164.678	0.174	0.306	
22.02	0.002	0.067	0.045	164.232	0.101	0.249	
23.02	0.000	0.042	0.043	165.015	0.144	0.297	
24.02	0.000	0.033	0.048	164.815	0.110	0.315	
25.02	0.335	0.029	0.052	164.877	0.164	0.229	
26.02	5.517	0.152	0.056	162.866	0.080	0.320	
27.02	1.771	0.095	0.047	164.464	0.047	0.250	
28.02	0.011	0.054	0.045	164.821	0.155	0.247	
min	0.000	0.019	0.037	162.866	0.002	0.229	
max	5.517	0.201	0.056	165.422	0.174	0.376	
MMV	0.552	0.080	0.043	164.611	0.063	0.294	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							