

# Menesine ataskaita: 02.2022



	UAB Fortum Klaipeda						sugeneruota: 1.03.2022
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.02	9.661	7.664	9.751	0.000	0.369	0.053	
2.02	9.917	7.689	6.615	0.000	0.371	0.026	
3.02	9.564	7.683	5.083	0.000	0.376	0.025	
4.02	9.355	7.745	6.176	0.000	0.443	0.022	
5.02	8.759	7.750	4.363	0.000	0.484	0.026	
6.02	8.826	7.701	4.761	0.000	0.417	0.048	
7.02	8.905	7.681	5.759	0.000	0.654	0.020	
8.02	8.865	7.699	6.730	0.000	0.352	0.018	
9.02	8.631	7.718	7.109	0.001	0.251	0.016	
10.02	8.594	7.748	6.092	0.000	0.251	0.008	
11.02	8.615	7.781	5.834	0.020	0.206	0.027	
12.02	8.697	7.745	4.426	2.577	0.198	0.043	
13.02	8.767	7.706	3.869	0.000	0.215	0.017	
14.02	8.849	7.694	4.880	0.000	0.225	0.010	
15.02	8.727	7.734	5.053	0.000	0.248	0.013	
16.02	8.685	7.779	5.994	0.000	0.267	0.016	
17.02	9.438	7.718	5.573	0.000	0.312	0.034	
18.02	8.645	7.759	5.980	0.000	0.309	0.038	
19.02	8.815	7.759	4.981	0.000	0.314	0.039	
20.02	8.725	7.766	4.702	0.000	0.321	0.013	
21.02	8.956	7.711	5.727	0.063	0.628	0.009	
22.02	9.214	7.691	6.683	0.000	0.373	0.006	
23.02	9.324	7.776	6.264	0.274	0.332	0.008	
24.02	8.629	7.780	6.175	0.000	0.377	0.010	
25.02	9.484	7.759	4.712	0.000	0.307	0.043	
26.02	8.389	7.770	4.039	0.000	0.268	0.046	
27.02	9.056	7.741	5.251	0.168	0.271	0.021	
28.02	8.884	7.755	5.852	0.000	0.260	0.018	
min	8.389	7.664	3.869	0.000	0.198	0.006	
max	9.917	7.781	9.751	2.577	0.654	0.053	
MMV	8.963	7.732	5.658	0.111	0.336	0.024	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 02.2022



	UAB Fortum Klaipeda						sugeneruota: 1.03.2022
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.02	0.020	0.000	131.076	0.007	0.106	221783.70	
2.02	0.020	0.000	131.817	0.007	0.108	224235.10	
3.02	0.020	0.000	131.753	0.003	X	223785.39	
4.02	0.020	0.000	132.242	0.001	X	221605.04	
5.02	0.020	0.000	131.860	0.000	X	220847.95	
6.02	0.020	0.000	131.751	0.000	X	219479.10	
7.02	0.020	0.000	131.285	0.000	X	220858.01	
8.02	0.021	0.000	131.406	0.000	0.280	218809.17	
9.02	0.021	0.055	131.899	0.016	0.334	218533.01	
10.02	0.022	0.000	132.264	0.000	0.315	217147.51	
11.02	0.021	0.000	131.261	0.000	0.373	217427.35	
12.02	0.021	0.000	131.929	0.000	0.442	217148.57	
13.02	0.021	0.000	131.787	0.000	0.461	218116.17	
14.02	0.021	0.000	131.137	0.001	0.497	217372.92	
15.02	0.021	0.000	131.856	0.000	0.543	214977.87	
16.02	0.021	0.000	132.216	0.000	0.510	219501.93	
17.02	0.022	0.000	131.502	0.000	0.381	219399.29	
18.02	0.021	0.000	131.750	0.000	0.446	217617.75	
19.02	0.022	0.000	132.348	0.000	0.419	222924.07	
20.02	0.021	0.000	131.089	0.000	0.455	220035.12	
21.02	0.021	0.000	131.792	0.000	0.466	219968.29	
22.02	0.022	0.000	131.256	0.000	0.323	221032.93	
23.02	0.022	0.000	132.182	0.001	0.402	224746.48	
24.02	0.021	0.000	131.428	0.000	0.330	219303.82	
25.02	0.021	0.000	131.641	0.000	0.332	219423.81	
26.02	0.023	0.000	131.853	0.000	0.373	217244.07	
27.02	0.024	0.000	131.768	0.000	0.358	206303.01	
28.02	0.023	0.000	130.136	0.000	0.326	217650.89	
min	0.020	0.000	130.136	0.000	0.106	206303.01	
max	0.024	0.055	132.348	0.016	0.543	224746.48	
MMV	0.021	0.002	131.653	0.001	0.361	219188.57	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 02.2022



	UAB Fortum Klaipeda			sugeneruota: 1.03.2022		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.02	45.446	1013.280	5.998	997.413	1042.881	10.847
2.02	45.970	1012.418	6.005	997.017	1041.141	7.376
3.02	45.403	1028.415	6.476	1011.273	1063.293	5.649
4.02	44.912	1022.331	6.492	1005.525	1043.358	6.864
5.02	43.541	1015.686	6.746	998.333	1050.032	4.856
6.02	43.628	1009.697	6.559	992.828	1052.359	5.293
7.02	43.819	1009.141	6.533	992.237	1038.384	6.396
8.02	43.877	1023.500	6.272	1006.508	1023.533	7.478
9.02	43.380	1027.156	6.328	1009.908	1048.987	7.865
10.02	43.293	1026.899	6.614	1009.995	1022.824	6.762
11.02	43.349	1028.186	6.501	1011.549	1022.938	6.472
12.02	43.676	1039.934	6.514	1023.345	1038.520	4.906
13.02	43.730	1032.363	6.234	1015.766	1030.532	4.276
14.02	43.820	1023.973	6.305	1007.127	1031.421	5.423
15.02	43.540	1023.035	6.514	1006.233	1044.306	5.622
16.02	43.320	1012.918	6.458	996.048	1036.298	6.636
17.02	44.368	990.131	6.254	973.458	1039.245	6.199
18.02	43.163	1007.058	6.363	990.385	1051.210	6.638
19.02	43.485	1001.423	6.659	985.068	1030.961	5.541
20.02	43.436	1014.678	6.425	998.025	1060.790	5.230
21.02	43.730	998.554	6.259	982.009	1050.637	6.361
22.02	44.472	1011.159	6.164	995.458	1044.027	7.446
23.02	44.857	1023.747	6.254	1007.307	1041.776	6.963
24.02	43.374	1029.048	6.404	1011.221	1062.656	6.895
25.02	44.755	1022.000	6.327	1005.014	1074.322	5.198
26.02	43.020	1042.119	6.493	1025.151	1070.792	4.512
27.02	44.536	1052.847	6.449	1036.859	1027.348	5.850
28.02	44.282	1053.747	6.440	1036.281	1029.601	6.523
min	43.020	990.131	5.998	973.458	1022.824	4.276
max	45.970	1053.747	6.746	1036.859	1074.322	10.847
MMV	44.006	1021.266	6.394	1004.548	1043.400	6.288
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 02.2022



	UAB Fortum Klaipeda						sugeneruota: 1.03.2022
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.02	0.000	0.088	0.033	163.845	0.011	0.151	
2.02	0.000	0.043	0.033	164.771	0.010	0.154	
3.02	0.000	0.042	0.034	164.691	0.004	X	
4.02	0.000	0.037	0.034	165.302	0.001	X	
5.02	0.000	0.044	0.033	164.826	0.000	X	
6.02	0.000	0.079	0.033	164.688	0.001	X	
7.02	0.000	0.033	0.033	164.106	0.000	X	
8.02	0.000	0.030	0.035	164.257	0.000	0.400	
9.02	0.001	0.027	0.035	164.873	0.022	0.476	
10.02	0.000	0.013	0.037	165.329	0.000	0.449	
11.02	0.025	0.045	0.035	164.077	0.000	0.532	
12.02	3.221	0.072	0.036	164.912	0.000	0.632	
13.02	0.000	0.028	0.036	164.734	0.000	0.659	
14.02	0.000	0.017	0.035	163.921	0.001	0.710	
15.02	0.000	0.022	0.035	164.820	0.000	0.776	
16.02	0.000	0.027	0.035	165.270	0.000	0.728	
17.02	0.000	0.057	0.036	164.378	0.000	0.544	
18.02	0.000	0.063	0.035	164.687	0.000	0.637	
19.02	0.000	0.065	0.036	165.435	0.000	0.599	
20.02	0.000	0.021	0.035	163.861	0.000	0.651	
21.02	0.079	0.016	0.035	164.739	0.000	0.666	
22.02	0.000	0.009	0.036	164.071	0.000	0.462	
23.02	0.343	0.013	0.036	165.227	0.001	0.575	
24.02	0.000	0.017	0.035	164.285	0.000	0.471	
25.02	0.000	0.072	0.034	164.551	0.000	0.475	
26.02	0.000	0.076	0.038	164.816	0.000	0.532	
27.02	0.210	0.035	0.039	164.710	0.001	0.511	
28.02	0.000	0.030	0.039	162.669	0.000	0.466	
min	0.000	0.009	0.033	162.669	0.000	0.151	
max	3.221	0.088	0.039	165.435	0.022	0.776	
MMV	0.138	0.040	0.035	164.566	0.002	0.516	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							