

Menesine ataskaita: 03.2015



UAB Fortum Klaipeda		sugeneruota: 1.04.2015				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.03	10.248	11.270	4.822	0.831	0.458	0.432
2.03	11.033	11.056	4.236	1.211	0.480	0.463
3.03	9.931	11.062	5.150	1.009	0.495	0.439
4.03	9.942	11.028	6.527	1.867	0.482	0.416
5.03	10.973	11.315	8.330	0.929	0.498	0.463
6.03	9.581	11.477	6.872	2.098	0.473	0.446
7.03	12.488	11.425	6.524	1.671	0.466	0.439
8.03	14.911	11.230	5.714	2.804	0.480	0.438
9.03	15.335	11.300	5.874	3.644	0.483	0.496
10.03	14.166	11.185	8.903	2.628	0.513	0.496
11.03	11.895	11.193	9.478	2.362	0.531	0.414
12.03	8.898	11.225	9.455	3.369	0.504	0.416
13.03	10.120	11.115	7.263	1.060	0.493	0.414
14.03	13.100	11.331	5.911	4.726	0.485	0.489
15.03	12.724	11.300	4.894	2.020	0.481	0.560
16.03	14.723	11.300	5.439	5.665	0.483	0.534
17.03	14.701	11.435	5.224	1.272	0.497	0.506
18.03	12.373	11.412	5.107	0.872	0.491	0.492
19.03	11.498	11.468	5.185	0.593	0.479	0.488
20.03	8.665	11.438	4.947	0.383	0.468	0.454
21.03	9.072	11.334	4.717	0.621	0.478	0.400
22.03	8.458	11.209	5.774	0.200	0.486	0.483
23.03	8.197	11.377	5.304	0.802	0.470	0.544
24.03	8.743	11.338	4.601	0.530	0.475	0.510
25.03	9.224	11.516	4.184	0.526	0.476	0.528
26.03	11.041	11.221	4.642	0.756	0.529	0.442
27.03	10.065	11.245	4.688	0.733	0.558	0.407
28.03	8.692	11.402	4.386	0.462	0.490	0.398
29.03	D 27.420	11.310	4.931	2.154	0.502	0.432
30.03	8.892	11.227	5.213	6.736	0.489	0.515
31.03	8.913	11.362	5.793	1.040	0.557	0.406
min	8.197	11.028	4.184	0.200	0.458	0.398
max	D 27.420	11.516	9.478	6.736	0.558	0.560
MMV	11.465	11.294	5.814	1.794	0.492	0.463
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 03.2015



UAB Fortum Klaipeda		sugeneruota: 1.04.2015				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.03	0.004	0.353	151.847	0.578	0.313	213176.89
2.03	0.004	0.285	153.007	0.549	0.366	205407.93
3.03	0.008	0.347	157.816	0.497	0.520	204808.32
4.03	0.005	0.235	153.958	0.373	0.413	206544.64
5.03	0.004	0.288	149.478	0.481	0.342	208948.87
6.03	0.010	0.318	151.624	0.412	0.526	206016.67
7.03	0.014	0.301	151.036	0.440	0.380	208431.12
8.03	0.010	0.310	156.701	0.596	0.368	210189.12
9.03	0.005	0.292	154.630	0.673	0.349	211489.81
10.03	0.000	0.334	151.917	0.808	0.490	212787.23
11.03	0.000	0.333	150.492	0.750	0.383	209946.01
12.03	0.001	0.343	154.753	0.664	0.738	202071.67
13.03	0.003	0.384	152.282	0.626	0.537	202762.76
14.03	0.004	0.367	156.305	0.610	0.422	209634.17
15.03	0.004	0.335	155.406	0.560	0.443	207757.43
16.03	0.006	0.325	157.644	0.635	0.408	210310.50
17.03	0.007	0.356	155.255	0.622	0.423	209695.17
18.03	0.006	0.354	155.467	0.650	0.403	204567.10
19.03	0.007	0.359	155.619	0.615	0.323	202302.50
20.03	0.011	0.353	152.408	0.570	0.487	195508.75
21.03	0.007	0.365	154.929	0.513	0.499	194997.23
22.03	0.008	0.391	158.155	0.516	0.395	193481.42
23.03	0.012	0.366	156.283	0.512	0.437	195779.29
24.03	0.009	0.357	149.081	0.514	0.367	198135.68
25.03	0.008	0.361	148.882	0.568	0.513	194662.68
26.03	0.006	0.339	154.677	0.692	0.423	198143.89
27.03	0.006	0.318	149.190	0.620	0.413	197188.75
28.03	0.012	0.342	149.856	0.515	0.565	195023.73
29.03	0.012	0.311	151.746	0.582	0.682	197579.65
30.03	0.012	0.285	146.575	0.574	0.711	197094.35
31.03	0.012	0.268	159.926	0.554	0.538	200815.51
min	0.000	0.235	146.575	0.373	0.313	193481.42
max	0.014	0.391	159.926	0.808	0.738	213176.89
MMV	0.007	0.332	153.454	0.576	0.457	203401.81
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 03.2015



UAB Fortum Klaipeda		sugeneruota: 1.04.2015				
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	
Diena	°C	mbar	Vol%	mbar	°C	
1.03	45.600	1007.035	5.964	1007.494	968.709	
2.03	45.808	993.245	6.285	994.809	984.591	
3.03	44.665	997.695	6.983	999.389	988.553	
4.03	45.013	1008.754	7.037	1010.159	988.612	
5.03	47.386	1021.908	6.817	1022.194	978.745	
6.03	44.327	1026.363	6.776	1026.862	993.603	
7.03	50.278	1024.581	6.589	1024.503	1009.304	
8.03	54.403	1019.984	6.432	1019.484	980.314	
9.03	54.741	1019.357	6.380	1020.064	997.719	
10.03	53.093	1020.147	6.629	1020.769	998.714	
11.03	48.609	1018.797	6.829	1019.662	1015.883	
12.03	43.064	1027.371	7.107	1028.775	1023.868	
13.03	46.002	1028.599	7.056	1029.530	1014.785	
14.03	51.932	1030.982	6.650	1030.927	1003.349	
15.03	51.055	1037.988	6.700	1038.279	1027.405	
16.03	54.289	1041.340	6.586	1041.312	992.696	
17.03	54.429	1040.404	6.585	1040.321	1009.370	
18.03	50.226	1033.736	6.636	1034.017	1013.480	
19.03	48.530	1026.051	6.651	1026.886	1039.241	
20.03	42.331	1016.068	6.864	1017.746	1048.596	
21.03	42.998	1009.029	6.841	1011.491	1053.503	
22.03	42.029	1020.555	6.953	1023.371	1009.471	
23.03	41.144	1013.559	6.894	1013.818	1018.753	
24.03	42.318	1006.874	6.841	1006.804	1047.476	
25.03	43.291	1012.210	6.799	1012.154	1081.439	
26.03	47.042	1010.042	6.739	1009.470	1029.218	
27.03	44.804	1007.133	6.724	1007.717	1058.204	
28.03	42.068	1011.323	6.813	1012.361	1064.971	
29.03	42.827	1000.968	6.859	1001.788	1053.277	
30.03	42.054	978.528	6.830	980.011	1038.567	
31.03	42.242	985.075	6.774	986.086	1059.254	
min	41.144	978.528	5.964	980.011	968.709	
max	54.741	1041.340	7.107	1041.312	1081.439	
MMV	46.734	1016.012	6.731	1016.739	1019.041	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						