

# Menesine ataskaita: 03.2017



UAB Fortum Klaipeda		sugeneruota: 1.04.2017				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.03	7.655	18.282	1.793	0.679	0.000	0.375
2.03	7.883	18.252	6.893	0.599	0.000	0.320
3.03	8.953	18.311	3.366	0.754	0.000	0.298
4.03	8.753	18.454	3.079	0.734	0.000	0.387
5.03	9.484	18.374	3.011	1.326	0.000	0.339
6.03	8.992	18.357	3.537	0.840	0.000	0.249
7.03	8.549	18.425	2.780	0.667	0.000	0.298
8.03	8.035	18.330	2.829	0.166	0.000	0.350
9.03	7.792	18.232	4.690	0.465	0.000	0.299
10.03	7.675	18.232	3.448	0.406	0.000	0.385
11.03	7.886	18.295	3.465	0.296	0.000	0.338
12.03	8.210	18.414	4.273	1.045	0.000	0.287
13.03	8.148	18.346	3.390	0.326	0.000	0.322
14.03	9.645	18.206	2.832	0.663	0.000	0.341
15.03	9.161	18.158	1.038	0.703	0.000	0.297
16.03	8.233	18.030	1.355	0.903	0.000	0.391
17.03	7.940	18.219	1.713	4.593	0.000	0.332
18.03	8.167	18.470	1.309	6.709	0.000	0.358
19.03	8.154	18.445	1.681	4.817	0.000	0.413
20.03	9.578	18.269	1.559	1.966	0.000	0.343
21.03	11.882	18.279	1.449	1.603	0.000	0.385
22.03	10.878	18.279	1.578	0.992	0.000	0.291
23.03	11.022	18.109	2.827	0.925	0.000	0.306
24.03	10.745	18.264	1.736	1.012	0.000	0.414
25.03	7.979	18.291	1.203	0.537	0.000	0.329
26.03	8.274	18.326	2.680	2.354	0.000	0.351
27.03	11.805	17.774	4.898	3.826	0.113	0.671
28.03	-	-	-	-	-	-
29.03	8.997	15.875	2.617	8.321	0.590	3.974
30.03	9.580	17.896	4.212	1.304	0.000	0.337
31.03	10.586	18.067	4.053	1.129	0.000	0.324
min	7.655	15.875	1.038	0.166	0.000	0.249
max	11.882	18.470	6.893	8.321	0.590	3.974
MMV	9.017	18.225	2.833	1.538	0.011	0.398
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 03.2017



	UAB Fortum Klaipeda						sugeneruota: 1.04.2017
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.03	0.086	0.000	179.701	0.196	0.647	214827.82	
2.03	0.087	0.000	179.561	0.202	0.532	216561.18	
3.03	0.091	0.000	180.130	0.179	0.590	220055.14	
4.03	0.090	0.000	179.328	0.178	0.610	219835.23	
5.03	0.084	0.000	174.319	0.186	0.668	220664.45	
6.03	0.084	0.000	177.060	0.169	0.595	219892.95	
7.03	0.086	0.000	175.874	0.146	0.559	218539.26	
8.03	0.087	0.000	173.887	0.166	0.695	218537.43	
9.03	0.086	0.000	176.895	0.198	0.505	218609.95	
10.03	0.086	0.000	176.502	0.232	0.423	218360.54	
11.03	0.088	0.000	176.981	0.217	0.565	219000.10	
12.03	0.084	0.000	176.607	0.190	0.682	220331.67	
13.03	0.083	0.001	173.983	0.152	0.616	220371.79	
14.03	0.090	0.001	178.244	0.134	0.593	221296.64	
15.03	0.096	0.001	180.824	0.182	0.539	213181.64	
16.03	0.092	0.001	174.794	0.219	0.618	217647.79	
17.03	0.093	0.002	176.694	0.233	0.658	218415.98	
18.03	0.097	0.001	181.214	0.214	0.723	220357.57	
19.03	0.094	0.001	177.029	0.204	0.571	220224.26	
20.03	0.096	0.001	177.978	0.123	0.668	222354.01	
21.03	0.100	0.000	183.000	0.170	0.571	225135.57	
22.03	0.100	0.000	190.428	0.181	0.619	221800.04	
23.03	0.096	0.000	180.627	0.249	0.489	223500.54	
24.03	0.091	0.001	181.510	0.235	0.647	222442.39	
25.03	0.092	0.003	177.125	0.196	0.533	220406.75	
26.03	0.092	0.001	173.510	0.177	0.663	222231.50	
27.03	0.115	0.133	171.688	0.371	0.661	184343.54	
28.03	-	-	-	-	-	-	
29.03	0.146	0.001	183.838	0.270	1.009	130617.60	
30.03	0.094	0.000	178.589	0.191	0.637	219754.70	
31.03	0.098	0.004	177.762	0.229	0.564	223354.12	
min	0.083	0.000	171.688	0.123	0.423	130617.60	
max	0.146	0.133	190.428	0.371	1.009	225135.57	
MMV	0.092	0.004	178.133	0.197	0.607	216409.68	
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down							

# Menesine ataskaita: 03.2017



	UAB Fortum Klaipeda			sugeneruota: 1.04.2017		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.03	41.510	999.226	5.496	995.045	1096.757	1.785
2.03	42.040	1002.301	5.516	997.636	1054.120	6.873
3.03	44.320	1008.146	5.411	1003.819	1051.537	3.371
4.03	43.898	1008.703	5.395	1003.354	1088.324	3.077
5.03	45.207	1004.967	5.302	1001.240	1074.357	3.023
6.03	44.447	1004.523	5.337	1002.502	1054.443	3.531
7.03	43.576	1008.278	5.379	1004.537	1078.302	2.779
8.03	42.666	1022.953	5.399	1018.126	1069.295	2.812
9.03	42.043	1020.502	5.488	1014.997	1035.842	4.686
10.03	41.767	1019.737	5.468	1014.180	1059.167	3.447
11.03	42.301	1024.862	5.496	1020.135	1066.583	3.457
12.03	43.053	1028.307	5.396	1024.234	1064.927	4.274
13.03	42.993	1029.440	5.409	1025.313	1052.791	3.391
14.03	45.658	1027.401	5.391	1022.346	1079.794	2.830
15.03	44.441	1016.386	5.446	1011.247	1088.100	1.367
16.03	42.839	1017.637	5.551	1012.289	1070.386	1.361
17.03	42.176	1007.970	5.470	1003.368	1054.400	1.717
18.03	42.536	996.503	5.314	991.983	1069.505	1.309
19.03	42.489	1002.373	5.309	997.871	1083.732	1.687
20.03	45.580	1006.485	5.295	1001.604	1067.131	1.462
21.03	49.540	1005.355	5.070	1000.315	1084.174	1.450
22.03	48.020	1017.253	5.192	1012.510	1087.841	1.620
23.03	48.492	1027.219	5.348	1021.664	1015.879	2.820
24.03	47.298	1028.456	5.321	1023.542	1032.542	1.729
25.03	42.430	1022.327	5.368	1017.869	1044.030	1.203
26.03	43.093	1024.835	5.325	1020.242	1046.494	2.686
27.03	77.872	1021.226	7.852	1015.880	1029.519	4.905
28.03	-	-	-	-	-	-
29.03	92.250	1015.888	9.320	1012.295	990.674	2.620
30.03	45.700	1026.017	5.491	1021.200	1010.678	4.222
31.03	46.918	1019.292	5.262	1013.871	1018.113	4.042
min	41.510	996.503	5.070	991.983	990.674	1.203
max	92.250	1029.440	9.320	1025.313	1096.757	6.873
MMV	46.527	1015.458	5.561	1010.808	1058.903	2.837
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 03.2017



	UAB Fortum Klaipeda						sugeneruota: 1.04.2017
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.03	0.679	0.375	0.086	179.701	0.196	0.647	
2.03	0.599	0.320	0.087	179.561	0.202	0.532	
3.03	0.754	0.298	0.091	180.130	0.179	0.590	
4.03	0.734	0.387	0.090	179.328	0.178	0.610	
5.03	1.326	0.339	0.084	174.319	0.186	0.668	
6.03	0.840	0.249	0.084	177.060	0.169	0.595	
7.03	0.667	0.298	0.086	175.874	0.146	0.559	
8.03	0.166	0.350	0.087	173.887	0.166	0.695	
9.03	0.465	0.299	0.086	176.895	0.198	0.505	
10.03	0.406	0.385	0.086	176.502	0.232	0.423	
11.03	0.296	0.338	0.088	176.981	0.217	0.565	
12.03	1.045	0.287	0.084	176.607	0.190	0.682	
13.03	0.326	0.322	0.083	173.983	0.152	0.616	
14.03	0.663	0.341	0.090	178.244	0.134	0.593	
15.03	0.703	0.297	0.096	180.824	0.182	0.539	
16.03	0.903	0.391	0.092	174.794	0.219	0.618	
17.03	4.593	0.332	0.093	176.694	0.233	0.658	
18.03	6.709	0.358	0.097	181.214	0.214	0.723	
19.03	4.817	0.413	0.094	177.029	0.204	0.571	
20.03	1.966	0.343	0.096	177.978	0.123	0.668	
21.03	1.603	0.385	0.100	183.000	0.170	0.571	
22.03	0.992	0.291	0.100	190.428	0.181	0.619	
23.03	0.925	0.306	0.096	180.627	0.249	0.489	
24.03	1.012	0.414	0.091	181.510	0.235	0.647	
25.03	0.537	0.329	0.092	177.125	0.196	0.533	
26.03	2.354	0.351	0.092	173.510	0.177	0.663	
27.03	3.826	0.671	0.115	171.688	0.371	0.661	
28.03	-	-	-	-	-	-	
29.03	8.321	3.974	0.146	183.838	0.270	1.009	
30.03	1.304	0.337	0.094	178.589	0.191	0.637	
31.03	1.129	0.324	0.098	177.762	0.229	0.564	
min	0.166	0.249	0.083	171.688	0.123	0.423	
max	8.321	3.974	0.146	190.428	0.371	1.009	
MMV	1.538	0.398	0.092	178.133	0.197	0.607	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							