

Menesine ataskaita: 04.2014



	UAB Fortum Klaipeda						sugeneruota: 1.05.2014
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.04	13.736	12.319	4.669	0.804	0.526	0.466	
2.04	14.253	12.277	5.170	1.185	0.516	0.555	
3.04	14.120	12.334	4.138	0.804	0.541	0.554	
4.04	16.664	12.310	4.752	0.317	0.547	0.502	
5.04	18.315	12.535	4.865	0.599	0.549	0.418	
6.04	18.672	12.368	4.269	0.510	0.548	0.451	
7.04	19.506	12.314	3.978	0.299	0.546	0.545	
8.04	18.214	12.602	3.554	0.802	0.535	0.489	
9.04	17.171	12.605	4.246	2.370	0.542	0.497	
10.04	17.029	12.512	5.669	1.767	0.549	0.498	
11.04	17.503	12.674	4.672	1.136	0.547	0.424	
12.04	19.171	12.446	4.000	0.044	0.577	0.398	
13.04	18.562	12.358	5.680	0.627	0.552	0.453	
14.04	18.475	12.310	6.549	0.599	0.556	0.537	
15.04	19.200	12.593	5.831	0.364	0.593	0.522	
16.04	18.065	12.549	4.254	0.787	0.573	0.449	
17.04	16.903	12.466	5.491	1.282	0.527	0.460	
18.04	18.210	12.450	5.172	0.954	0.482	4.072	
19.04	19.982	12.261	4.599	0.007	0.477	6.357	
20.04	19.707	12.435	4.404	0.198	0.628	4.535	
21.04	18.929	11.700	7.283	1.370	0.641	4.825	
22.04	20.240	12.111	5.604	1.700	0.763	4.625	
23.04	20.584	12.363	7.285	6.942	0.809	3.800	
24.04	19.743	12.412	5.073	1.086	0.692	2.818	
25.04	18.630	12.308	4.423	0.421	0.519	3.456	
26.04	19.174	12.380	4.149	0.076	0.463	4.003	
27.04	19.616	12.161	5.892	12.852	0.484	4.261	
28.04	19.561	12.178	3.617	5.994	0.512	3.275	
29.04	19.452	12.262	3.779	2.562	0.489	3.765	
30.04	19.410	12.125	6.035	15.684	0.551	2.314	
min	13.736	11.700	3.554	0.007	0.463	0.398	
max	20.584	12.674	7.285	15.684	0.809	6.357	
MMV	18.302	12.356	4.971	2.152	0.561	2.025	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 04.2014



UAB Fortum Klaipeda		sugeneruota: 1.05.2014				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.04	0.154	0.000	148.997	0.458	0.215	193875.04
2.04	0.135	0.000	150.612	0.538	0.330	193550.89
3.04	0.160	0.000	138.401	0.578	0.351	194114.67
4.04	0.199	0.000	141.271	0.630	0.391	200104.17
5.04	0.180	0.000	142.993	0.621	0.256	200598.76
6.04	0.227	0.000	142.334	0.530	0.346	200190.20
7.04	0.269	0.000	140.269	0.659	0.316	198180.56
8.04	0.192	0.000	156.935	0.759	0.401	200685.42
9.04	0.183	0.000	155.318	0.666	0.349	198088.60
10.04	0.155	0.000	150.125	0.576	0.369	201479.79
11.04	0.142	0.000	144.823	0.598	0.422	202604.68
12.04	0.187	0.000	145.261	0.814	0.314	205832.14
13.04	0.195	0.000	133.378	0.715	0.418	204726.82
14.04	0.192	0.000	138.929	0.553	0.286	201449.39
15.04	0.164	0.000	149.765	0.571	0.223	207776.06
16.04	0.162	0.000	142.080	0.563	0.304	203740.50
17.04	0.186	0.000	143.079	0.542	0.317	202582.06
18.04	0.207	0.000	149.248	0.831	0.228	206823.54
19.04	0.289	0.000	140.049	1.130	0.115	215633.70
20.04	0.270	0.000	136.389	1.083	0.110	215607.75
21.04	0.241	0.000	132.980	0.987	0.092	205988.75
22.04	0.275	0.000	128.694	1.148	0.073	213843.10
23.04	0.281	0.000	147.333	1.130	0.192	218132.70
24.04	0.322	0.000	139.196	0.963	0.181	217416.20
25.04	0.232	0.000	150.888	0.964	0.170	211518.32
26.04	0.255	0.000	148.176	1.125	0.080	215311.68
27.04	0.279	0.000	142.430	1.200	0.079	216258.39
28.04	0.370	0.000	140.880	1.106	0.087	216529.76
29.04	0.398	0.000	141.417	1.079	0.118	217245.25
30.04	0.379	0.000	138.004	1.024	0.208	209335.79
min	0.135	0.000	128.694	0.458	0.073	193550.89
max	0.398	0.000	156.935	1.200	0.422	218132.70
MMV	0.230	0.000	143.312	0.807	0.245	206307.67
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 04.2014



UAB Fortum Klaipeda		sugeneruota: 1.05.2014				
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	
Diena	°C	mbar	Vol%	mbar	°C	
1.04	51.251	1011.521	5.954	1014.449	1110.488	
2.04	52.346	1013.553	5.874	1015.872	1125.152	
3.04	51.692	1005.357	5.817	1007.583	1124.430	
4.04	55.548	1012.221	5.633	1015.016	1082.482	
5.04	58.113	1018.748	5.496	1019.890	1079.266	
6.04	58.782	1012.269	5.461	1014.284	1097.252	
7.04	59.756	1007.945	5.413	1010.189	1099.981	
8.04	58.055	1005.014	5.471	1005.750	1122.785	
9.04	56.755	1002.288	5.597	1005.529	1105.784	
10.04	56.683	1012.500	5.685	1015.444	1095.643	
11.04	57.360	1017.500	5.558	1018.769	1106.078	
12.04	59.553	1013.106	5.423	1014.812	1114.850	
13.04	58.605	1004.435	5.505	1006.832	1111.994	
14.04	58.450	997.359	5.471	999.957	1091.769	
15.04	59.468	1005.333	5.405	1007.589	1103.207	
16.04	58.197	1020.342	5.522	1022.893	1119.839	
17.04	56.662	1019.991	5.610	1021.473	1101.401	
18.04	102.017	1010.269	5.426	1011.369	1090.772	
19.04	142.078	1018.294	5.321	1019.536	1107.277	
20.04	143.854	1015.266	5.328	1017.315	1118.962	
21.04	142.846	1011.248	5.723	1012.988	1093.294	
22.04	144.781	1010.646	5.330	1012.442	1078.482	
23.04	145.062	1015.396	5.349	1018.573	1069.283	
24.04	143.930	1020.963	5.386	1024.625	1104.556	
25.04	141.704	1018.940	5.432	1021.048	1109.558	
26.04	142.962	1013.690	5.382	1015.657	1122.211	
27.04	141.002	1008.206	5.413	1010.181	1129.466	
28.04	137.517	1007.498	5.338	1009.953	1142.220	
29.04	143.589	1005.738	5.363	1008.710	1155.203	
30.04	103.220	1003.171	5.464	1005.383	1119.618	
min	51.251	997.359	5.321	999.957	1069.283	
max	145.062	1020.963	5.954	1024.625	1155.203	
MMV	91.395	1011.294	5.504	1013.471	1107.777	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						