

Menesine ataskaita: 04.2016



	UAB Fortum Klaipeda						sugeneruota: 1.05.2016
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.04	7.689	11.741	7.661	0.052	0.510	0.278	
2.04	8.239	11.967	6.597	0.312	0.445	0.275	
3.04	10.506	12.012	7.195	1.502	0.473	0.279	
4.04	14.349	11.559	9.058	0.213	0.548	0.292	
5.04	18.271	11.471	12.358	1.283	0.588	0.324	
6.04	12.453	11.590	9.306	0.878	0.540	0.298	
7.04	15.297	11.278	6.285	0.437	0.590	0.315	
8.04	14.080	11.377	6.969	1.855	0.543	0.308	
9.04	15.020	11.513	7.320	1.282	0.517	0.299	
10.04	14.586	11.534	11.496	3.483	0.513	0.297	
11.04	15.934	11.206	7.545	0.670	0.534	0.328	
12.04	17.978	11.150	18.513	6.852	0.553	0.324	
13.04	19.956	11.316	7.649	2.185	0.587	0.347	
14.04	19.192	10.959	5.999	1.242	0.587	0.338	
15.04	18.421	10.664	7.878	1.209	0.672	1.793	
16.04	16.921	10.287	6.557	1.116	0.659	3.808	
17.04	17.594	10.402	5.887	3.030	0.631	3.787	
18.04	17.619	10.441	5.657	3.712	0.589	3.334	
19.04	16.698	10.159	5.570	0.584	0.573	3.249	
20.04	17.086	10.220	6.201	0.603	0.600	3.948	
21.04	16.930	10.416	6.216	0.857	0.564	4.300	
22.04	17.129	10.497	6.691	1.484	0.552	4.383	
23.04	17.386	10.529	6.893	1.981	0.542	4.480	
24.04	17.643	10.430	8.136	1.899	0.563	4.109	
25.04	17.231	10.495	7.823	4.831	0.564	3.500	
26.04	16.926	10.382	6.980	1.077	0.551	3.338	
27.04	16.905	10.168	5.896	0.669	0.585	3.956	
28.04	17.432	10.355	5.920	0.799	0.582	4.149	
29.04	17.153	10.362	7.278	0.364	0.545	4.792	
30.04	18.039	10.721	7.461	0.269	0.569	5.196	
min	7.689	10.159	5.570	0.052	0.445	0.275	
max	19.956	12.012	18.513	6.852	0.672	5.196	
MMV	16.022	10.907	7.700	1.558	0.562	2.214	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 04.2016



	UAB Fortum Klaipeda						sugeneruota: 1.05.2016
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.04	0.012	0.544	156.368	1.058	0.243	175419.26	
2.04	0.013	0.537	155.971	1.048	0.111	178924.60	
3.04	0.011	0.575	154.662	1.265	0.275	183427.29	
4.04	0.008	0.628	149.301	1.665	0.223	182969.07	
5.04	0.008	0.792	146.132	1.983	0.284	185727.79	
6.04	0.006	0.646	151.325	1.448	0.534	177456.25	
7.04	0.017	0.617	146.613	1.599	0.300	182001.00	
8.04	0.011	0.668	153.822	1.560	0.256	179287.51	
9.04	0.012	0.668	155.337	1.539	0.240	181572.17	
10.04	0.017	0.792	149.791	1.546	0.433	180903.64	
11.04	0.014	0.698	148.833	1.702	0.340	181700.54	
12.04	0.010	0.975	145.288	2.044	0.386	180743.64	
13.04	0.005	0.718	143.261	1.924	0.602	181826.42	
14.04	0.004	0.700	143.144	1.910	0.549	180934.56	
15.04	0.020	0.699	143.100	1.890	0.877	175233.76	
16.04	0.016	0.759	144.031	2.044	0.411	160465.39	
17.04	0.016	0.788	146.440	1.947	0.160	162457.89	
18.04	0.020	0.777	150.270	1.969	0.099	166819.65	
19.04	0.021	0.787	147.170	2.081	0.129	164115.40	
20.04	0.023	0.777	145.813	1.945	0.209	169219.79	
21.04	0.027	0.805	147.016	1.839	0.263	167156.89	
22.04	0.022	0.772	148.675	1.941	0.193	169147.14	
23.04	0.025	0.750	149.427	1.965	0.159	169956.53	
24.04	0.020	0.758	149.919	2.103	0.196	171273.51	
25.04	0.018	0.752	149.855	1.935	0.126	170015.23	
26.04	0.011	0.758	149.672	1.943	0.254	168350.07	
27.04	0.015	0.777	144.956	1.947	0.309	170399.71	
28.04	0.021	0.775	146.082	1.885	0.250	170402.09	
29.04	0.014	0.808	147.236	1.903	0.109	170016.54	
30.04	0.009	0.758	142.909	1.956	0.140	171098.01	
min	0.004	0.537	142.909	1.048	0.099	160465.39	
max	0.027	0.975	156.368	2.103	0.877	185727.79	
MMV	0.015	0.729	148.414	1.786	0.289	174300.67	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 04.2016



	UAB Fortum Klaipeda					sugeneruota: 1.05.2016
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	
Diena	°C	mbar	Vol%	mbar	°C	
1.04	40.208	1011.408	6.446	1009.978	1021.168	
2.04	41.600	1023.635	6.178	1021.159	1060.060	
3.04	46.348	1020.598	6.059	1017.167	1044.782	
4.04	52.949	1013.947	6.137	1010.699	1035.233	
5.04	59.536	1009.557	5.939	1007.063	1051.738	
6.04	49.479	1003.340	6.349	1002.840	1034.050	
7.04	54.740	1007.487	6.353	1006.027	1033.547	
8.04	52.618	1010.214	6.343	1008.505	1035.242	
9.04	54.096	1010.710	6.167	1009.006	1059.693	
10.04	53.384	1014.747	6.213	1013.616	1054.202	
11.04	55.546	1018.782	6.383	1016.969	1039.230	
12.04	58.427	1014.821	6.324	1012.322	1053.775	
13.04	61.606	1005.934	5.973	1004.795	1097.864	
14.04	60.830	1004.833	6.248	1003.636	1056.078	
15.04	98.362	1008.004	6.573	1007.131	1041.351	
16.04	140.627	1004.725	7.042	1002.641	1044.514	
17.04	142.842	1002.394	6.887	1002.209	1072.377	
18.04	143.174	1008.752	6.850	1009.176	1110.914	
19.04	140.672	1008.173	7.098	1007.802	1099.003	
20.04	142.336	1014.645	7.100	1013.655	1071.636	
21.04	141.486	1016.306	6.934	1015.549	1086.246	
22.04	141.964	1005.598	6.827	1004.996	1114.415	
23.04	142.307	1007.252	6.774	1005.606	1083.286	
24.04	143.445	1000.731	6.848	1001.183	1083.555	
25.04	142.163	1006.008	6.857	1004.707	1074.284	
26.04	141.794	1003.958	6.912	1003.508	1071.851	
27.04	141.503	1006.009	7.088	1004.786	1063.577	
28.04	142.337	1010.127	6.935	1009.401	1064.018	
29.04	141.626	1021.907	6.983	1019.900	1071.768	
30.04	143.606	1024.085	6.608	1022.674	1068.856	
min	40.208	1000.731	5.939	1001.183	1021.168	
max	143.606	1024.085	7.100	1022.674	1114.415	
MMV	99.054	1010.623	6.581	1009.291	1063.277	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						