

# Menesine ataskaita: 04.2017



	UAB Fortum Klaipeda						sugeneruota: 1.05.2017
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.04	17.219	17.939	1.392	3.435	0.000	0.367	
2.04	14.910	17.298	1.060	3.298	0.000	0.509	
3.04	16.409	17.452	1.537	4.900	0.000	0.606	
4.04	13.861	17.571	1.080	3.556	0.000	0.606	
5.04	10.622	15.932	2.284	1.372	0.000	0.408	
6.04	9.935	16.236	1.249	2.244	0.000	0.408	
7.04	8.724	17.799	1.416	1.272	0.000	0.716	
8.04	12.109	17.964	1.718	1.135	0.000	0.376	
9.04	13.185	17.827	2.243	1.489	0.000	0.408	
10.04	15.658	17.719	1.652	2.038	0.000	0.457	
11.04	13.832	17.469	3.106	3.227	0.000	0.413	
12.04	12.210	17.681	4.411	4.422	0.000	0.339	
13.04	11.865	17.576	2.217	1.431	0.000	0.415	
14.04	9.332	18.016	2.002	1.484	0.000	0.374	
15.04	11.427	18.070	2.079	1.300	0.000	0.345	
16.04	7.899	17.891	2.607	0.761	0.000	0.349	
17.04	7.777	17.808	1.748	0.363	0.000	0.284	
18.04	10.333	17.987	2.416	1.023	0.000	0.241	
19.04	11.181	17.906	2.506	0.527	0.000	0.356	
20.04	9.348	17.577	0.994	0.960	0.000	0.401	
21.04	10.881	17.352	1.046	1.367	0.000	0.436	
22.04	11.229	17.293	1.011	1.656	0.000	0.363	
23.04	15.873	17.887	1.695	4.040	0.000	0.460	
24.04	13.110	17.598	2.567	3.955	0.000	0.385	
25.04	12.498	17.499	1.019	2.050	0.000	0.422	
26.04	12.528	17.785	2.167	3.219	0.000	0.433	
27.04	14.104	17.516	1.280	2.320	0.000	0.375	
28.04	12.470	17.332	0.770	1.871	0.000	0.329	
29.04	11.785	17.366	0.635	2.273	0.000	0.393	
30.04	10.666	17.749	1.161	1.748	0.000	0.361	
min	7.777	15.932	0.635	0.363	0.000	0.241	
max	17.219	18.070	4.411	4.900	0.000	0.716	
MMV	12.101	17.571	1.766	2.157	0.000	0.411	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 04.2017



	UAB Fortum Klaipeda						sugeneruota: 1.05.2017
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.04	0.113	0.000	179.217	0.375	0.609	231782.79	
2.04	0.108	0.002	175.328	0.280	0.816	224537.51	
3.04	0.107	0.004	178.476	0.324	0.795	228325.37	
4.04	0.098	0.021	179.767	0.241	0.758	225527.32	
5.04	0.103	0.048	177.388	0.300	0.567	225826.25	
6.04	0.108	0.049	173.306	0.307	0.844	227836.50	
7.04	0.097	0.001	175.076	0.163	0.657	218133.06	
8.04	0.101	0.000	178.367	0.222	0.525	225160.39	
9.04	0.105	0.002	175.487	0.322	0.608	223604.43	
10.04	0.118	0.000	178.311	0.313	0.590	227223.45	
11.04	0.097	0.005	177.613	0.209	0.499	216755.60	
12.04	0.091	0.000	176.728	0.160	0.619	221307.12	
13.04	0.094	0.000	178.544	0.158	0.722	222937.17	
14.04	0.102	0.000	176.451	0.226	0.622	222300.17	
15.04	0.101	0.000	178.012	0.250	0.643	225040.42	
16.04	0.094	0.000	178.972	0.178	0.531	218921.87	
17.04	0.097	0.001	178.262	0.182	0.668	220364.45	
18.04	0.093	0.000	175.881	0.229	0.481	224602.85	
19.04	0.095	0.000	177.309	0.192	0.599	223520.50	
20.04	0.094	0.000	181.425	0.106	0.742	221667.25	
21.04	0.108	0.000	184.082	0.207	0.482	221895.32	
22.04	0.110	0.000	182.640	0.167	0.645	222720.07	
23.04	0.106	0.000	176.516	0.253	0.683	229170.45	
24.04	0.106	0.000	177.485	0.229	0.942	226190.82	
25.04	0.107	0.000	179.455	0.198	0.623	224785.89	
26.04	0.105	0.000	179.549	0.218	0.620	223513.89	
27.04	0.107	0.000	178.737	0.286	0.498	227115.50	
28.04	0.093	0.000	186.908	0.181	0.655	223469.87	
29.04	0.102	0.003	196.388	0.192	0.711	223272.54	
30.04	0.102	0.000	185.846	0.219	0.618	222950.98	
min	0.091	0.000	173.306	0.106	0.481	216755.60	
max	0.118	0.049	196.388	0.375	0.942	231782.79	
MMV	0.102	0.005	179.255	0.230	0.646	224015.15	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 04.2017



	UAB Fortum Klaipeda			sugeneruota: 1.05.2017		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.04	57.116	1017.356	4.903	1010.762	1040.048	1.389
2.04	54.055	1016.917	5.372	1011.355	1056.090	1.066
3.04	56.422	1024.582	5.182	1019.741	1051.585	1.540
4.04	52.351	1028.427	5.289	1024.021	1095.972	1.072
5.04	47.068	1017.361	6.198	1013.578	1114.121	2.277
6.04	45.699	1011.352	6.091	1006.710	1114.050	1.258
7.04	46.876	1013.413	5.310	1008.988	1073.597	1.417
8.04	50.007	1021.188	5.114	1016.036	1079.753	1.718
9.04	51.506	1023.486	5.121	1018.245	1089.234	2.254
10.04	55.003	1015.100	4.995	1009.238	1064.875	1.644
11.04	52.284	1008.018	5.263	1004.753	1059.226	3.185
12.04	50.000	1006.796	5.278	1002.815	1039.680	4.408
13.04	49.347	1002.113	5.296	997.578	1043.410	2.220
14.04	44.881	1007.418	5.220	1003.124	1039.226	2.003
15.04	48.939	1009.158	5.111	1004.786	1028.289	2.077
16.04	42.204	1009.874	5.430	1006.664	1056.561	2.611
17.04	41.972	1019.781	5.407	1015.439	1064.882	1.727
18.04	46.594	1027.611	5.189	1022.878	1057.331	2.433
19.04	48.116	1034.149	5.166	1029.471	1053.039	2.508
20.04	45.482	1033.692	5.434	1028.265	1076.051	0.979
21.04	47.395	1015.355	5.405	1009.708	1059.586	1.050
22.04	48.318	1005.191	5.336	999.988	1018.620	1.012
23.04	55.247	1012.216	4.849	1006.763	1022.361	1.701
24.04	51.632	1012.737	5.137	1007.822	1025.285	2.561
25.04	50.571	1004.273	5.111	1000.177	1037.506	1.027
26.04	50.853	1010.448	5.108	1005.359	993.749	2.153
27.04	52.923	1016.970	5.038	1011.302	997.150	1.278
28.04	50.806	1018.906	5.219	1013.904	1017.351	0.769
29.04	49.261	1012.053	5.219	1007.977	1008.527	0.632
30.04	47.920	1026.269	5.183	1020.400	995.834	1.171
min	41.972	1002.113	4.849	997.578	993.749	0.632
max	57.116	1034.149	6.198	1029.471	1114.121	4.408
MMV	49.695	1016.075	5.265	1011.263	1049.100	1.771
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 04.2017



	UAB Fortum Klaipeda						sugeneruota: 1.05.2017
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.04	3.435	0.367	0.113	179.217	0.375	0.609	
2.04	3.298	0.509	0.108	175.328	0.280	0.816	
3.04	4.900	0.606	0.107	178.476	0.324	0.795	
4.04	3.556	0.606	0.098	179.767	0.241	0.758	
5.04	1.372	0.408	0.103	177.388	0.300	0.567	
6.04	2.244	0.408	0.108	173.306	0.307	0.844	
7.04	1.272	0.716	0.097	175.076	0.163	0.657	
8.04	1.135	0.376	0.101	178.367	0.222	0.525	
9.04	1.489	0.408	0.105	175.487	0.322	0.608	
10.04	2.038	0.457	0.118	178.311	0.313	0.590	
11.04	3.227	0.413	0.097	177.613	0.209	0.499	
12.04	4.422	0.339	0.091	176.728	0.160	0.619	
13.04	1.431	0.415	0.094	178.544	0.158	0.722	
14.04	1.484	0.375	0.102	176.451	0.226	0.622	
15.04	1.300	0.345	0.101	178.012	0.250	0.643	
16.04	0.761	0.349	0.094	178.972	0.178	0.531	
17.04	0.363	0.284	0.097	178.262	0.182	0.668	
18.04	1.023	0.241	0.093	175.881	0.229	0.481	
19.04	0.527	0.356	0.095	177.309	0.192	0.599	
20.04	0.960	0.401	0.094	181.425	0.106	0.742	
21.04	1.367	0.436	0.108	184.082	0.207	0.482	
22.04	1.656	0.363	0.110	182.640	0.167	0.645	
23.04	4.040	0.460	0.106	176.516	0.253	0.683	
24.04	3.955	0.385	0.106	177.485	0.229	0.942	
25.04	2.050	0.422	0.107	179.455	0.198	0.623	
26.04	3.219	0.433	0.105	179.549	0.218	0.620	
27.04	2.320	0.375	0.107	178.737	0.286	0.498	
28.04	1.871	0.329	0.093	186.908	0.181	0.655	
29.04	2.273	0.393	0.102	196.388	0.192	0.711	
30.04	1.748	0.361	0.102	185.846	0.219	0.618	
min	0.363	0.241	0.091	173.306	0.106	0.481	
max	4.900	0.716	0.118	196.388	0.375	0.942	
MMV	2.157	0.411	0.102	179.255	0.230	0.646	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							