

Menesine ataskaita: 05.2018



	UAB Fortum Klaipeda sugeneruota: 1.06.2018					
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.05	19.523	8.749	4.177	1.661	0.006	8.506
2.05	19.244	8.781	4.057	2.048	0.015	8.773
3.05	19.032	8.737	11.452	1.049	0.000	9.511
4.05	17.941	8.860	5.836	0.597	0.000	8.897
5.05	17.895	9.237	5.626	0.649	0.000	9.231
6.05	19.455	9.223	5.692	0.780	0.000	7.774
7.05	18.751	9.121	4.025	0.656	0.006	8.665
8.05	16.959	9.082	5.047	0.442	0.000	2.098
9.05	19.014	9.134	3.535	4.193	0.049	0.331
10.05	19.080	9.116	3.693	5.969	0.000	7.824
11.05	19.011	9.140	6.947	1.693	0.089	7.469
12.05	19.953	9.130	5.262	1.639	0.041	5.632
13.05	18.914	9.076	4.171	2.342	0.310	7.099
14.05	18.629	9.099	3.119	1.735	0.172	5.740
15.05	18.443	9.128	5.865	1.366	0.009	5.714
16.05	18.765	9.091	3.925	1.161	0.003	5.842
17.05	18.066	9.047	7.661	1.258	0.000	6.054
18.05	18.722	9.109	4.569	1.541	0.000	6.175
19.05	18.554	9.153	2.404	3.184	0.000	6.455
20.05	19.190	9.152	3.897	8.160	0.000	9.803
21.05	19.948	9.154	3.741	3.509	0.000	9.270
22.05	21.041	9.118	3.608	2.030	0.029	7.030
23.05	21.293	9.158	3.449	4.596	0.328	5.014
24.05	20.516	9.073	3.829	3.143	0.217	4.272
25.05	20.598	8.999	3.621	5.088	0.001	4.501
26.05	17.965	8.859	3.207	1.810	0.000	4.837
27.05	20.282	8.908	3.776	1.153	0.024	6.471
28.05	19.136	8.832	4.676	0.989	0.018	5.613
29.05	19.912	8.932	5.792	1.220	0.174	5.802
30.05	19.664	9.016	6.477	1.951	0.874	5.110
31.05	18.966	9.109	6.372	5.436	0.805	4.847
min	16.959	8.737	2.404	0.442	0.000	0.331
max	21.293	9.237	11.452	8.160	0.874	9.803
MMV	19.181	9.042	4.825	2.359	0.103	6.485
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 05.2018



	UAB Fortum Klaipeda						sugeneruota: 1.06.2018
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.05	0.100	0.013	169.841	0.415	1.413	203148.18	
2.05	0.095	0.001	169.204	0.305	0.854	204873.79	
3.05	0.091	0.009	169.450	0.373	1.221	206856.26	
4.05	0.093	0.007	168.907	0.368	0.971	197775.29	
5.05	0.092	0.002	169.706	0.387	0.943	190301.64	
6.05	0.095	0.005	169.723	0.365	0.795	192807.51	
7.05	0.101	0.012	168.665	0.321	0.937	190439.35	
8.05	0.049	0.017	131.967	0.441	0.410	191349.32	
9.05	0.020	0.003	109.871	0.222	0.290	194525.93	
10.05	0.054	0.004	136.004	0.459	0.686	191451.95	
11.05	0.054	0.000	134.678	0.273	0.662	192911.23	
12.05	0.054	0.000	135.690	0.171	0.614	195368.32	
13.05	0.052	0.001	136.476	0.124	0.656	199175.14	
14.05	0.053	0.000	135.161	0.154	0.682	180114.92	
15.05	0.052	0.001	134.874	0.157	0.666	185253.25	
16.05	0.052	0.000	135.972	0.163	0.807	190457.54	
17.05	0.052	0.000	136.993	0.151	0.515	197715.75	
18.05	0.052	0.001	136.129	0.125	0.743	197625.54	
19.05	0.053	0.000	135.787	0.164	0.555	197416.17	
20.05	0.053	0.000	135.032	0.162	0.733	198189.95	
21.05	0.053	0.000	135.814	0.221	0.779	201026.60	
22.05	0.053	0.000	137.723	0.176	0.593	204762.12	
23.05	0.053	0.000	152.257	0.156	0.938	204122.98	
24.05	0.052	0.000	157.674	0.204	0.715	204757.31	
25.05	0.052	0.041	153.350	0.275	0.901	204180.45	
26.05	0.052	0.022	139.230	0.210	0.717	199771.54	
27.05	0.052	0.003	147.129	0.189	0.758	205576.00	
28.05	0.052	0.006	136.708	0.240	0.776	201766.29	
29.05	0.052	0.006	134.599	0.230	0.535	199193.06	
30.05	0.055	0.079	135.332	0.472	0.665	194644.54	
31.05	0.054	0.087	135.076	0.526	0.730	189494.81	
min	0.020	0.000	109.871	0.124	0.290	180114.92	
max	0.101	0.087	169.841	0.526	1.413	206856.26	
MMV	0.061	0.010	144.751	0.264	0.750	197001.78	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 05.2018



	UAB Fortum Klaipeda			sugeneruota: 1.06.2018		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.05	143.451	1013.163	6.132	1005.671	1057.253	4.180
2.05	142.200	1020.880	6.303	1014.625	1063.343	4.062
3.05	136.668	1020.004	6.280	1012.221	1047.309	11.488
4.05	114.501	1025.980	7.115	1018.799	1040.212	5.855
5.05	110.606	1031.936	7.106	1023.796	1038.685	5.627
6.05	100.811	1033.365	6.779	1024.744	1040.090	5.676
7.05	105.551	1031.275	7.093	1022.260	1040.871	4.018
8.05	112.547	1026.690	7.333	1016.949	1033.808	X
9.05	111.308	1022.543	6.943	1013.555	1019.844	X
10.05	109.863	1022.615	6.968	1013.095	1055.549	4.109
11.05	123.299	1025.719	6.902	1016.797	1023.377	7.712
12.05	111.821	1027.477	6.789	1019.014	1030.334	5.870
13.05	144.947	1025.771	6.611	1017.519	1046.966	4.640
14.05	144.983	1026.134	6.752	1017.520	1061.893	3.432
15.05	144.649	1023.168	6.689	1014.795	1049.327	6.567
16.05	144.797	1019.450	6.570	1011.201	1046.654	4.364
17.05	143.307	1014.801	6.761	1006.989	1039.766	8.567
18.05	144.395	1016.213	6.641	1008.280	1049.405	5.076
19.05	142.297	1024.137	6.878	1016.839	1080.786	2.672
20.05	139.630	1032.287	6.706	1024.377	1054.112	4.309
21.05	141.563	1033.010	6.620	1024.009	1068.606	4.166
22.05	147.369	1026.480	6.362	1017.802	1071.445	4.009
23.05	148.597	1028.044	6.207	1020.109	1067.051	3.824
24.05	146.761	1032.442	6.215	1023.842	1065.514	4.251
25.05	146.963	1031.277	6.083	1022.077	1068.036	4.017
26.05	142.355	1031.803	6.601	1023.422	1085.740	3.577
27.05	146.219	1032.483	6.230	1022.696	1085.714	4.214
28.05	144.730	1033.322	6.363	1023.875	1074.629	5.219
29.05	146.033	1030.965	6.348	1021.385	1073.073	6.488
30.05	145.186	1027.332	7.044	1017.937	1072.164	7.242
31.05	143.952	1026.151	6.932	1017.624	1082.164	7.116
min	100.811	1013.163	6.083	1005.671	1019.844	2.672
max	148.597	1033.365	7.333	1024.744	1085.740	11.488
MMV	134.560	1026.352	6.655	1017.866	1055.926	5.343
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 05.2018



UAB Fortum Klaipeda		sugeneruota: 1.06.2018				
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.05	1.661	8.506	0.100	169.841	0.415	1.413
2.05	2.048	8.773	0.095	169.204	0.305	0.854
3.05	1.049	9.511	0.091	169.450	0.373	1.221
4.05	0.597	8.897	0.093	168.907	0.368	0.971
5.05	0.649	9.231	0.092	169.706	0.387	0.943
6.05	0.780	7.774	0.095	169.723	0.365	0.795
7.05	0.656	8.665	0.101	168.665	0.321	0.937
8.05	2.334	9.835	0.093	171.483	1.672	0.903
9.05	7.448	D 11.400	0.090	172.816	1.391	1.147
10.05	7.461	D 13.040	0.090	170.005	0.655	0.980
11.05	2.116	D 12.449	0.089	168.348	0.390	0.946
12.05	2.049	9.387	0.090	169.612	0.244	0.878
13.05	2.928	D 11.832	0.087	170.595	0.178	0.938
14.05	2.168	9.566	0.088	168.951	0.220	0.974
15.05	1.707	9.523	0.087	168.592	0.224	0.952
16.05	1.451	9.737	0.087	169.965	0.234	1.153
17.05	1.573	D 10.090	0.087	171.242	0.216	0.735
18.05	1.927	D 10.291	0.087	170.161	0.178	1.062
19.05	3.980	D 10.758	0.089	169.733	0.234	0.793
20.05	10.200	D 16.338	0.088	168.790	0.231	1.048
21.05	4.386	D 15.450	0.089	169.768	0.316	1.112
22.05	2.538	D 11.716	0.088	172.154	0.251	0.848
23.05	5.746	8.357	0.088	190.321	0.223	1.340
24.05	3.929	7.121	0.087	197.092	0.292	1.022
25.05	6.360	7.502	0.086	191.688	0.393	1.287
26.05	2.262	8.062	0.086	174.038	0.300	1.024
27.05	1.442	D 10.785	0.087	183.912	0.270	1.082
28.05	1.236	9.355	0.086	170.885	0.343	1.109
29.05	1.525	9.669	0.087	168.249	0.328	0.764
30.05	2.439	8.517	0.091	169.165	0.675	0.950
31.05	6.795	8.079	0.090	168.845	0.751	1.043
min	0.597	7.121	0.086	168.249	0.178	0.735
max	10.200	D 16.338	0.101	197.092	1.672	1.413
MMV	3.009	10.007	0.090	172.629	0.406	1.007
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						