

Menesine ataskaita: 06.2024



	UAB Gren Klaipeda						sugeneruota: 1.07.2024
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.06	17.602	7.516	6.570	1.336	0.118	0.000	
2.06	17.576	7.505	6.771	1.487	0.217	0.000	
3.06	18.447	7.491	7.355	0.288	0.467	0.000	
4.06	16.888	7.511	6.024	2.520	0.185	0.000	
5.06	17.848	7.539	6.757	0.746	0.098	0.000	
6.06	17.639	7.487	7.776	1.054	0.000	0.000	
7.06	17.902	7.502	6.914	5.959	0.000	0.000	
8.06	18.325	7.540	7.446	0.482	0.013	0.000	
9.06	16.998	7.529	8.947	2.193	0.079	0.000	
10.06	18.446	7.543	6.819	0.332	0.192	0.000	
11.06	17.194	7.573	6.311	2.344	0.241	0.000	
12.06	17.546	7.562	6.671	1.568	0.369	0.000	
13.06	17.429	7.555	7.296	1.669	0.388	0.000	
14.06	17.250	7.601	6.920	1.895	0.473	0.000	
15.06	17.490	7.516	6.798	1.655	0.535	0.000	
16.06	16.842	7.458	8.148	1.669	0.624	0.000	
17.06	17.153	7.502	6.767	1.705	1.172	0.000	
18.06	17.108	7.605	6.766	1.559	0.106	0.000	
19.06	18.404	7.606	10.468	0.304	0.035	0.000	
20.06	18.197	7.549	14.997	0.140	0.170	0.000	
21.06	17.854	7.636	13.078	0.947	1.415	0.000	
22.06	18.035	7.613	6.332	0.865	1.199	0.000	
23.06	18.007	7.631	5.601	0.667	0.885	0.000	
24.06	16.791	7.550	7.680	1.126	2.727	0.000	
25.06	X	-	-	-	-	-	
26.06	-	-	-	-	-	-	
27.06	-	-	-	-	-	-	
28.06	-	-	-	-	-	-	
29.06	X	X	X	X	X	X	
30.06	17.023	7.541	12.473	0.012	3.307	0.000	
min	16.791	7.458	5.601	0.012	0.000	0.000	
max	18.447	7.636	14.997	5.959	3.307	0.000	
MMV	17.323	7.544	8.018	1.369	0.640	0.000	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 06.2024



	UAB Gren Klaipeda						sugeneruota: 1.07.2024
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.		Nm3/h
1.06	0.084	0.000	135.929	0.185	0.876		220435.43
2.06	0.093	0.000	134.850	0.198	1.006		206386.35
3.06	0.090	0.000	134.972	0.253	1.809		227116.25
4.06	0.089	0.000	135.821	0.083	1.126		224749.85
5.06	0.087	0.000	135.455	0.277	0.882		225833.29
6.06	0.083	0.000	135.338	0.238	0.852		224139.68
7.06	0.086	0.000	135.450	0.210	0.677		224632.98
8.06	0.085	0.000	135.764	0.261	0.731		226048.25
9.06	0.084	0.000	135.205	0.187	0.755		182106.85
10.06	0.087	0.000	135.488	0.314	0.682		225146.56
11.06	0.077	0.000	135.875	0.217	0.750		222166.20
12.06	0.079	0.000	135.751	0.249	0.794		223552.07
13.06	0.077	0.000	137.215	0.191	0.768		223304.95
14.06	0.080	0.000	135.761	0.232	0.891		223224.07
15.06	0.080	0.000	135.155	0.274	0.850		210577.98
16.06	0.081	0.000	135.339	0.266	0.972		188525.00
17.06	0.081	0.000	135.939	0.199	1.309		226443.12
18.06	0.080	0.000	135.905	0.167	0.780		222796.56
19.06	0.078	0.000	135.807	0.359	0.722		228160.70
20.06	0.082	0.000	135.421	0.374	0.765		225505.06
21.06	0.102	0.000	135.963	0.099	0.927		226794.04
22.06	0.102	0.000	135.431	0.000	0.911		223112.04
23.06	0.099	0.000	135.436	0.000	0.727		221228.01
24.06	0.097	0.000	137.126	0.000	0.836		194096.93
25.06	-	-	-	-	-		X
26.06	-	-	-	-	-		-
27.06	-	-	-	-	-		-
28.06	-	-	-	-	-		-
29.06	X	X	X	X	2.466		114115.81
30.06	0.056	0.000	135.394	0.361	1.439		204571.12
min	0.056	0.000	134.850	0.000	0.677		114115.81
max	0.102	0.000	137.215	0.374	2.466		228160.70
MMV	0.084	0.000	135.699	0.215	0.947		213272.28
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 06.2024



	UAB Gren Klaipeda			sugeneruota: 1.07.2024		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.06	57.384	1029.914	6.975	1009.428	1071.906	7.070
2.06	57.314	1027.664	7.212	1007.159	1042.363	7.292
3.06	58.443	1028.195	6.541	1007.680	1052.912	7.971
4.06	56.335	1029.752	7.178	1009.061	1057.810	6.439
5.06	57.653	1029.431	6.764	1008.164	1068.583	7.266
6.06	57.455	1032.217	6.647	1012.471	1045.577	8.422
7.06	57.875	1035.134	6.628	1014.642	1059.524	7.459
8.06	58.329	1032.077	6.576	1010.891	1050.125	8.079
9.06	56.499	1022.715	7.268	1002.860	1011.777	9.737
10.06	58.350	1023.923	6.472	1002.985	1068.777	7.364
11.06	56.708	1023.746	6.890	1003.584	1064.773	6.780
12.06	57.216	1030.381	7.091	1010.275	1076.442	7.176
13.06	57.182	1035.117	6.853	1014.174	1041.425	7.897
14.06	56.951	1035.189	6.860	1014.406	1050.511	7.460
15.06	57.241	1033.393	6.679	1011.533	1035.676	7.351
16.06	56.412	1030.561	7.202	1009.678	1009.424	8.834
17.06	56.774	1032.079	6.762	1010.920	1050.691	7.295
18.06	56.777	1033.533	6.765	1012.128	1048.314	7.303
19.06	58.324	1027.872	6.417	1008.389	1044.304	11.483
20.06	58.133	1035.104	6.960	1014.607	1007.137	16.639
21.06	57.732	1035.936	6.853	1014.605	981.835	14.495
22.06	57.917	1027.986	6.561	1007.038	990.448	6.798
23.06	57.841	1024.611	6.545	1005.016	997.077	5.990
24.06	56.422	1035.381	7.728	1013.701	963.517	8.323
25.06	X	X	X	X	-	-
26.06	-	-	-	-	-	-
27.06	-	-	-	-	-	-
28.06	-	-	-	-	-	-
29.06	68.768	1034.331	X	1014.571	924.118	X
30.06	55.964	1029.456	6.779	1008.119	952.450	13.734
min	55.964	1022.715	6.417	1002.860	924.118	5.990
max	68.768	1035.936	7.728	1014.642	1076.442	16.639
MMV	58.065	1030.636	7.088	1009.961	1031.688	8.708
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 06.2024



	UAB Gren Klaipeda						sugeneruota: 1.07.2024
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.06	1.670	0.000	0.086	177.277	0.073	0.829	
2.06	1.858	0.000	0.100	176.006	0.078	1.011	
3.06	0.359	0.000	0.097	175.961	0.138	2.205	
4.06	3.149	0.000	0.094	177.177	0.003	1.194	
5.06	0.933	0.000	0.093	176.614	0.163	0.843	
6.06	1.318	0.000	0.086	176.410	0.137	0.806	
7.06	7.449	0.000	0.091	176.561	0.106	0.549	
8.06	0.602	0.000	0.088	176.968	0.162	0.624	
9.06	2.741	0.000	0.085	176.437	0.067	0.643	
10.06	0.416	0.000	0.092	176.589	0.205	0.552	
11.06	2.930	0.000	0.075	177.150	0.069	0.648	
12.06	1.960	0.000	0.076	177.091	0.149	0.705	
13.06	2.086	0.000	0.075	178.847	0.102	0.679	
14.06	2.369	0.000	0.080	176.999	0.100	0.860	
15.06	2.069	0.000	0.081	176.183	0.164	0.802	
16.06	2.086	0.000	0.081	176.589	0.160	0.966	
17.06	2.132	0.000	0.082	177.185	0.124	1.475	
18.06	1.949	0.000	0.081	177.139	0.091	0.700	
19.06	0.380	0.000	0.078	176.971	0.309	0.614	
20.06	0.175	0.000	0.083	176.679	0.378	0.663	
21.06	1.184	0.000	0.118	177.292	0.120	0.909	
22.06	1.081	0.000	0.118	176.522	0.000	0.890	
23.06	0.834	0.000	0.113	176.521	0.000	0.620	
24.06	1.407	0.000	0.107	178.918	0.000	0.763	
25.06	-	-	-	-	-	-	
26.06	-	-	-	-	-	-	
27.06	-	-	-	-	-	-	
28.06	-	-	-	-	-	-	
29.06	X	X	X	X	X	3.063	
30.06	0.015	0.000	0.039	176.497	0.267	1.663	
min	0.015	0.000	0.039	175.961	0.000	0.549	
max	7.449	0.000	0.118	178.918	0.378	3.063	
MMV	1.712	0.000	0.088	176.942	0.135	0.935	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							