

Menesine ataskaita: 07.2019



	UAB Fortum Klaipeda sugeneruota: 1.08.2019					
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.07	-	-	-	-	-	-
2.07	-	-	-	-	-	-
3.07	-	-	-	-	-	-
4.07	-	-	-	-	-	-
5.07	-	-	-	-	-	-
6.07	-	-	-	-	-	-
7.07	-	-	-	-	-	-
8.07	X	-	-	-	-	-
9.07	5.011	-	-	-	-	-
10.07	16.961	7.458	9.971	0.083	D 11.606	1.239
11.07	17.150	7.788	5.800	0.254	1.657	1.228
12.07	16.445	7.762	6.079	0.347	0.625	0.326
13.07	16.853	7.823	4.478	0.327	0.544	0.270
14.07	18.141	7.818	5.022	0.109	0.529	0.280
15.07	17.892	7.773	2.948	0.123	0.535	0.340
16.07	16.935	7.761	5.199	0.056	0.521	0.336
17.07	16.941	7.778	5.649	0.398	0.512	0.373
18.07	17.624	7.770	12.305	0.626	0.519	0.354
19.07	18.163	7.800	8.727	1.050	0.518	0.320
20.07	19.311	7.813	4.656	0.436	0.553	0.280
21.07	19.440	7.805	4.112	0.199	0.584	0.265
22.07	19.897	7.834	4.384	0.331	0.593	0.277
23.07	19.502	7.839	5.470	0.343	0.618	0.284
24.07	18.862	7.754	3.632	0.288	0.620	0.295
25.07	18.675	7.780	3.514	0.315	0.584	0.352
26.07	18.204	7.812	6.610	0.692	0.583	0.342
27.07	18.617	7.766	4.772	0.284	0.585	0.362
28.07	20.501	7.735	4.272	0.280	0.570	0.241
29.07	20.601	7.715	3.681	0.377	0.582	0.265
30.07	19.599	7.793	5.534	0.525	0.582	0.346
31.07	19.070	7.832	5.148	0.376	0.526	0.273
min	5.011	7.458	2.948	0.056	0.512	0.241
max	20.601	7.839	12.305	1.050	D 11.606	1.239
MMV	18.030	7.773	5.544	0.355	1.117	0.393
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 07.2019



	UAB Fortum Klaipeda sugeneruota: 1.08.2019					
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.07	-	-	-	-	-	-
2.07	-	-	-	-	-	-
3.07	-	-	-	-	-	-
4.07	-	-	-	-	-	-
5.07	-	-	-	-	-	-
6.07	-	-	-	-	-	-
7.07	-	-	-	-	-	-
8.07	-	-	-	-	-	X
9.07	-	-	-	-	-	37145.734
10.07	0.088	0.537	126.851	0.910	X	180315.62
11.07	0.076	0.519	127.528	0.859	0.472	197898.20
12.07	0.073	0.533	127.384	0.879	0.398	196751.98
13.07	0.074	0.524	127.410	0.849	0.452	196877.92
14.07	0.073	0.478	127.692	0.777	0.451	202607.32
15.07	0.073	0.503	127.104	0.828	0.405	203176.26
16.07	0.077	0.456	127.649	0.798	0.419	198769.06
17.07	0.078	0.480	127.452	0.842	0.391	199975.73
18.07	0.083	0.530	127.439	0.949	0.410	204002.67
19.07	0.075	0.531	127.422	0.836	0.418	202735.73
20.07	0.073	0.511	127.472	0.787	0.420	208133.37
21.07	0.075	0.487	127.474	0.723	0.420	206751.31
22.07	0.076	0.465	127.396	0.664	0.352	207754.92
23.07	0.075	0.432	127.408	0.671	0.409	204180.95
24.07	0.076	0.445	127.459	0.736	0.446	205467.89
25.07	0.072	0.493	127.506	0.818	0.408	205728.14
26.07	0.074	0.498	127.447	0.789	0.409	203144.31
27.07	0.079	0.486	127.577	0.744	0.437	202643.70
28.07	0.073	0.497	127.101	0.773	0.422	208410.43
29.07	0.074	0.492	126.942	0.791	0.483	207931.07
30.07	0.081	0.456	127.163	0.739	0.426	204731.81
31.07	0.079	0.436	127.346	0.687	0.404	206478.67
min	0.072	0.432	126.851	0.664	0.352	37145.734
max	0.088	0.537	127.692	0.949	0.483	208410.43
MMV	0.076	0.490	127.374	0.793	0.424	196878.95
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 07.2019



	UAB Fortum Klaipeda			sugeneruota: 1.08.2019		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.07	-	-	-	-	-	-
2.07	-	-	-	-	-	-
3.07	-	-	-	-	-	-
4.07	-	-	-	-	-	-
5.07	-	-	-	-	-	-
6.07	-	-	-	-	-	-
7.07	-	-	-	-	-	-
8.07	X	X	X	X	-	-
9.07	115.699	1017.156	17.409	1004.396	-	X
10.07	133.069	1017.750	7.581	1006.176	949.746	11.053
11.07	105.609	1019.860	6.300	1007.545	1015.884	6.474
12.07	56.167	1020.693	6.522	1007.719	1019.013	6.821
13.07	56.646	1021.227	6.133	1008.530	1029.537	5.000
14.07	58.172	1023.162	6.030	1010.636	1049.002	5.589
15.07	57.913	1023.749	6.327	1010.725	1064.375	3.283
16.07	56.717	1018.197	6.392	1005.807	1023.171	5.752
17.07	56.737	1018.996	6.360	1006.449	999.152	6.157
18.07	57.612	1023.210	6.270	1010.126	997.905	13.790
19.07	58.246	1025.311	5.823	1011.936	1009.520	9.725
20.07	59.529	1027.016	5.813	1013.653	1041.683	5.183
21.07	59.643	1026.307	5.709	1013.135	1066.983	4.576
22.07	60.147	1027.689	5.565	1015.231	1055.515	4.909
23.07	59.719	1029.237	5.616	1015.613	1029.171	6.134
24.07	59.077	1029.819	5.758	1016.578	1049.497	4.053
25.07	58.868	1030.007	6.061	1016.860	1050.029	3.920
26.07	58.321	1027.897	6.030	1014.682	1026.372	7.423
27.07	58.752	1025.756	5.849	1012.505	1006.758	5.319
28.07	60.699	1022.638	5.506	1008.616	1036.176	4.768
29.07	60.771	1020.086	5.547	1006.336	1054.867	4.090
30.07	59.709	1018.768	5.710	1006.829	1044.480	6.129
31.07	59.212	1025.135	5.800	1013.071	1009.304	5.752
min	56.167	1017.156	5.506	1004.396	949.746	3.283
max	133.069	1030.007	17.409	1016.860	1066.983	13.790
MMV	65.897	1023.528	6.408	1010.635	1028.551	6.176
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 07.2019



	UAB Fortum Klaipeda						sugeneruota: 1.08.2019
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.07	-	-	-	-	-	-	
2.07	-	-	-	-	-	-	
3.07	-	-	-	-	-	-	
4.07	-	-	-	-	-	-	
5.07	-	-	-	-	-	-	
6.07	-	-	-	-	-	-	
7.07	-	-	-	-	-	-	
8.07	-	-	-	-	-	-	
9.07	-	-	-	-	-	-	
10.07	0.103	2.064	0.147	158.563	1.299	X	
11.07	0.318	2.046	0.126	159.410	1.227	0.675	
12.07	0.433	0.544	0.121	159.230	1.256	0.569	
13.07	0.408	0.450	0.123	159.262	1.213	0.646	
14.07	0.137	0.467	0.122	159.615	1.110	0.645	
15.07	0.153	0.566	0.122	158.880	1.183	0.578	
16.07	0.070	0.560	0.129	159.561	1.140	0.598	
17.07	0.497	0.622	0.130	159.315	1.203	0.558	
18.07	0.782	0.590	0.139	159.298	1.356	0.586	
19.07	1.312	0.533	0.125	159.278	1.194	0.597	
20.07	0.545	0.467	0.122	159.340	1.125	0.600	
21.07	0.249	0.442	0.126	159.343	1.033	0.600	
22.07	0.414	0.461	0.127	159.245	0.948	0.502	
23.07	0.428	0.474	0.126	159.260	0.958	0.584	
24.07	0.360	0.491	0.127	159.323	1.052	0.637	
25.07	0.393	0.586	0.121	159.383	1.168	0.582	
26.07	0.866	0.570	0.124	159.308	1.127	0.584	
27.07	0.355	0.603	0.132	159.472	1.063	0.624	
28.07	0.350	0.401	0.122	158.877	1.104	0.602	
29.07	0.471	0.442	0.124	158.678	1.131	0.690	
30.07	0.656	0.576	0.134	158.954	1.055	0.609	
31.07	0.470	0.456	0.131	159.183	0.981	0.577	
min	0.070	0.401	0.121	158.563	0.948	0.502	
max	1.312	2.064	0.147	159.615	1.356	0.690	
MMV	0.444	0.655	0.127	159.217	1.133	0.606	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							