

Menesine ataskaita: 07.2020



UAB Fortum Klaipeda		sugeneruota: 1.08.2020				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.07	17.342	7.332	4.038	0.044	1.103	2.376
2.07	18.259	7.243	5.088	0.973	1.796	2.002
3.07	18.148	7.288	3.377	0.000	1.016	2.380
4.07	18.294	7.311	4.882	0.000	1.473	2.472
5.07	19.111	7.269	4.300	0.000	1.358	2.648
6.07	17.937	7.282	4.146	0.000	1.080	2.652
7.07	18.807	7.255	3.832	0.000	0.907	2.948
8.07	17.995	7.277	4.259	0.000	1.084	2.493
9.07	16.972	7.245	3.999	0.000	0.917	2.509
10.07	17.097	7.218	3.838	0.564	1.114	2.970
11.07	17.848	7.257	4.277	0.064	1.197	3.217
12.07	17.638	7.270	3.933	0.000	1.672	3.486
13.07	17.149	7.213	2.247	0.000	1.569	3.543
14.07	17.502	7.250	2.175	0.000	1.351	3.813
15.07	17.057	7.256	1.841	0.000	1.010	3.601
16.07	17.933	7.223	6.409	0.000	1.186	3.984
17.07	18.583	7.197	4.348	0.000	1.229	4.269
18.07	19.170	7.226	7.145	0.000	1.619	4.365
19.07	19.304	7.229	4.688	0.000	1.686	4.349
20.07	18.710	7.220	4.961	0.000	1.460	4.039
21.07	18.650	7.254	4.004	0.000	1.441	4.118
22.07	17.862	7.185	3.185	0.000	1.116	4.140
23.07	17.442	7.287	3.133	0.000	0.928	3.840
24.07	18.068	7.312	3.995	0.036	1.142	3.514
25.07	19.243	7.266	5.898	0.000	1.631	3.850
26.07	19.208	7.269	4.294	0.000	1.541	3.767
27.07	19.118	7.211	3.866	0.000	1.290	3.886
28.07	18.816	7.280	4.584	0.000	1.092	4.359
29.07	18.251	7.311	3.967	0.000	0.977	4.285
30.07	18.260	7.316	4.449	0.000	0.880	4.345
31.07	17.594	7.254	3.614	0.000	0.958	4.093
min	16.972	7.185	1.841	0.000	0.880	2.002
max	19.304	7.332	7.145	0.973	1.796	4.365
MMV	18.172	7.258	4.155	0.054	1.252	3.493
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 07.2020



UAB Fortum Klaipeda		sugeneruota: 1.08.2020				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.07	0.098	0.287	127.530	0.108	0.330	209016.45
2.07	0.088	0.253	127.812	0.093	0.353	218793.00
3.07	0.091	0.256	127.991	0.116	0.279	215880.18
4.07	0.085	0.255	127.965	0.103	0.261	214720.85
5.07	0.087	0.240	127.688	0.086	0.351	215529.51
6.07	0.094	0.260	127.106	0.144	0.281	210965.92
7.07	0.098	0.208	127.520	0.036	0.357	217101.48
8.07	0.099	0.213	127.958	0.035	0.236	218239.00
9.07	0.106	0.244	127.506	0.047	0.232	213161.70
10.07	0.099	0.248	127.523	0.072	0.302	214962.10
11.07	0.097	0.254	128.610	0.106	0.272	214757.26
12.07	0.097	0.259	127.538	0.083	0.229	213578.43
13.07	0.103	0.269	127.644	0.107	0.234	182257.82
14.07	0.114	0.252	127.816	0.043	0.263	186405.35
15.07	0.091	0.265	127.718	0.080	0.337	197631.95
16.07	0.082	0.283	128.022	0.102	0.296	204146.23
17.07	0.075	0.254	127.700	0.035	0.354	220508.25
18.07	0.073	0.243	128.341	0.058	0.325	215466.48
19.07	0.069	0.240	127.829	0.070	0.304	205655.50
20.07	0.070	0.238	127.268	0.071	0.276	204703.26
21.07	0.087	0.220	127.950	0.032	0.267	211410.51
22.07	0.093	0.225	127.781	0.023	0.334	211722.12
23.07	0.100	0.255	128.079	0.043	0.265	210446.98
24.07	0.093	0.268	127.525	0.024	0.323	213638.73
25.07	0.093	0.241	127.645	0.008	0.257	216699.18
26.07	0.077	0.183	127.826	0.009	0.296	221045.82
27.07	0.074	0.201	128.117	0.059	0.307	214948.20
28.07	0.073	0.212	127.872	0.062	0.276	214904.73
29.07	0.089	0.249	127.830	0.064	0.238	212571.10
30.07	0.103	0.222	126.809	0.069	0.315	212687.56
31.07	0.095	0.240	127.747	0.115	0.255	211127.25
min	0.069	0.183	126.809	0.008	0.229	182257.82
max	0.114	0.287	128.610	0.144	0.357	221045.82
MMV	0.090	0.243	127.750	0.068	0.291	211118.96
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 07.2020



	UAB Fortum Klaipeda			sugeneruota: 1.08.2020		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.07	139.920	1016.507	6.389	1002.620	1070.501	4.513
2.07	141.953	1019.577	6.177	1005.048	1055.641	5.676
3.07	141.318	1024.659	6.263	1010.091	1081.501	3.756
4.07	141.717	1025.863	6.257	1010.867	1051.798	5.398
5.07	142.988	1019.918	6.123	1005.613	1070.723	4.787
6.07	140.630	1017.145	6.343	1003.330	1061.394	4.616
7.07	142.550	1021.206	6.102	1007.888	1084.740	4.250
8.07	141.058	1022.627	6.422	1008.706	1072.986	4.740
9.07	138.025	1026.663	6.603	1011.749	1051.746	4.445
10.07	137.998	1021.197	6.477	1006.850	1064.966	4.256
11.07	138.921	1025.334	6.282	1011.926	1051.223	4.755
12.07	138.646	1032.396	6.329	1018.298	1057.537	4.361
13.07	136.339	1031.778	6.570	1017.340	1048.773	2.498
14.07	136.211	1030.248	6.635	1015.354	1054.277	2.419
15.07	135.094	1026.989	6.695	1011.838	1086.543	2.058
16.07	136.020	1024.008	6.450	1009.794	1022.579	7.127
17.07	138.181	1029.608	6.296	1014.613	1064.922	4.830
18.07	140.803	1033.725	6.127	1018.368	1006.024	7.940
19.07	139.691	1031.414	6.251	1016.431	1023.981	5.197
20.07	138.654	1026.588	6.360	1011.541	1022.753	5.534
21.07	138.817	1025.310	6.325	1012.296	1007.246	4.458
22.07	137.382	1026.074	6.465	1012.260	1030.092	3.524
23.07	136.489	1025.097	6.463	1010.735	1041.998	3.485
24.07	137.708	1022.500	6.326	1007.932	1017.728	4.434
25.07	140.184	1022.673	6.126	1007.844	1001.597	6.568
26.07	140.618	1028.357	6.070	1012.358	1034.165	4.764
27.07	139.999	1028.948	6.161	1014.544	1027.600	4.314
28.07	139.808	1025.023	6.219	1009.762	1019.834	5.097
29.07	138.415	1022.799	6.400	1009.604	1033.281	4.394
30.07	138.316	1024.175	6.360	1010.759	1033.692	4.978
31.07	137.106	1024.181	6.469	1009.469	1016.750	4.027
min	135.094	1016.507	6.070	1002.620	1001.597	2.058
max	142.988	1033.725	6.695	1018.368	1086.543	7.940
MMV	139.083	1025.245	6.340	1010.835	1044.147	4.619
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 07.2020



	UAB Fortum Klaipeda						sugeneruota: 1.08.2020
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.07	0.054	3.959	0.163	159.413	0.154	0.472	
2.07	1.216	3.337	0.146	159.765	0.134	0.505	
3.07	0.000	3.967	0.151	159.989	0.165	0.399	
4.07	0.000	4.119	0.142	159.957	0.147	0.373	
5.07	0.000	4.413	0.146	159.610	0.123	0.501	
6.07	0.000	4.420	0.157	158.883	0.205	0.402	
7.07	0.000	4.914	0.163	159.400	0.051	0.510	
8.07	0.000	4.154	0.166	159.948	0.050	0.338	
9.07	0.000	4.181	0.177	159.383	0.067	0.332	
10.07	0.705	4.951	0.165	159.403	0.102	0.432	
11.07	0.080	5.362	0.161	160.762	0.152	0.388	
12.07	0.000	5.810	0.161	159.423	0.118	0.327	
13.07	0.000	5.905	0.172	159.556	0.153	0.334	
14.07	0.000	6.356	0.190	159.770	0.062	0.376	
15.07	0.000	6.002	0.152	159.648	0.114	0.481	
16.07	0.000	6.641	0.136	160.028	0.146	0.423	
17.07	0.000	7.115	0.125	159.625	0.050	0.505	
18.07	0.000	7.275	0.121	160.426	0.082	0.464	
19.07	0.000	7.248	0.115	159.786	0.099	0.435	
20.07	0.000	6.732	0.117	159.085	0.102	0.394	
21.07	0.000	6.863	0.145	159.938	0.046	0.382	
22.07	0.000	6.900	0.155	159.726	0.033	0.477	
23.07	0.000	6.401	0.167	160.098	0.061	0.378	
24.07	0.045	5.857	0.154	159.406	0.035	0.461	
25.07	0.000	6.417	0.156	159.557	0.011	0.367	
26.07	0.000	6.278	0.128	159.782	0.013	0.423	
27.07	0.000	6.476	0.123	160.147	0.084	0.438	
28.07	0.000	7.264	0.121	159.840	0.089	0.394	
29.07	0.000	7.142	0.149	159.787	0.091	0.341	
30.07	0.000	7.241	0.172	158.511	0.099	0.450	
31.07	0.000	6.821	0.158	159.683	0.164	0.364	
min	0.000	3.337	0.115	158.511	0.011	0.327	
max	1.216	7.275	0.190	160.762	0.205	0.510	
MMV	0.068	5.822	0.150	159.688	0.097	0.415	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							