

Menesine ataskaita: 08.2018



UAB Fortum Klaipeda		sugeneruota: 1.09.2018				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.08	21.839	12.729	4.586	0.155	1.400	5.953
2.08	20.186	12.802	2.887	0.149	1.136	5.948
3.08	21.036	12.743	4.269	0.114	0.804	4.223
4.08	22.381	12.651	2.992	0.215	0.513	0.292
5.08	22.565	12.623	3.882	0.140	0.539	0.491
6.08	X	X	X	X	X	X
7.08	22.534	11.205	X	21.597	1.984	4.037
8.08	19.617	12.758	3.906	0.588	1.688	7.565
9.08	20.336	12.791	4.237	0.289	1.053	9.144
10.08	20.026	12.694	3.805	0.165	0.883	8.310
11.08	20.720	12.747	3.673	0.182	0.954	8.677
12.08	20.779	12.722	3.924	0.317	0.818	8.005
13.08	20.605	12.629	4.075	0.257	1.057	8.047
14.08	20.806	12.723	7.398	0.931	3.323	7.711
15.08	21.597	12.726	3.850	0.258	3.226	5.818
16.08	21.578	12.617	5.786	0.228	5.245	5.229
17.08	21.876	12.823	4.103	0.193	3.384	4.928
18.08	22.572	12.753	4.611	0.143	2.860	5.401
19.08	21.456	12.796	3.855	0.016	2.608	4.886
20.08	20.888	12.742	3.185	0.066	2.202	5.120
21.08	20.949	12.803	3.937	0.154	1.869	5.250
22.08	21.799	12.816	4.131	0.435	1.505	5.439
23.08	21.564	12.902	4.088	0.154	1.459	5.125
24.08	20.855	12.950	3.345	0.060	1.414	4.957
25.08	21.379	12.952	2.602	0.432	1.299	5.023
26.08	21.363	12.806	2.762	0.333	1.071	4.665
27.08	20.884	12.736	3.279	0.300	1.110	5.329
28.08	19.628	12.933	3.034	0.035	1.770	5.054
29.08	19.484	13.041	4.032	0.448	1.463	5.640
30.08	19.885	13.028	3.828	0.219	1.485	5.725
31.08	19.083	13.044	3.680	0.391	1.195	5.591
min	19.083	11.205	2.602	0.016	0.513	0.292
max	22.572	13.044	7.398	21.597	5.245	9.144
MMV	21.093	12.707	3.942	1.345	1.694	5.467
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 08.2018



	UAB Fortum Klaipeda						sugeneruota: 1.09.2018
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.08	0.076	0.001	134.555	0.532	0.666	200324.70	
2.08	0.082	0.010	134.145	0.577	0.640	195099.42	
3.08	0.072	0.009	134.480	0.628	0.640	193516.57	
4.08	0.069	0.006	134.877	0.713	0.544	189913.81	
5.08	0.072	0.001	134.863	0.699	0.580	192219.54	
6.08	X	X	X	X	0.567	191965.68	
7.08	0.063	0.001	138.525	0.671	0.581	195329.31	
8.08	0.078	0.003	134.981	0.423	0.679	192010.54	
9.08	0.079	0.000	134.904	0.500	0.689	194475.67	
10.08	0.079	0.002	135.196	0.491	0.701	192659.20	
11.08	0.067	0.000	134.980	0.424	0.765	196083.04	
12.08	0.071	0.000	135.403	0.471	0.658	196942.70	
13.08	0.075	0.000	135.221	0.554	0.752	195956.26	
14.08	0.068	0.000	135.850	0.505	0.763	194851.48	
15.08	0.069	0.000	135.635	0.537	0.616	197226.14	
16.08	0.075	0.000	141.227	0.585	0.735	196640.82	
17.08	0.065	0.000	135.013	0.488	0.642	194942.45	
18.08	0.064	0.000	134.899	0.468	0.711	201029.00	
19.08	0.073	0.000	134.937	0.504	0.693	197315.70	
20.08	0.080	0.000	135.088	0.567	0.734	193742.51	
21.08	0.071	0.001	132.243	0.508	0.631	193451.76	
22.08	0.064	0.000	135.327	0.465	0.696	198690.76	
23.08	0.073	0.000	134.773	0.489	0.772	199090.92	
24.08	0.079	0.000	130.567	0.528	0.744	195918.32	
25.08	0.070	0.000	127.576	0.429	0.711	196854.07	
26.08	0.070	0.000	127.351	0.518	0.681	198335.87	
27.08	0.068	0.012	127.541	0.526	0.627	195298.20	
28.08	0.075	0.000	126.284	0.545	0.656	188890.57	
29.08	0.077	0.000	127.435	0.440	0.611	187347.23	
30.08	0.076	0.000	127.051	0.435	0.653	190490.07	
31.08	0.075	0.000	126.187	0.461	0.745	185241.51	
min	0.063	0.000	126.187	0.423	0.544	185241.51	
max	0.082	0.012	141.227	0.713	0.772	201029.00	
MMV	0.072	0.002	133.215	0.528	0.674	194575.71	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 08.2018



	UAB Fortum Klaipeda			sugeneruota: 1.09.2018		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.08	139.479	1029.709	6.641	1018.828	1064.637	5.093
2.08	136.226	1029.898	6.703	1018.788	1089.415	3.215
3.08	109.547	1027.869	6.577	1016.876	1065.486	4.710
4.08	62.529	1023.901	6.481	1012.906	1084.024	3.322
5.08	62.291	1020.144	6.536	1009.231	1051.757	4.308
6.08	61.960	1021.126	X	1010.676	1061.174	X
7.08	86.913	1024.910	6.077	1013.383	1055.083	X
8.08	138.399	1026.590	6.616	1015.076	1070.971	4.329
9.08	138.763	1026.459	6.458	1015.527	1078.368	4.714
10.08	137.445	1024.571	6.459	1014.876	1081.745	4.238
11.08	138.863	1026.661	6.373	1016.500	1066.825	4.082
12.08	138.232	1018.539	6.455	1009.693	1072.125	4.358
13.08	138.874	1019.756	6.993	1009.497	1041.510	4.527
14.08	141.934	1017.551	6.872	1007.382	1041.636	8.223
15.08	141.877	1019.084	6.532	1008.646	1055.763	4.272
16.08	145.164	1027.986	7.358	1016.596	1019.867	6.451
17.08	144.102	1027.804	5.894	1016.788	1054.789	4.554
18.08	145.747	1025.761	6.213	1015.907	1058.382	5.124
19.08	143.807	1026.405	6.625	1016.045	1067.861	4.266
20.08	142.201	1019.940	6.790	1009.542	1074.641	3.548
21.08	142.327	1023.263	6.764	1013.394	1074.128	4.388
22.08	143.917	1030.904	6.718	1020.237	1060.677	4.581
23.08	144.365	1024.911	6.786	1014.175	1060.710	4.549
24.08	142.297	1015.265	6.597	1005.068	1063.416	3.724
25.08	143.724	1016.378	6.206	1006.534	1103.475	2.893
26.08	144.395	1018.930	6.541	1009.148	1089.864	3.059
27.08	143.344	1023.790	6.789	1013.225	1099.231	3.642
28.08	140.975	1023.673	6.885	1013.645	1054.110	3.372
29.08	140.004	1027.937	6.791	1017.372	1061.029	4.487
30.08	140.893	1025.615	6.648	1014.832	1064.491	4.243
31.08	138.773	1023.321	6.832	1011.771	1059.696	4.098
min	61.960	1015.265	5.894	1005.068	1019.867	2.893
max	145.747	1030.904	7.358	1020.237	1103.475	8.223
MMV	130.947	1023.827	6.591	1013.296	1066.029	4.381
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 08.2018



	UAB Fortum Klaipeda						sugeneruota: 1.09.2018
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.08	0.194	9.922	0.126	168.194	0.760	0.952	
2.08	0.187	9.913	0.136	167.682	0.824	0.914	
3.08	0.142	7.038	0.120	168.100	0.897	0.915	
4.08	0.268	0.486	0.115	168.596	1.018	0.777	
5.08	0.175	0.818	0.120	168.578	0.999	0.828	
6.08	X	X	X	X	X	0.811	
7.08	26.997	6.729	0.106	173.157	0.958	0.830	
8.08	0.735	D 12.609	0.130	168.726	0.604	0.970	
9.08	0.361	D 15.239	0.131	168.630	0.714	0.984	
10.08	0.207	D 13.850	0.131	168.995	0.701	1.001	
11.08	0.227	D 14.461	0.112	168.725	0.606	1.093	
12.08	0.396	D 13.342	0.119	169.254	0.672	0.940	
13.08	0.322	D 13.412	0.125	169.027	0.791	1.074	
14.08	1.164	D 12.852	0.114	169.813	0.721	1.090	
15.08	0.322	9.697	0.115	169.544	0.768	0.880	
16.08	0.285	8.714	0.124	176.534	0.836	1.050	
17.08	0.241	8.213	0.109	168.766	0.698	0.916	
18.08	0.179	9.001	0.107	168.624	0.669	1.016	
19.08	0.020	8.144	0.121	168.672	0.720	0.990	
20.08	0.083	8.533	0.134	168.860	0.810	1.049	
21.08	0.192	8.750	0.118	165.304	0.726	0.901	
22.08	0.544	9.064	0.107	169.159	0.665	0.995	
23.08	0.192	8.541	0.121	168.466	0.698	1.103	
24.08	0.075	8.261	0.132	163.208	0.754	1.063	
25.08	0.540	8.372	0.117	159.470	0.612	1.016	
26.08	0.416	7.775	0.116	159.188	0.740	0.973	
27.08	0.375	8.882	0.114	159.426	0.751	0.896	
28.08	0.043	8.424	0.126	157.855	0.778	0.938	
29.08	0.560	9.399	0.128	159.294	0.628	0.873	
30.08	0.273	9.542	0.126	158.813	0.622	0.932	
31.08	0.489	9.318	0.125	157.733	0.658	1.065	
min	0.020	0.486	0.106	157.733	0.604	0.777	
max	26.997	D 15.239	0.136	176.534	1.018	1.103	
MMV	1.681	9.112	0.120	166.519	0.754	0.962	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							