

Menesine ataskaita: 08.2021



UAB Fortum Klaipeda		sugeneruota: 1.09.2021				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.08	19.133	7.307	2.694	0.000	0.904	4.315
2.08	16.999	7.356	2.742	0.000	0.626	4.016
3.08	18.191	7.373	2.979	0.000	0.885	4.819
4.08	18.766	7.338	2.835	0.000	1.113	4.250
5.08	18.569	7.345	2.401	0.000	0.806	4.201
6.08	18.843	7.312	3.020	0.000	0.740	3.916
7.08	19.835	7.289	3.284	0.000	0.913	4.309
8.08	19.126	7.333	2.579	0.000	1.073	3.393
9.08	20.124	7.307	2.942	0.000	0.960	3.413
10.08	19.333	7.418	3.399	0.000	1.149	3.108
11.08	19.414	7.375	3.225	1.446	1.618	2.920
12.08	19.501	7.378	3.110	0.567	2.664	2.295
13.08	18.743	7.424	2.984	0.046	2.314	2.291
14.08	19.291	7.449	3.142	0.000	1.139	3.539
15.08	19.950	7.328	3.363	0.000	1.195	3.613
16.08	19.413	7.340	2.890	0.000	1.592	2.998
17.08	19.555	7.361	2.884	0.000	1.286	2.799
18.08	19.880	7.321	2.956	0.000	0.939	3.099
19.08	18.921	7.283	3.549	0.000	0.780	3.520
20.08	18.642	7.314	2.637	0.000	0.972	3.731
21.08	18.800	7.382	3.027	0.000	0.804	4.410
22.08	20.174	7.360	3.192	0.000	0.990	4.468
23.08	19.248	7.378	3.575	0.019	1.393	3.834
24.08	18.078	7.338	3.079	0.001	0.987	3.953
25.08	17.766	7.329	4.039	1.978	0.978	4.136
26.08	17.599	7.372	2.573	0.363	0.917	3.854
27.08	18.829	7.370	3.402	0.032	1.009	3.399
28.08	19.402	7.344	3.390	0.000	0.872	4.051
29.08	19.643	7.369	3.232	0.000	0.874	4.243
30.08	18.648	7.375	2.205	0.162	0.748	3.530
31.08	18.627	7.331	2.892	0.010	0.951	3.285
min	16.999	7.283	2.205	0.000	0.626	2.291
max	20.174	7.449	4.039	1.978	2.664	4.819
MMV	19.001	7.352	3.039	0.149	1.103	3.668
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 08.2021



	UAB Fortum Klaipeda						sugeneruota: 1.09.2021
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.08	0.023	0.000	131.569	0.001	0.479	221993.43	
2.08	0.022	0.000	130.806	0.000	0.220	216494.73	
3.08	0.023	0.000	131.917	0.000	X	221556.67	
4.08	0.022	0.000	131.263	0.000	X	223304.95	
5.08	0.023	0.000	131.554	0.000	0.304	222881.60	
6.08	0.023	0.000	131.860	0.000	0.352	225659.85	
7.08	0.024	0.000	131.828	0.003	0.239	228178.00	
8.08	0.023	0.000	131.637	0.000	0.198	226071.75	
9.08	0.024	0.000	131.422	0.000	0.205	228001.37	
10.08	0.023	0.000	132.215	0.002	0.198	226098.57	
11.08	0.023	0.000	131.701	0.001	0.236	228454.32	
12.08	0.025	0.000	131.777	0.000	0.172	228235.85	
13.08	0.025	0.000	131.675	0.000	0.262	224873.14	
14.08	0.023	0.000	131.679	0.000	0.274	226266.29	
15.08	0.024	0.000	131.421	0.000	0.260	228269.00	
16.08	0.023	0.000	131.374	0.000	0.250	225184.35	
17.08	0.023	0.000	131.589	0.000	0.258	227365.42	
18.08	0.025	0.000	131.248	0.001	X	226579.57	
19.08	0.023	0.000	131.202	0.000	X	225005.95	
20.08	0.025	0.000	131.357	0.000	0.206	223923.07	
21.08	0.023	0.001	131.796	0.001	0.245	224343.79	
22.08	0.024	0.000	131.888	0.002	0.286	229175.35	
23.08	0.023	0.000	131.213	0.000	0.264	212651.82	
24.08	0.023	0.000	131.156	0.000	0.221	207428.04	
25.08	0.024	0.000	131.145	0.004	X	203266.95	
26.08	0.023	0.000	131.976	0.002	X	204821.79	
27.08	0.023	0.000	131.516	0.001	X	208698.37	
28.08	0.025	0.000	131.668	0.001	X	211363.82	
29.08	0.026	0.000	131.694	0.001	X	213093.04	
30.08	0.026	0.000	130.684	0.008	X	208233.37	
31.08	0.025	0.000	131.504	0.004	0.507	209165.39	
min	0.022	0.000	130.684	0.000	0.172	203266.95	
max	0.026	0.001	132.215	0.008	0.507	229175.35	
MMV	0.024	0.000	131.527	0.001	0.295	220536.81	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 08.2021



	UAB Fortum Klaipeda			sugeneruota: 1.09.2021		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.08	140.831	1019.595	5.966	1003.375	1035.118	3.000
2.08	136.532	1018.374	6.424	1002.355	1032.838	3.044
3.08	138.674	1024.716	6.189	1008.167	1031.254	3.317
4.08	140.052	1029.292	6.060	1012.421	1051.217	3.155
5.08	139.532	1027.607	6.117	1010.902	1052.681	2.664
6.08	139.843	1019.285	6.024	1004.359	1030.814	3.361
7.08	141.811	1017.015	5.939	1000.539	1006.022	3.642
8.08	140.754	1023.894	5.997	1006.957	1036.276	2.866
9.08	142.123	1031.509	5.892	1014.377	1044.552	3.268
10.08	140.448	1032.566	5.964	1015.426	1007.235	3.770
11.08	140.340	1028.796	5.899	1012.494	1033.514	3.590
12.08	140.886	1033.251	5.883	1016.123	1021.740	3.456
13.08	139.257	1036.022	6.075	1018.626	1024.689	3.322
14.08	140.275	1029.763	5.865	1013.529	1017.409	3.485
15.08	141.402	1025.169	5.752	1008.820	1028.147	3.744
16.08	140.520	1022.071	5.837	1004.768	1018.984	3.212
17.08	140.964	1017.401	5.812	1001.724	1042.919	3.203
18.08	140.829	1015.976	5.817	1000.463	1047.846	3.274
19.08	139.500	1018.405	5.998	1002.381	1041.834	3.949
20.08	138.752	1026.677	6.039	1010.058	1027.309	2.926
21.08	139.367	1030.514	6.045	1013.965	996.545	3.360
22.08	141.776	1033.944	5.818	1017.077	1018.047	3.542
23.08	140.370	1036.047	6.048	1020.304	985.377	3.979
24.08	138.007	1038.561	6.276	1023.143	1007.782	3.420
25.08	137.515	1028.197	6.259	1011.651	1009.615	4.438
26.08	136.898	1017.878	6.289	1000.994	1025.990	2.860
27.08	139.658	1026.180	6.072	1010.069	1027.494	3.784
28.08	140.464	1027.660	5.965	1010.798	1011.143	3.774
29.08	141.214	1026.997	5.962	1010.693	1026.210	3.586
30.08	139.053	1028.759	6.204	1012.513	1054.955	2.450
31.08	138.956	1027.194	6.156	1011.158	1021.982	3.221
min	136.532	1015.976	5.752	1000.463	985.377	2.450
max	142.123	1038.561	6.424	1023.143	1054.955	4.438
MMV	139.891	1026.430	6.021	1010.008	1026.371	3.376
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 08.2021



	UAB Fortum Klaipeda						sugeneruota: 1.09.2021
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.08	0.000	7.192	0.038	164.462	0.001	0.684	
2.08	0.000	6.693	0.037	163.508	0.001	0.314	
3.08	0.000	8.031	0.038	164.896	0.000	X	
4.08	0.000	7.083	0.037	164.079	0.000	X	
5.08	0.000	7.001	0.039	164.443	0.000	0.435	
6.08	0.000	6.527	0.039	164.824	0.000	0.503	
7.08	0.000	7.182	0.041	164.784	0.004	0.342	
8.08	0.000	5.655	0.038	164.547	0.001	0.283	
9.08	0.000	5.689	0.040	164.278	0.000	0.293	
10.08	0.000	5.180	0.038	165.269	0.002	0.283	
11.08	1.807	4.866	0.038	164.626	0.001	0.337	
12.08	0.709	3.825	0.041	164.722	0.000	0.246	
13.08	0.058	3.818	0.041	164.593	0.000	0.375	
14.08	0.000	5.898	0.038	164.598	0.000	0.391	
15.08	0.000	6.022	0.041	164.276	0.000	0.372	
16.08	0.000	4.996	0.038	164.217	0.000	0.357	
17.08	0.000	4.666	0.039	164.486	0.000	0.369	
18.08	0.000	5.165	0.042	164.060	0.001	X	
19.08	0.000	5.866	0.039	164.003	0.000	X	
20.08	0.000	6.218	0.042	164.196	0.000	0.295	
21.08	0.000	7.350	0.039	164.745	0.002	0.350	
22.08	0.000	7.447	0.040	164.861	0.003	0.408	
23.08	0.024	6.390	0.039	164.016	0.001	0.377	
24.08	0.001	6.589	0.038	163.946	0.001	0.316	
25.08	2.473	6.893	0.040	163.932	0.005	X	
26.08	0.454	6.423	0.039	164.970	0.003	X	
27.08	0.040	5.666	0.039	164.396	0.001	X	
28.08	0.000	6.752	0.041	164.585	0.001	X	
29.08	0.000	7.072	0.044	164.618	0.002	X	
30.08	0.203	5.882	0.044	163.354	0.012	X	
31.08	0.012	5.476	0.042	164.380	0.005	0.724	
min	0.000	3.818	0.037	163.354	0.000	0.246	
max	2.473	8.031	0.044	165.269	0.012	0.724	
MMV	0.187	6.113	0.040	164.409	0.002	0.422	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							