

Menesine ataskaita: 09.2017



	UAB Fortum Klaipeda						sugeneruota: 1.10.2017
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.09	19.462	11.737	4.312	8.967	0.000	5.793	
2.09	19.376	11.791	3.907	20.421	0.000	6.729	
3.09	19.971	11.707	3.228	33.684	0.007	6.614	
4.09	20.348	11.612	2.072	25.191	0.001	6.077	
5.09	18.561	11.571	1.534	9.151	0.000	4.862	
6.09	20.224	11.568	2.568	5.611	0.000	6.860	
7.09	19.066	11.549	2.501	3.987	0.000	7.439	
8.09	19.070	11.585	2.622	4.349	0.000	8.716	
9.09	19.775	11.677	4.397	21.219	0.001	8.177	
10.09	19.586	11.610	3.649	15.387	0.000	7.336	
11.09	20.451	11.526	5.686	9.595	0.000	7.272	
12.09	19.551	11.703	3.905	6.890	0.000	7.470	
13.09	19.478	11.690	2.929	13.571	0.000	7.948	
14.09	19.425	11.352	3.162	D 52.035	0.012	7.467	
15.09	19.154	11.245	3.268	3.928	0.008	5.302	
16.09	20.324	11.172	3.870	5.802	0.019	7.640	
17.09	19.452	11.433	3.379	25.352	0.050	7.259	
18.09	19.686	11.429	4.081	33.610	0.013	7.415	
19.09	19.810	11.578	4.651	13.537	0.000	5.562	
20.09	20.187	11.709	3.485	13.891	0.000	6.702	
21.09	20.273	11.109	4.329	7.432	0.073	6.214	
22.09	21.447	11.432	3.586	7.560	0.021	7.795	
23.09	21.263	11.568	3.160	17.518	0.027	7.087	
24.09	21.767	11.574	2.885	6.624	0.190	7.953	
25.09	21.276	11.530	3.844	11.529	0.434	6.826	
26.09	19.749	11.582	5.285	4.256	0.049	7.704	
27.09	19.868	11.723	3.164	8.719	0.007	7.255	
28.09	19.730	11.715	3.311	16.779	0.000	6.801	
29.09	20.633	11.742	5.667	6.870	0.019	5.968	
30.09	20.611	11.670	3.997	5.571	0.000	6.681	
min	18.561	11.109	1.534	3.928	0.000	4.862	
max	21.767	11.791	5.686	D 52.035	0.434	8.716	
MMV	19.986	11.563	3.613	13.994	0.031	6.965	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 09.2017



	UAB Fortum Klaipeda						sugeneruota: 1.10.2017
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.09	0.078	0.124	168.631	0.496	0.677	222320.37	
2.09	0.077	0.061	169.638	0.434	0.632	223687.37	
3.09	0.078	0.083	169.819	0.484	0.686	225190.95	
4.09	0.078	0.113	170.114	0.504	0.906	226986.81	
5.09	0.077	0.101	168.614	0.428	0.777	223027.26	
6.09	0.078	0.059	169.335	0.394	0.712	226997.06	
7.09	0.077	0.019	169.755	0.263	0.880	225052.81	
8.09	0.077	0.007	169.316	0.305	0.781	223447.04	
9.09	0.078	0.069	169.538	0.461	0.727	226505.81	
10.09	0.078	0.052	169.118	0.394	0.847	225717.10	
11.09	0.078	0.086	169.163	0.383	0.637	227798.70	
12.09	0.078	0.101	170.019	0.406	0.592	226338.54	
13.09	0.078	0.066	169.356	0.451	0.743	226458.04	
14.09	0.079	0.047	169.624	0.362	0.724	227617.43	
15.09	0.080	0.032	169.187	0.272	0.812	226550.01	
16.09	0.082	0.062	169.887	0.399	0.734	235005.39	
17.09	0.079	0.046	168.791	0.426	0.843	230268.01	
18.09	0.078	0.020	169.872	0.458	2.338	228046.81	
19.09	0.078	0.058	168.973	0.430	1.078	227587.85	
20.09	0.078	0.042	170.120	0.385	0.956	228782.04	
21.09	0.082	0.007	168.985	0.366	0.801	234666.95	
22.09	0.080	0.017	169.809	0.260	0.777	231734.51	
23.09	0.078	0.081	170.134	0.368	0.916	231521.29	
24.09	0.078	0.069	169.980	0.377	0.873	231611.20	
25.09	0.079	0.069	169.612	0.360	0.903	231822.39	
26.09	0.078	0.061	169.544	0.343	0.791	227025.64	
27.09	0.077	0.088	169.034	0.354	0.792	227934.79	
28.09	0.078	0.061	170.028	0.328	0.807	227498.04	
29.09	0.077	0.014	169.067	0.268	0.739	227989.17	
30.09	0.077	0.017	170.539	0.304	0.944	229213.35	
min	0.077	0.007	168.614	0.260	0.592	222320.37	
max	0.082	0.124	170.539	0.504	2.338	235005.39	
MMV	0.078	0.058	169.521	0.382	0.843	227813.62	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 09.2017



	UAB Fortum Klaipeda			sugeneruota: 1.10.2017		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.09	145.789	1018.863	4.611	1013.251	1042.480	4.353
2.09	144.763	1015.097	4.638	1010.012	1052.477	3.912
3.09	145.048	1013.948	4.623	1006.576	1061.518	3.229
4.09	146.414	1012.079	4.543	1005.254	1089.372	2.075
5.09	143.645	1017.351	4.777	1011.358	1114.479	1.529
6.09	146.259	1017.069	4.495	1010.479	1100.683	2.576
7.09	144.101	1009.895	4.670	1003.627	1070.771	2.488
8.09	144.303	1011.205	4.680	1003.710	1085.294	2.625
9.09	146.239	1008.654	4.600	1001.051	1054.004	4.390
10.09	145.645	1008.268	4.617	1001.538	1070.771	3.646
11.09	146.641	1009.712	4.464	1002.481	1059.525	5.476
12.09	145.876	1007.248	4.547	1000.159	1045.508	3.905
13.09	145.385	1004.686	4.605	998.189	1089.374	2.924
14.09	144.148	996.793	4.875	990.574	1077.529	3.168
15.09	144.384	1004.201	5.182	998.374	1060.844	3.299
16.09	147.297	1018.000	5.265	1010.360	1049.647	3.872
17.09	145.399	1016.295	4.937	1010.642	1071.301	3.380
18.09	145.139	1006.126	4.764	1000.385	1072.217	4.073
19.09	145.754	1017.310	4.567	1009.837	1074.089	4.666
20.09	146.265	1022.886	4.545	1015.232	1073.210	3.482
21.09	147.210	1021.105	5.331	1015.796	1057.055	4.336
22.09	148.162	1022.885	4.653	1015.414	1062.758	3.590
23.09	148.166	1027.281	4.419	1019.660	1059.464	3.160
24.09	148.860	1031.886	4.297	1024.976	1045.733	2.889
25.09	147.711	1035.170	4.539	1028.767	1047.544	3.830
26.09	144.984	1038.436	4.648	1031.454	1038.096	5.291
27.09	145.385	1040.841	4.524	1034.129	1073.929	3.178
28.09	144.899	1041.008	4.578	1034.296	1094.307	3.324
29.09	146.731	1038.040	4.398	1031.498	1054.515	5.708
30.09	146.447	1033.740	4.395	1027.724	1057.239	3.995
min	143.645	996.793	4.297	990.574	1038.096	1.529
max	148.860	1041.008	5.331	1034.296	1114.479	5.708
MMV	145.902	1018.869	4.659	1012.228	1066.857	3.612
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 09.2017



UAB Fortum Klaipeda		sugeneruota: 1.10.2017				
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.09	8.967	5.793	0.078	168.631	0.496	0.677
2.09	20.421	6.729	0.077	169.638	0.434	0.632
3.09	33.684	6.614	0.078	169.819	0.484	0.686
4.09	25.191	6.077	0.078	170.114	0.504	0.906
5.09	9.151	4.862	0.077	168.614	0.428	0.777
6.09	5.611	6.860	0.078	169.335	0.394	0.712
7.09	3.987	7.439	0.077	169.755	0.263	0.880
8.09	4.349	8.716	0.077	169.316	0.305	0.781
9.09	21.219	8.177	0.078	169.538	0.461	0.727
10.09	15.387	7.336	0.078	169.118	0.394	0.847
11.09	9.595	7.272	0.078	169.163	0.383	0.637
12.09	6.890	7.470	0.078	170.019	0.406	0.592
13.09	13.571	7.948	0.078	169.356	0.451	0.743
14.09	D 52.035	7.467	0.079	169.624	0.362	0.724
15.09	3.928	5.302	0.080	169.187	0.272	0.812
16.09	5.802	7.640	0.082	169.887	0.399	0.734
17.09	25.352	7.259	0.079	168.791	0.426	0.843
18.09	33.610	7.415	0.078	169.872	0.458	2.338
19.09	13.537	5.562	0.078	168.973	0.430	1.078
20.09	13.891	6.702	0.078	170.120	0.385	0.956
21.09	7.432	6.214	0.082	168.985	0.366	0.801
22.09	7.560	7.795	0.080	169.809	0.260	0.777
23.09	17.518	7.087	0.078	170.134	0.368	0.916
24.09	6.624	7.953	0.078	169.980	0.377	0.873
25.09	11.529	6.826	0.079	169.612	0.360	0.903
26.09	4.256	7.704	0.078	169.544	0.343	0.791
27.09	8.719	7.255	0.077	169.034	0.354	0.792
28.09	16.779	6.801	0.078	170.028	0.328	0.807
29.09	6.870	5.968	0.077	169.067	0.268	0.739
30.09	5.571	6.681	0.077	170.539	0.304	0.944
min	3.928	4.862	0.077	168.614	0.260	0.592
max	D 52.035	8.716	0.082	170.539	0.504	2.338
MMV	13.994	6.965	0.078	169.521	0.382	0.843
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						