

# Menesine ataskaita: 09.2018



	UAB Fortum Klaipeda						sugeneruota: 1.10.2018
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.09	18.915	12.963	4.084	0.729	1.078	5.930	
2.09	20.310	12.908	2.839	0.312	1.265	6.476	
3.09	20.635	12.895	2.451	0.288	0.892	4.388	
4.09	23.548	11.663	X	14.805	2.184	2.422	
5.09	24.128	11.363	X	21.579	3.246	3.554	
6.09	23.146	11.412	X	24.753	3.129	3.199	
7.09	20.533	12.722	X	3.340	2.489	6.201	
8.09	20.808	12.892	2.815	0.048	1.914	7.856	
9.09	20.959	12.907	2.794	0.045	1.943	5.455	
10.09	20.606	12.962	3.206	0.170	1.332	5.324	
11.09	21.190	12.782	3.830	0.229	2.167	5.072	
12.09	21.789	12.757	4.822	0.080	3.373	5.003	
13.09	20.195	11.763	4.692	0.027	3.260	4.817	
14.09	20.467	9.121	4.266	0.008	3.333	4.438	
15.09	20.915	9.043	3.902	0.058	3.231	4.485	
16.09	21.329	8.979	3.889	0.032	3.043	4.654	
17.09	X	X	X	X	X	X	
18.09	21.659	9.022	3.790	0.064	2.995	5.025	
19.09	22.046	8.968	4.074	0.148	2.158	4.881	
20.09	21.380	8.979	3.938	0.642	2.190	4.768	
21.09	21.316	8.980	4.425	0.094	1.994	4.233	
22.09	22.360	8.957	4.242	4.745	3.323	3.881	
23.09	20.005	8.962	2.784	0.416	2.305	2.975	
24.09	19.946	8.998	2.739	0.465	2.204	4.284	
25.09	20.514	9.115	4.732	0.650	3.009	4.996	
26.09	20.019	9.082	3.662	0.537	2.059	4.546	
27.09	20.743	9.037	4.544	0.617	1.802	4.985	
28.09	20.683	8.999	3.146	0.527	1.948	5.199	
29.09	20.143	9.150	2.861	0.712	2.022	4.800	
30.09	20.651	8.991	2.480	0.760	1.998	4.746	
min	18.915	8.957	2.451	0.008	0.892	2.422	
max	24.128	12.963	4.822	24.753	3.373	7.856	
MMV	21.086	10.538	3.646	2.614	2.355	4.779	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 09.2018



	UAB Fortum Klaipeda						sugeneruota: 1.10.2018
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.09	0.082	0.000	126.984	0.470	0.635	184372.56	
2.09	0.075	0.000	127.095	0.483	0.683	188924.20	
3.09	0.072	0.000	125.886	0.517	0.718	192474.12	
4.09	0.062	0.000	128.969	0.570	0.571	189509.37	
5.09	0.056	0.000	137.688	0.657	0.562	190711.85	
6.09	0.063	0.000	154.445	0.614	0.580	186734.56	
7.09	0.076	0.000	128.587	0.534	0.625	176433.04	
8.09	0.080	0.000	127.524	0.447	0.672	188711.82	
9.09	0.073	0.000	127.195	0.488	0.677	195624.68	
10.09	0.071	0.000	127.002	0.528	0.671	193826.29	
11.09	0.078	0.000	127.113	0.551	0.741	193518.98	
12.09	0.084	0.006	126.755	0.562	0.812	200741.14	
13.09	0.089	0.000	128.029	0.493	0.705	191403.67	
14.09	0.079	0.000	127.296	0.478	0.725	196854.39	
15.09	0.074	0.000	127.159	0.481	0.735	197225.25	
16.09	0.069	0.000	127.180	0.507	0.691	197736.56	
17.09	X	X	X	X	0.866	173906.32	
18.09	0.067	0.000	127.374	0.457	0.685	196333.25	
19.09	0.060	0.000	126.893	0.381	0.720	198295.92	
20.09	0.061	0.000	126.587	0.441	0.736	195031.93	
21.09	0.067	0.000	127.066	0.496	0.621	197411.75	
22.09	0.061	0.000	128.037	0.520	0.775	202091.68	
23.09	0.065	0.000	126.713	0.463	0.689	192597.26	
24.09	0.062	0.000	126.688	0.356	0.692	192329.23	
25.09	0.061	0.000	127.027	0.419	0.804	193770.67	
26.09	0.062	0.000	127.191	0.350	0.832	190673.45	
27.09	0.064	0.000	127.458	0.480	0.704	192650.23	
28.09	0.064	0.000	127.133	0.441	0.784	192652.60	
29.09	0.059	0.000	127.242	0.411	0.768	190150.25	
30.09	0.063	0.000	127.561	0.384	0.736	192792.93	
min	0.056	0.000	125.886	0.350	0.562	173906.32	
max	0.089	0.006	154.445	0.657	0.866	202091.68	
MMV	0.069	0.000	128.451	0.483	0.707	192183.10	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 09.2018



	UAB Fortum Klaipeda			sugeneruota: 1.10.2018		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.09	138.092	1031.001	6.930	1020.354	1053.967	4.518
2.09	141.089	1035.708	6.644	1025.190	1081.607	3.158
3.09	114.610	1031.789	6.619	1021.755	1110.113	2.727
4.09	58.402	1025.470	6.147	1014.314	1086.835	X
5.09	59.345	1025.667	5.792	1014.953	1078.908	X
6.09	58.710	1025.037	6.432	1013.659	1063.704	X
7.09	104.666	1022.827	6.703	1011.414	1060.395	X
8.09	140.753	1025.395	6.684	1015.127	1094.560	3.134
9.09	142.371	1030.791	6.600	1020.651	1104.638	3.113
10.09	141.719	1030.528	6.636	1019.979	1088.448	3.564
11.09	142.777	1025.537	7.187	1015.127	1052.475	4.249
12.09	144.052	1021.137	7.325	1011.679	1028.533	5.364
13.09	141.807	1026.485	7.585	1016.390	1034.008	5.223
14.09	142.937	1027.832	7.237	1017.333	1043.919	4.734
15.09	143.312	1024.424	7.076	1014.459	1063.037	4.341
16.09	143.748	1028.213	6.691	1018.249	1079.727	4.319
17.09	142.774	1026.698	X	1015.966	1074.424	X
18.09	144.070	1027.149	6.752	1015.397	1088.278	4.210
19.09	144.880	1023.282	6.730	1013.225	1073.609	4.533
20.09	144.562	1025.276	6.775	1014.148	1075.854	4.364
21.09	143.984	1018.988	6.822	1007.936	1070.695	4.922
22.09	145.111	1013.251	6.664	1005.559	1066.592	4.689
23.09	141.212	1013.744	6.965	1004.390	1072.838	3.101
24.09	140.912	1014.346	6.974	1005.447	1076.264	3.048
25.09	142.088	1031.611	7.423	1022.164	1061.592	5.358
26.09	140.669	1029.647	7.033	1019.764	1073.162	4.079
27.09	142.683	1022.540	6.718	1011.830	1092.323	5.059
28.09	143.150	1018.716	6.709	1009.335	1075.628	3.485
29.09	142.048	1029.508	6.809	1020.082	1074.365	3.170
30.09	143.695	1024.927	6.823	1014.557	1103.055	2.776
min	58.402	1013.251	5.792	1004.390	1028.533	2.727
max	145.111	1035.708	7.585	1025.190	1110.113	5.364
MMV	132.007	1025.250	6.806	1015.015	1073.452	4.042
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 09.2018



	UAB Fortum Klaipeda						sugeneruota: 1.10.2018
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.09	0.912	9.883	0.137	158.730	0.671	0.907	
2.09	0.390	D 10.793	0.124	158.868	0.690	0.976	
3.09	0.360	7.313	0.120	157.357	0.738	1.026	
4.09	18.507	4.037	0.103	161.211	0.814	0.816	
5.09	26.973	5.923	0.093	172.110	0.938	0.803	
6.09	30.941	5.331	0.105	193.057	0.877	0.829	
7.09	4.174	D 10.335	0.126	160.734	0.763	0.893	
8.09	0.059	D 13.093	0.133	159.406	0.638	0.960	
9.09	0.056	9.091	0.121	158.993	0.697	0.967	
10.09	0.212	8.873	0.118	158.752	0.755	0.959	
11.09	0.287	8.454	0.129	158.891	0.787	1.059	
12.09	0.100	8.339	0.139	158.444	0.802	1.160	
13.09	0.034	8.029	0.149	160.036	0.704	1.007	
14.09	0.010	7.396	0.132	159.120	0.683	1.036	
15.09	0.073	7.475	0.123	158.949	0.687	1.050	
16.09	0.040	7.756	0.115	158.975	0.724	0.987	
17.09	X	X	X	X	X	1.237	
18.09	0.080	8.375	0.111	159.218	0.653	0.979	
19.09	0.185	8.135	0.100	158.616	0.545	1.028	
20.09	0.802	7.947	0.102	158.234	0.630	1.051	
21.09	0.118	7.055	0.112	158.833	0.708	0.887	
22.09	5.931	6.469	0.102	160.047	0.743	1.108	
23.09	0.521	4.958	0.108	158.391	0.661	0.984	
24.09	0.581	7.141	0.103	158.360	0.508	0.989	
25.09	0.813	8.326	0.101	158.784	0.598	1.149	
26.09	0.671	7.577	0.103	158.989	0.500	1.188	
27.09	0.771	8.309	0.106	159.322	0.685	1.006	
28.09	0.659	8.665	0.107	158.916	0.629	1.120	
29.09	0.890	7.999	0.098	159.052	0.588	1.097	
30.09	0.950	7.910	0.104	159.452	0.549	1.052	
min	0.010	4.037	0.093	157.357	0.500	0.803	
max	30.941	D 13.093	0.149	193.057	0.938	1.237	
MMV	3.267	7.966	0.115	160.563	0.689	1.010	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							