

# Menesine ataskaita: 10.2017



	UAB Fortum Klaipeda						sugeneruota: 1.11.2017
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.10	20.465	11.600	7.023	16.428	0.047	5.992	
2.10	20.738	11.607	7.014	17.968	0.008	6.349	
3.10	19.895	11.515	4.539	11.877	0.169	5.880	
4.10	20.541	11.475	3.048	8.719	0.120	6.463	
5.10	19.405	11.393	5.482	7.836	0.061	8.200	
6.10	19.979	11.297	5.340	2.628	0.020	8.743	
7.10	19.812	11.488	3.347	4.832	0.001	9.231	
8.10	20.515	11.234	3.382	5.120	0.019	8.810	
9.10	20.503	11.288	6.107	3.918	0.178	8.039	
10.10	19.687	11.420	3.607	5.339	0.133	8.133	
11.10	14.253	11.645	3.582	3.941	0.089	3.554	
12.10	8.405	11.830	3.696	1.792	0.000	0.289	
13.10	8.720	11.779	5.713	0.543	0.000	0.351	
14.10	9.819	11.829	4.533	0.238	0.000	0.321	
15.10	10.855	11.482	3.967	0.461	0.000	0.327	
16.10	11.621	8.088	5.846	0.379	0.000	0.297	
17.10	14.580	8.096	5.545	1.870	0.000	0.315	
18.10	15.297	8.116	6.520	2.912	0.000	0.310	
19.10	11.980	8.209	4.180	2.670	0.000	0.270	
20.10	8.248	8.174	6.513	0.413	0.000	0.252	
21.10	9.210	8.182	4.668	0.592	0.000	0.313	
22.10	7.668	8.115	3.347	0.583	0.000	0.295	
23.10	7.712	8.115	4.504	0.946	0.000	0.291	
24.10	8.617	8.178	5.082	2.976	0.000	0.332	
25.10	7.978	8.150	5.387	7.104	0.000	0.331	
26.10	10.149	8.118	4.918	6.740	0.000	0.273	
27.10	8.892	8.151	4.939	5.012	0.000	0.296	
28.10	9.627	8.124	4.336	8.418	0.000	0.287	
29.10	10.047	8.062	6.312	8.857	0.000	0.343	
30.10	8.455	8.106	5.973	7.699	0.000	0.299	
31.10	7.955	8.115	5.389	4.889	0.000	0.272	
min	7.668	8.062	3.048	0.238	0.000	0.252	
max	20.738	11.830	7.023	17.968	0.178	9.231	
MMV	13.279	9.771	4.963	4.971	0.027	2.754	
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down							

# Menesine ataskaita: 10.2017



	UAB Fortum Klaipeda						sugeneruota: 1.11.2017
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.10	0.077	0.017	168.332	0.278	0.855	228677.92	
2.10	0.077	0.025	169.538	0.358	0.818	228564.68	
3.10	0.077	0.052	169.661	0.428	0.814	228552.00	
4.10	0.077	0.048	169.806	0.430	0.864	229552.56	
5.10	0.076	0.084	169.996	0.504	0.848	228601.01	
6.10	0.077	0.022	168.374	0.470	0.989	227708.76	
7.10	0.077	0.021	170.267	0.426	0.765	229222.95	
8.10	0.077	0.013	169.269	0.393	1.054	230631.54	
9.10	0.077	0.009	169.437	0.308	0.929	231131.85	
10.10	0.077	0.017	170.010	0.421	0.830	228938.23	
11.10	0.073	0.027	168.992	0.461	0.859	219507.57	
12.10	0.070	0.019	170.012	0.445	0.807	211329.31	
13.10	0.070	0.005	169.208	0.322	0.733	210302.95	
14.10	0.071	0.011	169.973	0.422	0.702	213460.29	
15.10	0.071	0.019	169.756	0.418	0.594	216529.89	
16.10	0.071	0.013	168.651	0.416	0.708	215304.42	
17.10	0.073	0.099	169.821	0.522	0.665	218626.18	
18.10	0.074	0.070	169.104	0.528	0.624	219671.48	
19.10	0.072	0.016	170.117	0.388	0.623	216589.04	
20.10	0.070	0.006	169.881	0.248	0.522	209613.64	
21.10	0.071	0.014	171.690	0.295	0.665	212400.37	
22.10	0.069	0.001	167.642	0.246	0.579	211635.64	
23.10	0.069	0.007	168.880	0.205	0.635	211355.29	
24.10	0.071	0.000	170.111	0.156	0.485	215200.31	
25.10	0.070	0.005	175.936	0.247	0.759	213641.64	
26.10	0.072	0.002	172.382	0.377	0.713	215077.06	
27.10	0.070	0.007	168.988	0.278	0.863	210890.23	
28.10	0.071	0.006	177.190	0.353	0.652	215164.76	
29.10	0.070	0.007	168.493	0.378	0.517	216386.37	
30.10	0.070	0.008	168.770	0.260	0.644	212163.26	
31.10	0.070	0.003	168.798	0.225	0.628	213839.64	
min	0.069	0.000	167.642	0.156	0.485	209613.64	
max	0.077	0.099	177.190	0.528	1.054	231131.85	
MMV	0.073	0.021	169.971	0.362	0.733	219037.40	
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down							

# Menesine ataskaita: 10.2017



	UAB Fortum Klaipeda			sugeneruota: 1.11.2017		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.10	146.301	1032.099	4.382	1025.979	1045.168	7.056
2.10	146.407	1024.021	4.319	1017.941	1059.358	7.027
3.10	145.559	1012.122	4.540	1005.215	1050.987	4.549
4.10	146.002	1009.404	4.261	1003.505	1047.824	3.052
5.10	145.159	997.489	4.366	991.230	1065.531	5.512
6.10	146.027	1001.771	4.348	995.102	1057.592	5.294
7.10	145.493	1009.480	4.391	1002.909	1042.260	3.385
8.10	146.424	1003.951	4.371	998.198	1038.528	3.397
9.10	146.267	1001.968	4.362	996.245	1016.600	6.125
10.10	145.655	1007.506	4.425	1000.996	1040.031	3.628
11.10	84.821	1011.085	4.696	1003.544	1023.997	3.608
12.10	43.237	1010.680	4.999	1002.582	1037.187	3.718
13.10	43.954	1014.185	5.102	1006.781	1029.656	5.705
14.10	46.183	1021.893	4.914	1013.649	1033.686	4.545
15.10	47.805	1025.152	4.902	1016.696	1035.311	3.993
16.10	49.436	1024.382	4.729	1016.250	1035.984	5.794
17.10	53.626	1023.422	4.631	1015.230	1065.982	5.584
18.10	54.733	1018.239	4.627	1010.886	1039.248	6.427
19.10	49.526	1023.634	4.861	1017.107	1076.405	4.214
20.10	42.969	1024.863	5.145	1018.044	1065.724	6.456
21.10	44.270	1022.112	5.089	1015.438	1080.671	4.731
22.10	41.718	1021.736	5.059	1015.275	1051.464	3.371
23.10	41.807	1021.158	5.082	1015.081	1074.761	4.455
24.10	43.781	1031.190	5.188	1024.296	1045.475	5.118
25.10	42.287	1022.510	5.150	1015.140	1046.817	5.385
26.10	46.035	1015.917	5.117	1006.608	1062.129	4.960
27.10	43.938	1012.544	5.020	1005.651	1058.034	4.936
28.10	45.224	1001.157	4.985	993.650	1064.336	4.364
29.10	45.327	985.803	4.815	979.265	1045.714	6.252
30.10	43.061	1002.136	5.030	996.433	1064.858	5.913
31.10	42.340	1015.967	5.082	1008.838	1062.076	5.429
min	41.718	985.803	4.261	979.265	1016.600	3.052
max	146.424	1032.099	5.188	1025.979	1080.671	7.056
MMV	79.160	1014.465	4.774	1007.503	1050.426	4.968
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						

# Menesine ataskaita: 10.2017



UAB Fortum Klaipeda		sugeneruota: 1.11.2017				
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.10	16.428	5.992	0.077	168.332	0.278	0.855
2.10	17.968	6.349	0.077	169.538	0.358	0.818
3.10	11.877	5.880	0.077	169.661	0.428	0.814
4.10	8.719	6.463	0.077	169.806	0.430	0.864
5.10	7.836	8.200	0.076	169.996	0.504	0.848
6.10	2.628	8.743	0.077	168.374	0.470	0.989
7.10	4.832	9.231	0.077	170.267	0.426	0.765
8.10	5.120	8.810	0.077	169.269	0.393	1.054
9.10	3.918	8.039	0.077	169.437	0.308	0.929
10.10	5.339	8.133	0.077	170.010	0.421	0.830
11.10	3.941	3.554	0.073	168.992	0.461	0.859
12.10	1.792	0.289	0.070	170.012	0.445	0.807
13.10	0.543	0.351	0.070	169.208	0.322	0.733
14.10	0.238	0.321	0.071	169.973	0.422	0.702
15.10	0.461	0.327	0.071	169.756	0.418	0.594
16.10	0.379	0.297	0.071	168.651	0.416	0.708
17.10	1.870	0.315	0.073	169.821	0.522	0.665
18.10	2.912	0.310	0.074	169.104	0.528	0.624
19.10	2.670	0.270	0.072	170.117	0.388	0.623
20.10	0.413	0.252	0.070	169.881	0.248	0.522
21.10	0.592	0.313	0.071	171.690	0.295	0.665
22.10	0.583	0.295	0.069	167.642	0.246	0.579
23.10	0.946	0.291	0.069	168.880	0.205	0.635
24.10	2.976	0.332	0.071	170.111	0.156	0.485
25.10	7.104	0.331	0.070	175.936	0.247	0.759
26.10	6.740	0.273	0.072	172.382	0.377	0.713
27.10	5.012	0.296	0.070	168.988	0.278	0.863
28.10	8.418	0.287	0.071	177.190	0.353	0.652
29.10	8.857	0.343	0.070	168.493	0.378	0.517
30.10	7.699	0.299	0.070	168.770	0.260	0.644
31.10	4.889	0.272	0.070	168.798	0.225	0.628
min	0.238	0.252	0.069	167.642	0.156	0.485
max	17.968	9.231	0.077	177.190	0.528	1.054
MMV	4.971	2.754	0.073	169.971	0.362	0.733
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						