

Menesine ataskaita: 10.2018



UAB Fortum Klaipeda		sugeneruota: 1.11.2018				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.10	18.865	9.006	2.656	1.151	1.642	4.038
2.10	18.312	9.002	2.193	1.317	0.954	4.439
3.10	19.142	9.024	2.937	1.310	1.606	5.067
4.10	18.416	9.140	1.761	0.853	2.116	4.691
5.10	18.059	9.149	4.008	0.502	2.070	5.037
6.10	20.036	9.058	3.255	1.166	2.637	4.834
7.10	20.585	8.935	2.893	0.198	1.960	4.268
8.10	20.027	9.026	2.142	0.214	1.859	3.915
9.10	17.945	8.992	2.295	0.460	0.981	3.722
10.10	18.185	9.038	4.740	0.283	1.318	4.284
11.10	18.516	9.088	3.819	0.180	1.455	4.175
12.10	18.534	9.032	11.641	0.172	1.530	4.074
13.10	19.169	9.075	3.278	0.165	1.272	4.301
14.10	19.319	9.063	4.535	0.156	1.463	3.961
15.10	20.021	8.996	3.084	0.063	1.863	3.990
16.10	19.701	9.147	3.135	0.044	2.000	4.151
17.10	20.294	9.044	3.364	0.046	2.289	4.088
18.10	20.649	9.044	3.547	0.043	2.789	3.757
19.10	20.937	9.129	4.940	0.202	2.633	3.883
20.10	20.380	9.114	4.140	0.333	2.958	3.105
21.10	19.277	9.071	3.099	0.388	1.641	2.577
22.10	18.179	9.123	2.485	0.148	1.204	1.787
23.10	9.899	9.477	4.864	0.261	0.659	0.225
24.10	8.171	9.478	5.996	0.336	0.525	0.243
25.10	9.220	9.424	5.172	0.396	0.542	0.250
26.10	8.016	9.414	5.019	0.512	0.519	0.264
27.10	8.193	9.298	6.575	0.825	0.507	0.240
28.10	7.837	9.352	3.068	0.159	0.511	0.321
29.10	8.250	9.331	3.804	0.279	0.524	0.272
30.10	8.154	9.427	4.431	0.265	0.537	0.230
31.10	10.022	9.442	3.059	0.325	0.628	0.191
min	7.837	8.935	1.761	0.043	0.507	0.191
max	20.937	9.478	11.641	1.317	2.958	5.067
MMV	16.182	9.160	3.924	0.409	1.455	2.904
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 10.2018



	UAB Fortum Klaipeda sugeneruota: 1.11.2018					
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.10	0.060	0.000	126.896	0.387	0.707	186881.54
2.10	0.061	0.000	127.080	0.330	0.781	185061.95
3.10	0.062	0.000	127.117	0.375	1.115	160067.60
4.10	0.062	0.000	127.505	0.392	0.935	160620.43
5.10	0.069	0.000	127.035	0.384	1.074	157774.09
6.10	0.066	0.000	127.083	0.460	0.630	180965.07
7.10	0.062	0.000	126.951	0.515	0.890	189181.93
8.10	0.059	0.000	126.864	0.444	0.690	185354.54
9.10	0.061	0.000	126.564	0.332	0.674	181347.04
10.10	0.065	0.000	126.631	0.476	0.695	178978.25
11.10	0.061	0.000	126.803	0.353	0.770	171551.34
12.10	0.064	0.000	126.805	0.398	0.789	169700.54
13.10	0.063	0.000	127.195	0.401	0.788	174252.53
14.10	0.068	0.000	126.979	0.464	0.808	172122.35
15.10	0.062	0.000	127.318	0.525	0.739	172193.85
16.10	0.062	0.000	126.888	0.479	0.764	178316.64
17.10	0.062	0.000	126.952	0.481	0.827	179221.85
18.10	0.060	0.001	126.793	0.450	0.726	178205.25
19.10	0.056	0.000	126.746	0.431	0.787	184304.43
20.10	0.055	0.000	127.155	0.322	0.733	190878.62
21.10	0.057	0.001	126.024	0.328	0.788	183976.60
22.10	0.056	0.000	127.517	0.365	0.570	178573.23
23.10	0.052	0.000	126.884	0.254	0.491	176495.06
24.10	0.051	0.000	126.834	0.211	0.512	175707.43
25.10	0.051	0.001	127.028	0.195	0.528	177053.10
26.10	0.050	0.000	126.760	0.153	0.532	176616.81
27.10	0.051	0.000	127.100	0.156	0.535	179560.89
28.10	0.050	0.000	127.210	0.180	0.507	177644.37
29.10	0.049	0.000	127.078	0.196	0.693	178969.82
30.10	0.051	0.000	126.795	0.180	0.475	177999.43
31.10	0.053	0.000	127.401	0.223	0.552	178537.20
min	0.049	0.000	126.024	0.153	0.475	157774.09
max	0.069	0.001	127.517	0.525	1.115	190878.62
MMV	0.058	0.000	126.968	0.349	0.713	177358.81
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 10.2018



	UAB Fortum Klaipeda			sugeneruota: 1.11.2018		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.10	139.697	1018.329	7.050	1008.060	1084.480	2.948
2.10	136.914	1012.792	7.202	1003.822	1080.688	2.449
3.10	137.647	1004.949	7.093	996.017	1039.370	3.268
4.10	136.985	1023.992	7.998	1014.539	1058.893	1.959
5.10	135.524	1027.438	8.679	1016.769	1034.530	4.419
6.10	141.862	1022.224	7.212	1011.248	1066.065	3.618
7.10	143.351	1015.524	6.825	1007.067	1086.179	3.230
8.10	142.185	1030.547	6.830	1020.573	1085.196	2.379
9.10	137.945	1030.767	7.162	1019.828	1081.018	2.540
10.10	138.973	1032.981	7.247	1022.803	1039.068	5.225
11.10	139.975	1036.555	7.209	1026.614	1064.074	4.253
12.10	140.231	1036.564	7.261	1025.773	1043.737	12.778
13.10	141.470	1036.175	7.123	1025.838	1073.754	3.662
14.10	142.013	1033.049	7.024	1023.041	1050.884	5.035
15.10	143.409	1029.322	6.959	1019.632	1052.489	3.436
16.10	143.288	1028.892	7.299	1018.862	1060.033	3.547
17.10	144.199	1029.806	6.994	1019.542	1059.242	3.755
18.10	143.660	1026.945	6.700	1017.077	1060.386	3.936
19.10	144.373	1028.492	6.120	1019.932	1070.082	5.471
20.10	144.459	1030.475	6.232	1020.787	1076.998	4.617
21.10	143.702	1033.393	6.303	1023.221	1103.670	3.462
22.10	111.554	1026.786	6.635	1016.779	1102.267	2.756
23.10	45.197	1005.987	7.407	996.227	1059.920	5.425
24.10	42.114	1001.455	7.433	992.156	1052.577	6.701
25.10	43.878	1006.944	7.266	996.705	1065.911	5.715
26.10	41.924	1011.234	7.253	1000.437	1051.718	5.576
27.10	42.027	1004.945	6.905	994.498	1039.592	7.311
28.10	41.609	1023.203	7.111	1013.941	1077.250	3.405
29.10	42.627	1026.627	7.106	1018.000	1063.867	4.228
30.10	42.258	1020.992	7.321	1008.642	1088.536	4.933
31.10	45.380	1028.072	7.242	1016.294	1109.919	3.376
min	41.609	1001.455	6.120	992.156	1034.530	1.959
max	144.459	1036.564	8.679	1026.614	1109.919	12.778
MMV	111.533	1023.402	7.101	1013.379	1067.187	4.362
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 10.2018



UAB Fortum Klaipeda		sugeneruota: 1.11.2018				
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.10	1.439	6.730	0.100	158.621	0.552	1.009
2.10	1.646	7.398	0.102	158.851	0.471	1.116
3.10	1.638	8.445	0.103	158.896	0.536	1.592
4.10	1.066	7.818	0.103	159.382	0.560	1.335
5.10	0.628	8.395	0.116	158.793	0.548	1.535
6.10	1.457	8.057	0.110	158.853	0.657	0.900
7.10	0.247	7.113	0.103	158.689	0.735	1.272
8.10	0.267	6.525	0.098	158.580	0.635	0.986
9.10	0.575	6.203	0.102	158.205	0.474	0.962
10.10	0.354	7.140	0.108	158.289	0.681	0.993
11.10	0.225	6.959	0.101	158.503	0.504	1.100
12.10	0.214	6.791	0.106	158.506	0.568	1.128
13.10	0.206	7.168	0.104	158.993	0.573	1.125
14.10	0.195	6.601	0.113	158.724	0.663	1.154
15.10	0.079	6.650	0.104	159.147	0.750	1.056
16.10	0.055	6.919	0.103	158.610	0.684	1.092
17.10	0.057	6.813	0.103	158.690	0.687	1.182
18.10	0.054	6.262	0.101	158.491	0.643	1.038
19.10	0.253	6.472	0.093	158.432	0.616	1.125
20.10	0.417	5.175	0.092	158.944	0.460	1.048
21.10	0.484	4.295	0.095	157.530	0.468	1.126
22.10	0.185	2.979	0.094	159.396	0.522	0.814
23.10	0.327	0.375	0.087	158.606	0.362	0.701
24.10	0.420	0.406	0.085	158.542	0.302	0.732
25.10	0.494	0.417	0.086	158.785	0.279	0.754
26.10	0.640	0.441	0.084	158.450	0.219	0.760
27.10	1.031	0.399	0.085	158.875	0.223	0.764
28.10	0.198	0.534	0.083	159.012	0.257	0.724
29.10	0.349	0.453	0.082	158.847	0.280	0.989
30.10	0.331	0.383	0.085	158.494	0.257	0.679
31.10	0.407	0.318	0.089	159.251	0.318	0.789
min	0.054	0.318	0.082	157.530	0.219	0.679
max	1.646	8.445	0.116	159.396	0.750	1.592
MMV	0.512	4.840	0.097	158.710	0.499	1.018
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						