

# Menesine ataskaita: 10.2019



UAB Fortum Klaipeda		sugeneruota: 1.11.2019				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.10	20.373	7.740	4.288	1.017	0.741	0.356
2.10	20.656	7.822	5.189	1.541	0.690	0.358
3.10	20.250	7.736	4.735	2.422	0.770	0.385
4.10	20.975	7.808	4.574	3.637	0.721	0.371
5.10	20.870	7.790	2.650	2.465	0.688	0.219
6.10	22.355	7.750	5.211	0.636	0.722	0.316
7.10	15.815	7.932	4.212	1.536	0.618	0.289
8.10	9.050	8.133	4.945	1.216	0.479	0.266
9.10	7.917	8.140	8.808	0.983	0.463	0.266
10.10	8.506	8.162	4.761	1.819	0.462	0.284
11.10	7.939	8.165	5.564	1.461	0.468	0.288
12.10	8.795	8.192	5.873	2.217	0.477	0.269
13.10	10.908	8.123	5.444	2.641	0.541	0.337
14.10	15.903	7.963	5.781	7.556	0.885	0.376
15.10	11.034	8.168	5.815	2.595	0.816	0.285
16.10	18.095	7.975	6.458	1.433	1.542	2.528
17.10	13.586	8.145	6.942	0.272	0.566	0.329
18.10	12.676	8.173	8.629	0.211	0.582	0.302
19.10	14.726	8.125	4.641	0.008	0.538	0.294
20.10	17.358	8.020	5.822	0.160	0.607	0.297
21.10	13.162	8.094	5.770	0.492	0.656	0.302
22.10	15.336	8.017	7.242	0.183	0.896	0.294
23.10	10.323	8.087	5.731	0.010	0.635	0.271
24.10	9.201	8.139	4.587	0.005	0.552	0.203
25.10	9.333	8.198	3.940	0.002	0.546	0.191
26.10	11.889	8.130	3.955	0.000	0.580	0.290
27.10	11.286	8.116	3.186	0.031	0.583	0.261
28.10	8.529	8.105	5.002	0.146	0.510	0.218
29.10	8.188	7.843	15.411	0.032	0.423	0.112
30.10	7.150	6.341	0.550	0.000	0.458	0.001
31.10	8.538	7.613	5.234	0.000	0.581	0.005
min	7.150	6.341	0.550	0.000	0.423	0.001
max	22.355	8.198	15.411	7.556	1.542	2.528
MMV	13.248	8.001	5.620	1.217	0.643	0.351
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						

# Menesine ataskaita: 10.2019



UAB Fortum Klaipeda		sugeneruota: 1.11.2019				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.10	0.093	0.519	127.195	1.003	0.381	208828.17
2.10	0.093	0.517	128.054	0.903	0.581	211461.42
3.10	0.086	0.505	127.131	0.902	0.693	209358.51
4.10	0.085	0.529	127.739	0.884	0.868	211817.35
5.10	0.084	0.364	127.560	0.602	0.593	210368.04
6.10	0.081	0.299	127.592	0.624	0.569	214849.43
7.10	0.074	0.353	131.163	0.548	0.520	197585.32
8.10	0.081	0.337	127.553	0.440	0.386	198525.45
9.10	0.082	0.435	127.266	0.593	0.384	213589.87
10.10	0.081	0.443	127.380	0.593	0.449	217651.98
11.10	0.082	0.450	127.641	0.594	0.559	208536.60
12.10	0.086	0.482	127.915	0.629	0.508	216827.35
13.10	0.097	0.469	127.417	0.592	0.325	218875.67
14.10	0.095	0.473	127.456	0.824	0.531	223442.12
15.10	0.091	0.429	129.404	0.591	0.457	204148.92
16.10	0.091	0.423	127.520	0.801	0.530	221876.17
17.10	0.085	0.474	127.489	0.750	0.419	217662.95
18.10	0.090	0.470	127.612	0.752	0.379	216729.57
19.10	0.098	0.434	127.338	0.739	0.443	220573.10
20.10	0.089	0.462	127.595	0.859	0.471	228381.39
21.10	0.088	0.515	127.718	0.839	0.417	207232.10
22.10	0.103	0.427	127.820	0.729	0.449	223110.01
23.10	0.096	0.438	127.378	0.569	0.397	212590.93
24.10	0.082	0.427	127.307	0.527	0.439	210075.12
25.10	0.085	0.443	127.229	0.558	0.404	210695.25
26.10	0.105	0.436	127.562	0.568	X	216059.20
27.10	0.095	0.443	127.894	0.657	X	216910.95
28.10	0.083	0.392	126.911	0.509	X	215832.57
29.10	0.063	0.346	126.717	0.217	0.410	209154.29
30.10	0.068	0.447	122.900	0.002	0.297	86204.031
31.10	0.050	0.314	130.435	0.000	0.179	190136.98
min	0.050	0.299	122.900	0.000	0.179	86204.031
max	0.105	0.529	131.163	1.003	0.868	228381.39
MMV	0.087	0.436	127.699	0.644	0.471	208691.59
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data						

# Menesine ataskaita: 10.2019



	UAB Fortum Klaipeda			sugeneruota: 1.11.2019		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.10	60.262	1007.367	5.940	995.251	1069.981	4.763
2.10	60.596	1010.260	5.689	997.461	1078.356	5.794
3.10	60.288	1017.114	5.980	1004.336	1053.579	5.282
4.10	61.091	1019.453	5.560	1007.107	1080.078	5.100
5.10	61.067	1024.954	5.637	1014.185	1098.973	2.971
6.10	62.562	1029.865	5.497	1018.159	1030.349	5.784
7.10	53.303	1026.708	5.826	1014.222	1048.158	4.950
8.10	44.120	1019.435	6.510	1006.045	1078.184	5.478
9.10	41.731	1015.202	6.047	1000.607	1074.310	9.859
10.10	42.997	1014.658	5.944	1001.013	1070.656	5.301
11.10	41.824	1018.543	6.150	1005.042	1049.576	6.191
12.10	43.602	1015.547	6.361	1001.831	1036.944	6.517
13.10	47.430	1024.313	6.325	1010.257	1039.142	6.031
14.10	54.624	1022.583	5.564	1009.080	1076.941	6.462
15.10	47.723	1026.774	6.282	1013.139	1047.699	6.964
16.10	88.639	1018.650	5.285	1004.746	1069.076	7.206
17.10	51.163	1020.371	5.692	1007.868	1064.303	7.771
18.10	50.267	1024.808	5.950	1011.042	1052.378	9.216
19.10	53.675	1023.680	5.685	1010.153	1099.277	5.100
20.10	56.955	1025.947	5.689	1011.861	1027.184	6.447
21.10	50.380	1029.963	6.428	1016.506	1028.315	6.383
22.10	54.359	1031.305	6.066	1017.864	1036.025	8.032
23.10	46.559	1031.706	6.255	1018.284	1057.784	6.382
24.10	44.536	1029.290	6.240	1015.463	1063.212	5.123
25.10	44.805	1025.704	6.167	1012.014	1099.800	4.379
26.10	49.488	1024.876	5.842	1011.124	1058.922	4.385
27.10	47.838	1017.014	5.865	1004.284	1074.220	3.540
28.10	43.000	1021.927	6.027	1009.664	1050.654	5.589
29.10	42.313	1028.847	6.525	1017.013	1018.997	16.537
30.10	40.236	1035.804	13.658	1024.044	917.939	1.725
31.10	42.937	1033.528	7.444	1019.834	1033.516	5.884
min	40.236	1007.367	5.285	995.251	917.939	1.725
max	88.639	1035.804	13.658	1024.044	1099.800	16.537
MMV	51.298	1023.094	6.262	1009.977	1057.595	6.262
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						

# Menesine ataskaita: 10.2019



UAB Fortum Klaipeda		sugeneruota: 1.11.2019				
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.10	1.271	0.594	0.155	158.994	1.433	0.544
2.10	1.927	0.597	0.155	160.067	1.290	0.831
3.10	3.028	0.642	0.143	158.914	1.288	0.990
4.10	4.546	0.618	0.142	159.674	1.262	1.240
5.10	3.081	0.366	0.140	159.450	0.859	0.847
6.10	0.795	0.527	0.135	159.489	0.892	0.812
7.10	1.920	0.481	0.124	163.954	0.782	0.743
8.10	1.520	0.444	0.135	159.442	0.629	0.551
9.10	1.228	0.443	0.137	159.083	0.848	0.549
10.10	2.273	0.473	0.135	159.225	0.848	0.641
11.10	1.826	0.481	0.137	159.552	0.848	0.798
12.10	2.772	0.449	0.143	159.894	0.898	0.726
13.10	3.302	0.562	0.162	159.271	0.846	0.464
14.10	9.445	0.626	0.159	159.320	1.177	0.759
15.10	3.243	0.475	0.151	161.755	0.845	0.653
16.10	1.791	4.213	0.152	159.399	1.144	0.757
17.10	0.340	0.549	0.141	159.361	1.071	0.598
18.10	0.264	0.504	0.151	159.515	1.074	0.542
19.10	0.010	0.490	0.163	159.172	1.055	0.633
20.10	0.200	0.495	0.149	159.494	1.226	0.672
21.10	0.615	0.503	0.146	159.647	1.198	0.595
22.10	0.228	0.489	0.172	159.776	1.042	0.642
23.10	0.013	0.451	0.160	159.222	0.813	0.567
24.10	0.006	0.338	0.136	159.134	0.754	0.627
25.10	0.002	0.318	0.141	159.036	0.798	0.578
26.10	0.000	0.483	0.174	159.452	0.811	X
27.10	0.039	0.435	0.158	159.867	0.938	X
28.10	0.182	0.364	0.139	158.638	0.727	X
29.10	0.041	0.194	0.106	158.454	0.316	0.589
30.10	0.000	0.002	0.114	153.625	0.003	0.424
31.10	0.000	0.008	0.084	163.044	0.000	0.256
min	0.000	0.002	0.084	153.625	0.000	0.256
max	9.445	4.213	0.174	163.954	1.433	1.240
MMV	1.521	0.585	0.144	159.625	0.920	0.673
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						