

Menesine ataskaita: 10.2020



	UAB Fortum Klaipeda						sugeneruota: 1.11.2020
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.10	18.419	7.484	4.400	0.103	1.248	4.560	
2.10	19.127	7.474	3.877	0.000	1.145	4.577	
3.10	18.715	7.479	7.627	0.000	1.119	4.825	
4.10	20.260	7.437	4.308	0.115	1.653	4.773	
5.10	18.982	7.477	5.734	0.039	1.408	4.495	
6.10	17.208	7.483	6.686	0.000	0.902	4.720	
7.10	16.637	7.364	6.790	0.000	0.878	4.056	
8.10	18.030	7.423	4.041	0.000	1.095	4.005	
9.10	17.695	7.398	4.073	0.000	0.896	3.712	
10.10	18.952	7.411	4.645	0.000	0.927	3.756	
11.10	18.790	7.425	4.384	0.000	1.047	3.587	
12.10	18.478	7.396	3.418	0.000	0.819	3.671	
13.10	17.246	7.421	3.159	0.000	0.721	1.400	
14.10	18.703	7.372	6.895	0.000	0.860	0.572	
15.10	19.053	7.431	7.602	0.000	1.674	0.097	
16.10	15.754	7.559	4.986	0.000	0.968	0.018	
17.10	16.166	7.617	4.964	0.000	1.106	0.047	
18.10	18.889	7.414	4.925	0.000	1.341	0.018	
19.10	18.502	7.434	5.224	0.000	1.464	0.029	
20.10	16.264	7.523	7.599	0.000	0.706	0.024	
21.10	15.809	7.533	8.228	0.000	0.632	0.033	
22.10	18.012	7.556	6.598	0.000	0.373	0.073	
23.10	16.775	7.657	4.970	0.000	0.269	0.057	
24.10	17.205	7.599	7.496	0.000	0.249	0.041	
25.10	17.936	7.553	8.562	0.000	0.253	0.034	
26.10	16.177	7.571	5.609	0.000	0.249	0.101	
27.10	14.935	7.530	4.124	0.000	0.262	0.079	
28.10	17.320	7.462	4.152	0.000	0.355	0.070	
29.10	20.134	7.445	4.522	0.023	0.525	0.131	
30.10	19.467	7.462	5.431	0.406	0.932	0.147	
31.10	18.123	7.544	5.995	0.381	1.164	0.031	
min	14.935	7.364	3.159	0.000	0.249	0.018	
max	20.260	7.657	8.562	0.406	1.674	4.825	
MMV	17.866	7.482	5.522	0.034	0.878	1.735	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 10.2020



UAB Fortum Klaipeda		sugeneruota: 1.11.2020				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.10	0.027	0.000	131.831	0.076	0.226	220100.98
2.10	0.028	0.000	131.803	0.083	0.357	222377.81
3.10	0.029	0.000	131.257	0.058	0.312	220596.67
4.10	0.035	0.000	132.031	0.153	0.291	224864.62
5.10	0.027	0.000	131.318	0.120	0.285	221544.29
6.10	0.023	0.000	131.771	0.048	0.373	216817.89
7.10	0.025	0.008	131.464	0.072	0.270	215750.64
8.10	0.026	0.000	131.770	0.088	0.245	219893.37
9.10	0.025	0.000	132.022	0.158	0.221	218907.23
10.10	0.026	0.000	132.040	0.180	0.358	222645.42
11.10	0.028	0.000	131.590	0.130	0.198	221625.32
12.10	0.027	0.000	131.732	0.106	0.375	221158.29
13.10	0.025	0.000	131.668	0.090	0.167	216528.67
14.10	0.029	0.001	131.333	0.143	0.245	219938.07
15.10	0.027	0.003	132.216	0.221	0.234	222569.26
16.10	0.022	0.000	132.093	0.147	0.190	216849.04
17.10	0.021	0.000	131.705	0.091	0.211	219408.68
18.10	0.025	0.002	130.129	0.165	0.291	223055.14
19.10	0.026	0.000	131.246	0.138	0.222	221022.64
20.10	0.024	0.000	131.516	0.068	0.230	215919.60
21.10	0.025	0.000	130.667	0.129	0.271	215511.87
22.10	0.028	0.000	131.853	0.185	0.221	221419.06
23.10	0.026	0.000	131.537	0.123	0.209	217829.07
24.10	0.027	0.000	131.528	0.150	0.207	219182.79
25.10	0.029	0.000	131.742	0.088	0.242	221973.65
26.10	0.025	0.000	131.457	0.075	0.283	216497.95
27.10	0.024	0.001	131.746	0.057	0.180	211927.45
28.10	0.027	0.000	130.794	0.087	0.247	218853.12
29.10	0.038	0.000	131.466	0.163	0.221	224587.37
30.10	0.035	0.000	131.638	0.110	0.234	221530.17
31.10	0.030	0.000	131.362	0.130	0.237	219115.37
min	0.021	0.000	130.129	0.048	0.167	211927.45
max	0.038	0.008	132.216	0.221	0.375	224864.62
MMV	0.027	0.000	131.559	0.117	0.253	219680.53
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 10.2020



	UAB Fortum Klaipeda			sugeneruota: 1.11.2020		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.10	138.376	1024.306	5.982	1009.688	1069.504	4.891
2.10	139.370	1025.028	5.906	1010.353	1090.767	4.290
3.10	138.412	1022.766	6.006	1008.248	1009.129	8.455
4.10	141.718	1016.680	5.591	1001.066	1023.165	4.773
5.10	139.315	1022.877	5.910	1008.147	1017.714	6.317
6.10	135.408	1017.167	6.261	1002.420	1012.915	7.471
7.10	134.608	1021.211	6.403	1006.317	1028.317	7.584
8.10	137.467	1027.230	6.090	1012.819	1048.815	4.504
9.10	136.711	1026.162	6.177	1012.015	1060.666	4.470
10.10	139.149	1029.087	5.859	1014.294	1019.307	5.189
11.10	138.887	1029.596	5.906	1014.721	1004.287	4.890
12.10	138.368	1028.251	5.980	1014.144	1008.231	3.813
13.10	95.270	1027.590	6.302	1013.424	1005.571	3.520
14.10	75.173	1022.007	6.129	1008.504	1006.535	7.697
15.10	59.337	1025.627	5.890	1011.029	970.222	8.481
16.10	55.253	1031.378	6.185	1016.829	988.267	5.539
17.10	56.033	1030.730	6.037	1016.023	1005.153	5.516
18.10	59.142	1019.219	5.811	1003.842	995.168	5.495
19.10	58.767	1026.469	6.001	1011.030	990.149	5.795
20.10	56.082	1033.371	6.471	1017.618	1001.334	8.495
21.10	55.369	1024.289	6.488	1008.789	1026.752	9.161
22.10	57.985	1019.784	5.940	1003.919	1035.220	7.306
23.10	56.625	1021.088	6.293	1005.611	1050.731	5.515
24.10	57.184	1022.218	6.044	1006.778	1015.929	8.374
25.10	58.063	1025.665	5.910	1010.098	1001.662	9.498
26.10	55.798	1021.915	6.158	1006.695	1026.246	6.230
27.10	54.256	1021.929	6.424	1006.409	1033.425	4.645
28.10	57.297	1024.455	6.188	1009.489	1029.442	4.618
29.10	60.458	1023.630	5.768	1008.154	1003.561	5.021
30.10	59.379	1024.085	5.941	1010.039	1043.298	6.036
31.10	58.525	1035.695	6.010	1020.692	1039.602	6.651
min	54.256	1016.680	5.591	1001.066	970.222	3.520
max	141.718	1035.695	6.488	1020.692	1090.767	9.498
MMV	90.401	1024.887	6.066	1009.975	1021.299	6.141
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 10.2020



	UAB Fortum Klaipeda						sugeneruota: 1.11.2020
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.10	0.128	7.600	0.045	164.788	0.109	0.323	
2.10	0.000	7.629	0.047	164.754	0.119	0.510	
3.10	0.000	8.042	0.048	164.071	0.083	0.446	
4.10	0.144	7.956	0.058	165.038	0.218	0.415	
5.10	0.049	7.491	0.045	164.147	0.171	0.406	
6.10	0.000	7.866	0.038	164.714	0.069	0.533	
7.10	0.000	6.761	0.041	164.329	0.102	0.385	
8.10	0.000	6.675	0.043	164.712	0.125	0.351	
9.10	0.000	6.187	0.042	165.028	0.225	0.316	
10.10	0.000	6.259	0.044	165.049	0.258	0.511	
11.10	0.000	5.978	0.047	164.487	0.186	0.283	
12.10	0.000	6.119	0.046	164.665	0.152	0.535	
13.10	0.000	2.333	0.042	164.585	0.129	0.238	
14.10	0.000	0.954	0.048	164.166	0.204	0.351	
15.10	0.000	0.162	0.045	165.270	0.315	0.334	
16.10	0.000	0.030	0.037	165.116	0.210	0.272	
17.10	0.000	0.078	0.035	164.631	0.130	0.302	
18.10	0.000	0.030	0.042	162.662	0.235	0.416	
19.10	0.000	0.048	0.043	164.058	0.197	0.317	
20.10	0.000	0.040	0.040	164.395	0.097	0.329	
21.10	0.000	0.056	0.042	163.334	0.184	0.388	
22.10	0.000	0.121	0.047	164.816	0.264	0.315	
23.10	0.000	0.095	0.043	164.421	0.176	0.298	
24.10	0.000	0.068	0.046	164.410	0.215	0.295	
25.10	0.000	0.056	0.048	164.678	0.126	0.345	
26.10	0.000	0.168	0.042	164.322	0.107	0.405	
27.10	0.000	0.131	0.040	164.683	0.081	0.258	
28.10	0.000	0.117	0.045	163.492	0.124	0.353	
29.10	0.029	0.218	0.063	164.333	0.232	0.316	
30.10	0.508	0.245	0.059	164.548	0.157	0.335	
31.10	0.476	0.052	0.050	164.203	0.186	0.338	
min	0.000	0.030	0.035	162.662	0.069	0.238	
max	0.508	8.042	0.063	165.270	0.315	0.535	
MMV	0.043	2.891	0.045	164.449	0.167	0.362	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							