

# Menesine ataskaita: 10.2022



	UAB Fortum Klaipeda						sugeneruota: 1.11.2022
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.10	17.670	7.395	6.005	0.001	0.302	4.581	
2.10	18.440	7.360	6.914	0.001	0.415	4.737	
3.10	17.933	7.369	4.279	0.002	0.351	4.479	
4.10	16.312	7.426	4.426	10.870	0.325	2.487	
5.10	16.610	7.377	4.283	0.000	0.144	0.120	
6.10	16.440	7.399	6.187	0.000	0.155	0.122	
7.10	16.656	7.356	8.285	0.000	0.163	0.098	
8.10	17.141	7.308	6.599	0.014	0.140	0.074	
9.10	16.877	7.319	4.120	0.011	0.132	0.037	
10.10	17.754	7.345	4.575	0.011	0.132	0.050	
11.10	15.694	7.397	4.022	0.008	0.148	0.086	
12.10	15.541	7.384	2.648	0.008	0.145	0.112	
13.10	16.266	7.393	2.421	0.008	0.147	0.056	
14.10	16.674	7.393	8.067	0.038	0.136	0.061	
15.10	17.433	7.289	6.273	0.133	0.128	0.051	
16.10	17.042	7.310	6.132	0.007	0.134	0.140	
17.10	16.437	7.345	8.675	0.059	0.142	0.118	
18.10	17.307	7.327	9.338	0.004	0.129	0.029	
19.10	17.560	7.291	4.834	0.004	0.140	0.046	
20.10	16.171	7.370	3.152	0.003	0.155	0.807	
21.10	18.108	7.351	3.816	0.006	0.173	5.184	
22.10	18.742	7.287	4.052	0.007	0.321	3.224	
23.10	18.639	7.320	3.394	0.006	0.134	0.069	
24.10	17.696	7.364	3.495	0.004	0.130	0.054	
25.10	16.702	7.421	5.264	0.003	0.137	0.060	
26.10	12.366	7.538	5.835	0.002	0.145	0.053	
27.10	10.723	7.594	3.380	0.000	0.133	0.023	
28.10	11.796	7.612	3.394	0.000	0.134	0.039	
29.10	14.183	7.498	3.489	0.000	0.133	0.079	
30.10	11.310	7.600	3.258	0.000	0.143	0.053	
31.10	8.347	7.671	2.332	0.000	0.135	0.007	
min	8.347	7.287	2.332	0.000	0.128	0.007	
max	18.742	7.671	9.338	10.870	0.415	5.184	
MMV	16.011	7.401	4.939	0.363	0.174	0.866	
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down							

# Menesine ataskaita: 10.2022



	UAB Fortum Klaipeda						sugeneruota: 1.11.2022
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.10	0.032	0.028	143.877	0.050	0.464	220287.81	
2.10	0.035	0.052	143.601	0.059	0.174	221062.51	
3.10	0.034	0.056	143.651	0.044	0.263	219371.68	
4.10	0.034	0.026	143.621	0.025	0.238	212097.68	
5.10	0.035	0.025	143.828	0.052	0.324	206570.32	
6.10	0.029	0.010	143.566	0.020	0.318	207718.95	
7.10	0.029	0.025	143.841	0.012	0.322	212154.01	
8.10	0.034	0.042	143.512	0.042	0.306	214292.82	
9.10	0.034	0.064	143.710	0.067	0.366	212506.10	
10.10	0.026	0.028	143.457	0.024	0.377	217363.04	
11.10	0.026	0.001	143.874	0.000	0.311	210484.50	
12.10	0.024	0.001	143.863	0.000	0.370	209067.37	
13.10	0.026	0.010	143.708	0.000	0.426	209512.18	
14.10	0.027	0.004	143.826	0.001	0.438	215246.85	
15.10	0.028	0.009	143.968	0.003	0.465	219846.89	
16.10	0.034	0.037	143.544	0.021	0.452	215338.73	
17.10	0.039	0.047	143.969	0.020	0.470	214375.87	
18.10	0.040	0.063	143.646	0.098	0.511	216821.67	
19.10	0.033	0.044	143.906	0.069	0.455	224104.95	
20.10	0.026	0.020	145.229	0.001	0.300	211139.23	
21.10	0.027	0.001	145.485	0.000	0.206	223457.76	
22.10	0.026	0.022	145.027	0.006	0.236	229684.82	
23.10	0.032	0.073	143.910	0.055	0.327	221426.23	
24.10	0.036	0.062	143.772	0.060	0.287	216591.57	
25.10	0.036	0.033	143.510	0.049	0.301	211790.60	
26.10	0.029	0.023	143.907	0.013	0.252	209809.42	
27.10	0.026	0.024	143.980	0.009	0.234	214457.32	
28.10	0.030	0.027	143.640	0.001	0.256	216769.23	
29.10	0.032	0.059	143.844	0.019	0.253	223602.51	
30.10	0.026	0.023	143.731	0.000	0.229	215286.51	
31.10	0.023	0.006	143.310	0.000	0.254	211703.89	
min	0.023	0.001	143.310	0.000	0.174	206570.32	
max	0.040	0.073	145.485	0.098	0.511	229684.82	
MMV	0.030	0.031	143.875	0.027	0.328	215610.56	
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down							

# Menesine ataskaita: 10.2022



	UAB Fortum Klaipeda			sugeneruota: 1.11.2022		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.10	135.335	1026.308	6.306	1008.241	1041.420	6.691
2.10	136.759	1018.966	6.167	1002.144	1029.020	7.692
3.10	135.924	1021.749	6.264	1004.949	1045.021	4.757
4.10	116.572	1027.563	6.569	1009.427	1029.241	4.931
5.10	56.615	1031.818	6.565	1012.860	1046.083	4.766
6.10	56.431	1033.151	6.511	1014.595	1062.276	6.902
7.10	56.838	1039.609	6.480	1021.151	1016.111	9.215
8.10	57.286	1030.015	6.169	1011.775	1047.125	7.343
9.10	57.058	1035.871	6.260	1017.669	1063.102	4.567
10.10	58.093	1039.253	6.111	1020.989	1062.843	5.106
11.10	55.457	1032.565	6.449	1014.552	1031.839	4.475
12.10	55.387	1039.261	6.452	1020.620	1049.018	2.948
13.10	56.285	1039.615	6.379	1020.873	1064.903	2.691
14.10	56.675	1032.912	6.223	1014.875	1024.858	8.974
15.10	57.565	1029.188	6.115	1010.782	1051.147	7.001
16.10	57.149	1031.837	6.394	1012.708	1063.453	6.842
17.10	56.497	1039.609	6.483	1020.869	1047.466	9.684
18.10	57.526	1034.561	6.113	1016.208	1034.477	10.429
19.10	57.759	1033.600	6.308	1016.948	1038.324	5.396
20.10	67.834	1040.832	6.442	1022.476	1047.219	X
21.10	135.250	1034.898	6.320	1017.186	1049.977	4.255
22.10	107.676	1027.929	6.404	1009.919	1019.324	4.503
23.10	58.943	1029.876	6.410	1011.013	1021.843	3.752
24.10	57.872	1029.848	6.297	1011.210	1042.435	3.891
25.10	56.631	1027.543	6.337	1008.599	1030.829	5.862
26.10	49.786	1031.822	6.452	1013.419	1045.331	6.506
27.10	47.014	1039.223	6.595	1020.400	1075.322	3.760
28.10	49.221	1037.181	6.539	1018.090	1101.572	3.761
29.10	52.959	1029.733	6.123	1011.074	1095.105	3.882
30.10	48.475	1032.906	6.442	1014.388	1085.253	3.619
31.10	43.035	1036.578	6.745	1018.301	1105.158	2.595
min	43.035	1018.966	6.111	1002.144	1016.111	2.595
max	136.759	1040.832	6.745	1022.476	1105.158	10.429
MMV	69.388	1032.768	6.368	1014.462	1050.598	5.500
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						

# Menesine ataskaita: 10.2022



	UAB Fortum Klaipeda						sugeneruota: 1.11.2022
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.10	0.001	7.635	0.053	179.847	0.071	0.663	
2.10	0.001	7.895	0.058	179.501	0.084	0.249	
3.10	0.002	7.466	0.056	179.564	0.063	0.375	
4.10	13.587	4.144	0.057	179.526	0.036	0.339	
5.10	0.000	0.200	0.059	179.785	0.075	0.463	
6.10	0.000	0.203	0.048	179.457	0.028	0.454	
7.10	0.000	0.163	0.048	179.801	0.018	0.460	
8.10	0.017	0.123	0.057	179.390	0.060	0.437	
9.10	0.014	0.062	0.056	179.637	0.095	0.522	
10.10	0.014	0.083	0.043	179.322	0.034	0.539	
11.10	0.009	0.143	0.043	179.843	0.001	0.444	
12.10	0.010	0.186	0.040	179.829	0.000	0.529	
13.10	0.010	0.093	0.043	179.635	0.001	0.609	
14.10	0.048	0.102	0.045	179.783	0.001	0.626	
15.10	0.167	0.084	0.046	179.960	0.005	0.664	
16.10	0.009	0.233	0.056	179.429	0.030	0.646	
17.10	0.073	0.197	0.066	179.962	0.028	0.671	
18.10	0.006	0.048	0.067	179.557	0.140	0.730	
19.10	0.004	0.077	0.054	179.882	0.099	0.650	
20.10	0.004	1.344	0.043	181.536	0.001	0.429	
21.10	0.008	8.753	0.044	181.856	0.000	0.294	
22.10	0.009	5.374	0.043	181.283	0.009	0.338	
23.10	0.008	0.115	0.053	179.887	0.078	0.467	
24.10	0.005	0.090	0.059	179.715	0.086	0.409	
25.10	0.004	0.100	0.060	179.388	0.070	0.430	
26.10	0.002	0.089	0.049	179.883	0.018	0.360	
27.10	0.000	0.038	0.043	179.975	0.013	0.335	
28.10	0.000	0.065	0.050	179.550	0.001	0.366	
29.10	0.000	0.132	0.054	179.805	0.027	0.361	
30.10	0.000	0.089	0.043	179.664	0.000	0.328	
31.10	0.000	0.012	0.038	179.138	0.000	0.363	
min	0.000	0.012	0.038	179.138	0.000	0.249	
max	13.587	8.753	0.067	181.856	0.140	0.730	
MMV	0.453	1.461	0.051	179.844	0.038	0.469	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							