

Menesine ataskaita: 11.2015



	UAB Fortum Klaipeda						sugeneruota: 1.12.2015
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	14.230	10.427	6.478	0.067	0.574	0.314	
2.11	17.247	10.228	6.852	0.022	0.675	0.321	
3.11	15.358	10.559	11.363	0.024	0.608	0.316	
4.11	14.204	10.792	6.853	0.014	0.551	0.305	
5.11	16.594	10.632	6.420	0.017	0.565	0.316	
6.11	12.247	10.838	6.993	0.405	0.521	0.305	
7.11	9.209	10.860	6.750	0.140	0.509	0.300	
8.11	14.449	10.679	6.756	0.058	0.558	0.308	
9.11	14.433	10.635	7.198	0.071	0.551	0.313	
10.11	17.554	10.207	8.651	0.017	0.589	0.321	
11.11	18.474	10.317	9.275	0.975	0.584	0.325	
12.11	18.247	10.332	8.496	0.800	0.650	0.322	
13.11	13.673	7.924	22.268	1.250	0.687	0.390	
14.11	15.866	9.746	12.757	0.184	0.975	0.768	
15.11	16.521	10.505	14.577	0.210	0.588	0.315	
16.11	15.549	10.493	8.044	0.084	0.567	0.311	
17.11	19.026	10.200	8.672	0.067	0.607	0.326	
18.11	18.946	10.086	7.998	0.486	0.609	0.322	
19.11	19.868	10.072	10.299	0.293	0.678	0.335	
20.11	16.246	10.385	9.223	0.032	0.615	0.316	
21.11	10.156	10.438	9.190	2.184	0.530	0.306	
22.11	9.389	10.664	10.650	0.796	0.544	0.301	
23.11	8.669	10.936	9.289	0.645	0.510	0.293	
24.11	8.928	10.581	9.060	7.319	0.533	0.299	
25.11	7.979	10.704	9.137	2.706	0.557	0.297	
26.11	8.152	10.689	8.915	0.618	0.588	0.297	
27.11	11.366	10.608	8.729	0.969	0.678	0.307	
28.11	8.789	10.597	8.187	3.110	0.618	0.297	
29.11	12.789	10.421	8.992	13.814	0.632	0.309	
30.11	13.514	10.441	9.089	5.485	0.661	0.312	
min	7.979	7.924	6.420	0.014	0.509	0.293	
max	19.868	10.936	22.268	13.814	0.975	0.768	
MMV	13.928	10.399	9.237	1.431	0.604	0.329	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 11.2015



	UAB Fortum Klaipeda						sugeneruota: 1.12.2015
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.11	0.011	0.713	138.229	1.608	0.177	198155.57	
2.11	0.005	0.792	141.593	1.946	0.128	201314.93	
3.11	0.004	0.771	135.084	1.869	0.225	198679.51	
4.11	0.005	0.710	137.279	1.759	0.253	197603.29	
5.11	0.005	0.745	139.014	1.866	0.200	200516.56	
6.11	0.006	0.682	143.003	1.557	0.292	194531.93	
7.11	0.006	0.597	138.478	1.196	0.344	188581.12	
8.11	0.007	0.653	135.760	1.765	0.178	197383.93	
9.11	0.008	0.671	143.542	1.656	0.244	197790.37	
10.11	0.004	0.720	155.827	2.064	0.210	203492.79	
11.11	0.001	0.780	148.548	2.201	0.356	205914.39	
12.11	0.004	0.763	147.544	2.019	0.368	203184.82	
13.11	0.003	1.231	145.814	2.229	0.460	164675.82	
14.11	0.009	0.839	151.982	2.077	0.567	186864.56	
15.11	0.009	0.681	159.939	1.915	0.347	199763.92	
16.11	0.010	0.696	156.422	1.802	0.327	199068.51	
17.11	0.007	0.709	155.156	2.081	0.180	207076.82	
18.11	0.004	0.680	149.756	2.093	0.330	206236.35	
19.11	0.004	0.724	157.993	2.157	0.248	211501.79	
20.11	0.006	0.676	160.963	1.968	0.268	205490.62	
21.11	0.004	0.610	162.082	1.417	0.356	174508.17	
22.11	0.006	0.592	166.135	1.311	0.377	195572.01	
23.11	0.004	0.542	167.250	1.190	0.247	195299.32	
24.11	0.009	0.575	158.075	1.209	0.318	193661.89	
25.11	0.004	0.589	151.096	1.132	0.357	191438.51	
26.11	0.006	0.590	148.215	1.157	0.221	193207.79	
27.11	0.009	0.631	146.593	1.450	0.153	198771.32	
28.11	0.007	0.582	146.771	1.246	0.229	192417.81	
29.11	0.009	0.622	154.990	1.596	0.103	199243.51	
30.11	0.008	0.626	157.772	1.683	0.163	201988.01	
min	0.001	0.542	135.084	1.132	0.103	164675.82	
max	0.011	1.231	167.250	2.229	0.567	211501.79	
MMV	0.006	0.693	150.019	1.708	0.274	196797.89	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 11.2015



UAB Fortum Klaipeda		sugeneruota: 1.12.2015				
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	
Diena	°C	mbar	Vol%	mbar	°C	
1.11	53.760	1028.861	6.987	1026.633	1061.950	
2.11	58.269	1024.067	6.789	1022.014	1059.410	
3.11	55.267	1022.677	6.915	1020.763	1058.139	
4.11	53.393	1017.986	6.821	1016.841	1046.893	
5.11	57.134	1023.606	6.688	1021.844	1029.980	
6.11	50.107	1022.814	6.995	1022.220	1015.833	
7.11	43.523	1018.556	7.290	1018.310	1055.862	
8.11	53.565	1009.882	6.816	1007.519	1044.647	
9.11	53.795	1010.610	6.892	1008.901	1040.630	
10.11	58.295	1000.572	6.740	998.806	1054.180	
11.11	59.757	1007.192	6.722	1005.466	1048.625	
12.11	59.352	1009.868	6.651	1008.546	1053.398	
13.11	50.791	1016.420	8.588	1015.092	975.347	
14.11	81.491	1004.003	7.293	1003.695	980.057	
15.11	56.927	1001.717	6.767	1000.777	1026.465	
16.11	55.472	1007.749	6.857	1006.746	988.888	
17.11	60.313	1003.159	6.687	1001.538	979.393	
18.11	60.086	994.100	6.660	992.745	978.030	
19.11	61.094	993.987	6.581	993.075	972.468	
20.11	56.302	990.354	6.742	990.051	974.887	
21.11	45.002	992.706	7.269	992.910	971.060	
22.11	44.485	998.903	7.373	999.863	969.776	
23.11	42.756	1011.655	7.153	1010.836	971.666	
24.11	43.393	1016.773	7.283	1015.327	974.605	
25.11	41.268	1009.253	7.394	1009.057	983.111	
26.11	41.631	1011.205	7.333	1010.478	982.348	
27.11	48.310	1016.172	7.169	1014.118	982.821	
28.11	43.166	1006.700	7.315	1006.405	980.987	
29.11	51.127	1002.004	7.079	1000.652	975.559	
30.11	52.112	993.194	6.955	991.404	963.947	
min	41.268	990.354	6.581	990.051	963.947	
max	81.491	1028.861	8.588	1026.633	1061.950	
MMV	53.065	1008.892	7.027	1007.755	1006.698	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						