

# Menesine ataskaita: 11.2017



	UAB Fortum Klaipeda						sugeneruota: 1.12.2017
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	10.350	8.125	6.177	2.515	0.000	0.264	
2.11	14.931	8.018	4.127	4.383	0.000	0.274	
3.11	14.292	7.997	5.296	6.226	0.000	0.288	
4.11	17.032	8.011	3.816	6.102	0.000	0.347	
5.11	12.819	7.974	4.371	4.240	0.000	0.327	
6.11	11.614	8.006	6.213	2.512	0.000	0.297	
7.11	11.817	7.999	9.726	2.234	0.000	0.360	
8.11	X	X	X	X	X	X	
9.11	8.654	8.165	5.197	2.854	0.000	0.538	
10.11	11.692	8.037	10.242	4.188	0.000	0.465	
11.11	10.822	8.052	6.242	4.146	0.000	0.471	
12.11	10.731	8.019	4.402	3.906	0.000	0.465	
13.11	9.331	8.003	5.656	1.451	0.000	0.427	
14.11	7.831	8.122	7.316	0.958	0.000	0.303	
15.11	9.778	7.645	8.847	6.260	0.000	0.301	
16.11	8.708	7.868	3.846	1.697	0.199	0.925	
17.11	9.802	8.062	4.961	3.686	0.000	0.286	
18.11	8.081	8.119	3.810	1.056	0.000	0.267	
19.11	7.323	8.078	3.020	3.875	0.000	0.245	
20.11	7.849	8.098	3.755	6.439	0.000	0.220	
21.11	7.680	8.083	3.373	10.986	0.000	0.257	
22.11	7.939	8.071	3.803	13.414	0.000	0.273	
23.11	7.410	8.051	8.380	14.964	0.000	0.268	
24.11	X	-	-	-	-	-	
25.11	8.414	7.847	8.949	11.390	0.192	4.776	
26.11	8.464	8.009	3.449	0.824	0.000	0.296	
27.11	7.409	7.989	4.269	3.438	0.000	0.354	
28.11	7.671	8.067	3.061	8.788	0.000	0.374	
29.11	7.643	8.024	5.132	13.638	0.000	0.293	
30.11	8.151	8.002	9.886	9.146	0.000	0.259	
min	7.323	7.645	3.020	0.824	0.000	0.220	
max	17.032	8.165	10.242	14.964	0.199	4.776	
MMV	9.853	8.029	5.633	5.319	0.006	0.398	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 11.2017



	UAB Fortum Klaipeda						sugeneruota: 1.12.2017
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.11	0.071	0.015	170.159	0.343	0.586	216662.89	
2.11	0.074	0.002	168.846	0.472	0.781	222947.31	
3.11	0.076	0.005	170.732	0.393	0.672	225644.93	
4.11	0.075	0.027	169.987	0.547	0.934	226852.29	
5.11	0.073	0.029	170.584	0.336	0.559	221945.37	
6.11	0.072	0.007	167.549	0.315	0.732	218219.56	
7.11	0.072	0.022	169.690	0.298	0.646	217588.07	
8.11	X	X	X	X	0.986	175457.14	
9.11	0.086	0.128	168.731	0.180	0.698	204909.26	
10.11	0.073	0.092	168.296	0.252	0.805	210506.31	
11.11	0.074	0.108	170.675	0.243	0.781	216505.18	
12.11	0.073	0.041	168.239	0.139	0.613	218514.00	
13.11	0.072	0.009	169.304	0.153	0.627	217742.14	
14.11	0.070	0.015	169.824	0.237	0.667	215043.92	
15.11	0.079	0.001	167.051	0.302	0.697	208595.53	
16.11	0.073	0.010	173.304	0.483	0.717	188132.50	
17.11	0.072	0.000	168.342	0.273	0.701	217802.93	
18.11	0.069	0.000	169.670	0.267	0.653	214814.85	
19.11	0.068	0.001	169.471	0.323	0.808	214092.76	
20.11	0.069	0.000	168.926	0.310	0.772	215176.43	
21.11	0.069	0.000	170.711	0.236	0.890	214699.64	
22.11	0.069	0.000	169.455	0.239	0.662	214867.07	
23.11	0.073	0.009	168.288	0.359	0.669	173295.35	
24.11	-	-	-	-	-	X	
25.11	0.080	0.002	170.938	0.342	0.910	148745.43	
26.11	0.069	0.000	171.625	0.244	0.837	212914.25	
27.11	0.069	0.000	167.346	0.270	0.751	211510.82	
28.11	0.070	0.000	169.305	0.270	0.621	210900.54	
29.11	0.070	0.001	168.752	0.300	0.843	213025.98	
30.11	0.070	0.000	168.993	0.236	0.701	213236.81	
min	0.068	0.000	167.051	0.139	0.559	148745.43	
max	0.086	0.128	173.304	0.547	0.986	226852.29	
MMV	0.077	0.021	169.360	0.294	0.732	210676.40	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 11.2017



	UAB Fortum Klaipeda			sugeneruota: 1.12.2017		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.11	46.282	1013.804	4.864	1005.116	1054.321	6.208
2.11	53.858	1005.646	4.699	997.557	1060.257	4.145
3.11	52.984	1015.804	5.237	1007.998	1014.742	5.322
4.11	57.056	1019.022	4.599	1011.408	1023.448	3.823
5.11	50.235	1014.425	4.976	1007.554	1038.748	4.385
6.11	48.681	1020.454	5.000	1013.058	1050.413	6.266
7.11	48.629	1032.946	4.838	1025.289	1021.195	9.605
8.11	49.629	1032.621	X	1025.067	1037.643	X
9.11	43.646	1024.859	5.088	1018.045	1049.708	5.213
10.11	48.756	1011.836	4.833	1004.192	1040.974	10.187
11.11	46.896	997.040	4.844	990.308	1059.802	6.282
12.11	46.808	1000.118	4.664	992.743	1065.306	4.241
13.11	44.287	1010.067	5.090	1003.423	1043.416	5.654
14.11	42.090	1019.246	5.131	1011.775	1024.604	7.376
15.11	45.186	1022.191	6.466	1013.733	1014.380	9.011
16.11	65.331	1027.799	6.601	1020.164	1042.574	3.822
17.11	45.555	1021.672	5.167	1014.089	1040.873	4.986
18.11	42.222	1013.165	4.852	1006.180	1071.608	3.825
19.11	40.650	1001.346	4.864	995.003	1097.320	3.042
20.11	41.902	1007.434	4.876	1000.926	1064.319	3.780
21.11	41.701	1014.929	4.966	1007.646	1100.946	3.392
22.11	42.352	1016.315	4.999	1010.155	1066.926	3.823
23.11	62.186	1014.735	7.967	1007.200	1046.249	8.377
24.11	X	X	X	X	-	-
25.11	76.145	1012.157	8.735	1004.959	1010.732	8.870
26.11	42.922	1014.670	4.900	1007.621	1057.660	3.468
27.11	41.107	1018.317	5.057	1011.586	1035.505	4.286
28.11	41.644	1011.439	5.146	1005.314	1059.698	3.073
29.11	41.592	1011.995	5.191	1004.815	1070.353	5.163
30.11	42.733	1011.363	5.084	1004.465	1023.866	9.722
min	40.650	997.040	4.599	990.308	1010.732	3.042
max	76.145	1032.946	8.735	1025.289	1100.946	10.187
MMV	47.527	1014.940	5.247	1007.707	1049.029	5.624
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 11.2017



	UAB Fortum Klaipeda						sugeneruota: 1.12.2017
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	2.515	0.264	0.071	170.159	0.343	0.586	
2.11	4.383	0.274	0.074	168.846	0.472	0.781	
3.11	6.226	0.288	0.076	170.732	0.393	0.672	
4.11	6.102	0.347	0.075	169.987	0.547	0.934	
5.11	4.240	0.327	0.073	170.584	0.336	0.559	
6.11	2.512	0.297	0.072	167.549	0.315	0.732	
7.11	2.234	0.360	0.072	169.690	0.298	0.646	
8.11	X	X	X	X	X	0.986	
9.11	2.854	0.538	0.086	168.731	0.180	0.698	
10.11	4.188	0.465	0.073	168.296	0.252	0.805	
11.11	4.146	0.471	0.074	170.675	0.243	0.781	
12.11	3.906	0.465	0.073	168.239	0.139	0.613	
13.11	1.451	0.427	0.072	169.304	0.153	0.627	
14.11	0.958	0.303	0.070	169.824	0.237	0.667	
15.11	6.260	0.301	0.079	167.051	0.302	0.697	
16.11	1.697	0.925	0.073	173.304	0.483	0.717	
17.11	3.686	0.286	0.072	168.342	0.273	0.701	
18.11	1.056	0.267	0.069	169.670	0.267	0.653	
19.11	3.875	0.245	0.068	169.471	0.323	0.808	
20.11	6.439	0.220	0.069	168.926	0.310	0.772	
21.11	10.986	0.257	0.069	170.711	0.236	0.890	
22.11	13.414	0.273	0.069	169.455	0.239	0.662	
23.11	14.964	0.268	0.073	168.288	0.359	0.669	
24.11	-	-	-	-	-	-	
25.11	11.390	4.776	0.080	170.938	0.342	0.910	
26.11	0.824	0.296	0.069	171.625	0.244	0.837	
27.11	3.438	0.354	0.069	167.346	0.270	0.751	
28.11	8.788	0.374	0.070	169.305	0.270	0.621	
29.11	13.638	0.293	0.070	168.752	0.300	0.843	
30.11	9.146	0.259	0.070	168.993	0.236	0.701	
min	0.824	0.220	0.068	167.051	0.139	0.559	
max	14.964	4.776	0.086	173.304	0.547	0.986	
MMV	5.319	0.398	0.077	169.360	0.294	0.732	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							