

Menesine ataskaita: 11.2018



	UAB Fortum Klaipeda						sugeneruota: 1.12.2018
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	14.124	9.380	3.457	0.617	0.730	0.249	
2.11	18.291	9.255	3.819	0.804	1.050	0.209	
3.11	18.673	9.279	3.486	0.560	1.017	0.229	
4.11	14.008	9.272	2.600	0.308	0.843	0.209	
5.11	15.974	9.273	4.607	0.415	0.885	0.200	
6.11	16.630	9.276	3.665	0.484	1.010	0.211	
7.11	16.114	9.251	2.831	0.477	0.933	0.188	
8.11	10.968	9.539	6.446	0.478	0.706	0.210	
9.11	10.153	9.477	8.550	0.622	0.612	0.254	
10.11	15.645	9.322	2.986	0.766	0.751	0.243	
11.11	10.534	9.402	4.882	0.341	0.644	0.266	
12.11	12.404	9.413	3.669	0.499	0.609	0.259	
13.11	15.881	9.243	3.485	0.731	0.686	0.253	
14.11	17.796	9.217	5.234	1.241	0.659	0.193	
15.11	18.959	9.186	3.757	0.522	0.670	0.209	
16.11	15.940	9.317	2.530	3.354	0.580	0.240	
17.11	15.421	9.277	2.632	2.200	0.600	0.270	
18.11	16.467	9.265	3.163	3.069	0.719	0.248	
19.11	11.663	9.409	8.739	1.055	0.647	0.285	
20.11	8.082	9.499	3.495	0.856	0.504	0.284	
21.11	8.887	9.478	4.281	0.573	0.525	0.234	
22.11	8.862	X	X	X	X	X	
23.11	8.802	9.299	29.370	3.536	3.736	6.790	
24.11	9.589	9.374	17.700	0.942	0.798	1.233	
25.11	8.599	9.362	4.757	1.537	0.525	0.266	
26.11	9.185	9.262	5.289	1.399	0.495	0.216	
27.11	9.359	9.363	5.888	1.628	0.507	0.242	
28.11	9.556	9.293	6.995	1.794	0.475	0.198	
29.11	10.125	9.276	5.985	0.787	0.496	0.190	
30.11	10.404	9.287	4.153	2.212	0.484	0.261	
min	8.082	9.186	2.530	0.308	0.475	0.188	
max	18.959	9.539	29.370	3.536	3.736	6.790	
MMV	13.047	9.334	5.244	1.105	0.715	0.336	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 11.2018



	UAB Fortum Klaipeda						sugeneruota: 1.12.2018
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.11	0.056	0.000	127.197	0.302	0.553	182182.54	
2.11	0.065	0.000	126.138	0.408	0.579	181248.82	
3.11	0.062	0.000	127.147	0.385	0.562	183390.75	
4.11	0.056	0.000	127.264	0.335	0.548	178543.70	
5.11	0.058	0.000	127.462	0.318	0.586	180959.32	
6.11	0.061	0.000	127.018	0.339	0.656	179028.18	
7.11	0.060	0.000	127.333	0.323	0.592	178248.79	
8.11	0.057	0.000	127.071	0.236	0.548	169420.85	
9.11	0.056	0.000	127.288	0.324	0.513	171001.18	
10.11	0.059	0.000	127.504	0.360	0.590	178439.93	
11.11	0.056	0.000	127.225	0.212	0.590	174348.26	
12.11	0.055	0.000	127.446	0.278	0.543	177714.01	
13.11	0.057	0.000	127.341	0.318	0.539	187852.85	
14.11	0.059	0.000	127.081	0.327	0.491	196096.25	
15.11	0.057	0.000	127.732	0.392	0.474	200412.57	
16.11	0.054	0.000	127.275	0.269	0.725	196049.45	
17.11	0.057	0.000	127.604	0.306	0.546	197296.42	
18.11	0.055	0.000	127.205	0.318	0.659	199252.12	
19.11	0.053	0.017	127.041	0.264	0.531	174782.12	
20.11	0.053	0.000	126.916	0.202	0.556	174628.25	
21.11	0.050	0.000	127.111	0.315	0.654	175152.14	
22.11	X	X	X	X	X	135546.09	
23.11	0.088	0.000	130.415	0.349	1.021	74747.406	
24.11	0.054	0.005	130.373	0.318	0.621	180300.29	
25.11	0.052	0.000	126.978	0.227	0.478	192922.26	
26.11	0.049	0.000	127.280	0.251	0.446	194730.39	
27.11	0.049	0.008	127.237	0.292	0.598	191555.70	
28.11	0.048	0.000	127.134	0.236	0.587	196712.93	
29.11	0.048	0.000	127.058	0.227	0.589	195306.07	
30.11	0.049	0.000	127.163	0.246	0.562	194558.01	
min	0.048	0.000	126.138	0.202	0.446	74747.406	
max	0.088	0.017	130.415	0.408	1.021	200412.57	
MMV	0.056	0.001	127.347	0.299	0.574	181949.92	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 11.2018



	UAB Fortum Klaipeda			sugeneruota: 1.12.2018		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.11	51.935	1031.869	7.000	1021.169	1098.961	3.837
2.11	57.967	1029.627	6.959	1018.096	1106.581	4.254
3.11	58.644	1035.125	6.713	1024.741	1104.303	3.891
4.11	51.722	1036.476	7.179	1026.370	1103.593	2.906
5.11	54.941	1031.008	6.992	1020.153	1091.436	5.123
6.11	56.043	1028.234	7.756	1017.224	1080.178	4.057
7.11	55.355	1027.406	7.779	1016.924	1070.938	3.146
8.11	47.393	1028.267	8.342	1018.020	1048.625	7.241
9.11	45.695	1028.255	7.697	1018.105	1040.248	9.433
10.11	54.721	1026.293	7.292	1014.744	1073.584	3.330
11.11	45.787	1026.523	7.422	1016.779	1058.497	5.422
12.11	49.594	1030.141	7.341	1019.238	1050.953	4.091
13.11	54.926	1027.356	6.950	1016.069	1032.438	3.875
14.11	57.542	1031.621	6.725	1020.019	1059.382	5.810
15.11	58.989	1041.681	6.428	1030.279	1067.743	4.177
16.11	54.794	1048.667	6.610	1038.849	1082.506	2.812
17.11	54.470	1048.864	6.630	1038.459	1071.058	2.900
18.11	55.031	1037.559	6.402	1027.491	1105.029	3.519
19.11	48.497	1038.855	7.103	1029.622	1046.654	10.161
20.11	42.412	1037.777	7.382	1028.981	1060.594	3.898
21.11	44.218	1037.307	7.326	1028.708	1056.556	4.789
22.11	44.252	1037.049	9.586	1028.598	X	X
23.11	100.817	1033.728	14.821	1024.458	961.578	D 84.148
24.11	53.624	1025.344	7.538	1014.856	1009.698	19.692
25.11	43.354	1023.508	6.952	1012.969	1050.591	5.300
26.11	44.625	1023.917	6.785	1013.279	1055.944	5.888
27.11	44.898	1027.237	7.001	1016.811	1056.489	6.525
28.11	45.534	1039.165	6.699	1030.163	1031.741	7.764
29.11	46.390	1040.123	6.705	1031.541	1048.207	6.617
30.11	46.797	1033.309	6.741	1024.417	1071.484	4.607
min	42.412	1023.508	6.402	1012.969	961.578	2.812
max	100.817	1048.864	14.821	1038.849	1106.581	D 84.148
MMV	52.088	1032.967	7.299	1022.742	1064.030	6.579
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 11.2018



	UAB Fortum Klaipeda						sugeneruota: 1.12.2018
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	0.771	0.415	0.093	158.996	0.432	0.789	
2.11	1.005	0.349	0.108	157.673	0.584	0.827	
3.11	0.700	0.381	0.104	158.934	0.550	0.803	
4.11	0.384	0.348	0.093	159.080	0.478	0.783	
5.11	0.519	0.333	0.096	159.328	0.454	0.837	
6.11	0.604	0.351	0.102	158.772	0.484	0.938	
7.11	0.597	0.313	0.101	159.167	0.462	0.846	
8.11	0.598	0.350	0.096	158.838	0.338	0.782	
9.11	0.777	0.424	0.093	159.110	0.463	0.733	
10.11	0.957	0.405	0.098	159.380	0.514	0.843	
11.11	0.426	0.444	0.093	159.031	0.303	0.843	
12.11	0.623	0.431	0.092	159.308	0.397	0.776	
13.11	0.914	0.421	0.095	159.176	0.454	0.770	
14.11	1.551	0.321	0.098	158.852	0.467	0.702	
15.11	0.653	0.348	0.095	159.665	0.560	0.676	
16.11	4.193	0.401	0.091	159.094	0.384	1.036	
17.11	2.750	0.450	0.094	159.504	0.437	0.780	
18.11	3.837	0.413	0.092	159.006	0.455	0.941	
19.11	1.319	0.474	0.089	158.802	0.378	0.759	
20.11	1.070	0.473	0.088	158.645	0.288	0.795	
21.11	0.717	0.390	0.083	158.888	0.450	0.934	
22.11	X	X	X	X	X	X	
23.11	4.420	D 11.317	0.146	163.018	0.499	1.458	
24.11	1.178	2.055	0.091	162.966	0.455	0.887	
25.11	1.922	0.444	0.086	158.723	0.324	0.683	
26.11	1.749	0.359	0.081	159.100	0.359	0.638	
27.11	2.035	0.403	0.082	159.046	0.417	0.854	
28.11	2.243	0.329	0.080	158.917	0.337	0.838	
29.11	0.984	0.317	0.081	158.822	0.324	0.842	
30.11	2.765	0.435	0.082	158.953	0.352	0.803	
min	0.384	0.313	0.080	157.673	0.288	0.638	
max	4.420	D 11.317	0.146	163.018	0.584	1.458	
MMV	1.381	0.561	0.093	159.184	0.427	0.820	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							