

# Menesine ataskaita: 11.2020



	UAB Fortum Klaipeda						sugeneruota: 1.12.2020
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	20.490	7.458	4.833	0.000	1.036	0.032	
2.11	19.438	7.539	4.551	0.000	3.084	0.038	
3.11	19.305	7.506	6.602	0.000	1.926	1.670	
4.11	17.625	7.436	4.773	0.000	1.254	3.852	
5.11	18.222	7.422	3.472	0.000	0.710	4.329	
6.11	18.670	7.343	6.013	0.000	0.584	4.656	
7.11	18.932	7.325	5.929	0.000	0.769	4.770	
8.11	19.036	7.290	3.159	0.000	0.740	4.776	
9.11	18.795	7.375	3.535	0.000	0.409	1.807	
10.11	17.517	7.435	5.291	0.000	0.252	0.019	
11.11	16.546	7.482	5.526	0.000	0.276	0.039	
12.11	15.782	7.491	3.378	0.594	0.255	0.038	
13.11	16.548	7.474	3.467	0.428	0.254	0.023	
14.11	16.678	7.487	3.724	0.000	0.313	0.039	
15.11	17.582	7.511	3.384	0.000	0.307	0.011	
16.11	17.307	7.459	3.937	0.000	0.295	0.024	
17.11	18.318	7.472	4.651	0.000	0.318	0.014	
18.11	17.503	7.510	5.167	12.073	0.320	0.049	
19.11	16.818	7.567	3.872	0.016	0.301	0.045	
20.11	16.565	7.577	5.248	0.000	0.362	0.023	
21.11	X	X	X	X	X	X	
22.11	18.750	7.392	5.636	0.000	0.563	4.315	
23.11	18.006	7.262	5.181	0.000	0.554	3.480	
24.11	17.883	7.441	4.457	0.000	0.463	0.081	
25.11	19.168	7.382	4.631	0.000	0.719	0.080	
26.11	17.331	7.469	6.591	0.000	0.761	0.043	
27.11	17.501	7.482	5.693	0.000	1.303	0.019	
28.11	17.582	7.466	6.109	0.000	2.313	0.034	
29.11	14.635	7.514	5.723	0.000	1.401	0.031	
30.11	16.590	7.403	5.091	0.000	0.641	1.836	
min	14.635	7.262	3.159	0.000	0.252	0.011	
max	20.490	7.577	6.602	12.073	3.084	4.776	
MMV	17.742	7.452	4.816	0.440	0.768	1.219	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 11.2020



	UAB Fortum Klaipeda						sugeneruota: 1.12.2020
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.11	0.044	0.000	131.946	0.069	0.336	212076.10	
2.11	0.038	0.000	131.521	0.106	0.200	216775.48	
3.11	0.046	0.000	130.592	0.077	0.219	196478.23	
4.11	0.038	0.000	131.435	0.069	0.305	207686.25	
5.11	0.043	0.000	131.137	0.099	0.320	211679.48	
6.11	0.045	0.000	131.593	0.114	0.226	207836.67	
7.11	0.055	0.000	131.999	0.059	0.334	199657.70	
8.11	0.046	0.000	131.624	0.039	0.254	206154.20	
9.11	0.037	0.000	131.740	0.096	0.293	224970.81	
10.11	0.031	0.000	131.543	0.084	0.366	224266.85	
11.11	0.026	0.000	132.044	0.041	0.212	218735.29	
12.11	0.026	0.000	131.785	0.074	0.239	216256.45	
13.11	0.026	0.000	131.108	0.137	0.164	217558.20	
14.11	0.025	0.000	132.041	0.171	0.329	218069.07	
15.11	0.029	0.000	130.859	0.100	0.179	219553.06	
16.11	0.030	0.000	131.546	0.130	0.201	215871.45	
17.11	0.035	0.000	132.503	0.163	0.269	220944.76	
18.11	0.036	0.000	131.832	0.107	0.239	211689.12	
19.11	0.031	0.000	132.032	0.092	0.298	212257.23	
20.11	0.030	0.000	131.649	0.073	0.195	218339.89	
21.11	X	X	X	X	0.326	193412.79	
22.11	0.041	0.000	130.647	0.145	0.265	223470.20	
23.11	0.036	0.000	131.552	0.105	0.194	218047.04	
24.11	0.036	0.000	131.701	0.144	0.187	225700.10	
25.11	0.040	0.000	132.069	0.134	0.193	225677.29	
26.11	0.028	0.000	130.139	0.082	0.246	222646.25	
27.11	0.032	0.000	131.702	0.081	0.252	224119.31	
28.11	0.029	0.000	131.748	0.035	0.189	223689.35	
29.11	0.027	0.000	130.197	0.068	0.237	221022.81	
30.11	0.034	0.000	131.591	0.098	0.211	223016.54	
min	0.025	0.000	130.139	0.035	0.164	193412.79	
max	0.055	0.000	132.503	0.171	0.366	225700.10	
MMV	0.035	0.000	131.543	0.096	0.249	215921.73	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 11.2020



	UAB Fortum Klaipeda			sugeneruota: 1.12.2020		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.11	61.019	1033.080	5.888	1017.926	1039.576	5.418
2.11	59.795	1024.479	6.017	1009.566	1036.572	5.050
3.11	100.939	1030.089	6.020	1014.416	996.220	7.936
4.11	137.445	1035.603	6.227	1020.810	1015.918	5.299
5.11	136.543	1035.163	5.998	1021.397	1053.027	3.856
6.11	135.234	1037.396	5.874	1021.978	1032.368	6.680
7.11	136.821	1039.073	5.875	1024.680	1006.466	6.618
8.11	137.651	1036.811	5.933	1022.413	1039.926	3.516
9.11	90.328	1042.728	5.825	1028.592	1050.858	3.934
10.11	57.805	1046.706	5.917	1031.097	1033.476	5.873
11.11	56.656	1044.326	6.077	1029.323	1032.701	6.142
12.11	55.584	1038.871	6.296	1024.050	1053.540	3.752
13.11	56.449	1034.846	6.123	1020.120	1062.001	3.842
14.11	56.639	1033.503	6.124	1017.999	1054.709	4.152
15.11	57.675	1031.493	5.951	1015.978	1073.824	3.755
16.11	57.336	1028.289	6.034	1012.676	1040.413	4.367
17.11	58.593	1032.844	5.919	1016.912	1054.963	5.174
18.11	57.683	1032.860	6.151	1017.223	1016.384	5.730
19.11	56.705	1020.558	6.156	1005.756	1035.830	4.321
20.11	56.390	1029.191	6.325	1015.373	1019.989	5.822
21.11	56.961	1036.928	X	1022.569	1042.367	X
22.11	134.824	1023.252	5.728	1008.497	1029.812	6.277
23.11	111.626	1023.858	5.733	1009.019	1004.239	5.752
24.11	58.038	1029.666	5.704	1014.745	1019.357	4.951
25.11	59.519	1031.498	5.609	1015.647	1027.618	5.145
26.11	57.364	1026.749	5.811	1012.049	966.890	7.345
27.11	57.555	1026.090	5.800	1012.180	983.217	6.315
28.11	57.786	1032.845	5.817	1019.923	1000.992	6.789
29.11	53.570	1035.373	5.797	1021.816	1003.248	6.366
30.11	82.643	1033.036	5.856	1018.083	977.672	5.652
min	53.570	1020.558	5.609	1005.756	966.890	3.516
max	137.651	1046.706	6.325	1031.097	1073.824	7.936
MMV	78.439	1032.907	5.955	1018.095	1026.807	5.372
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 11.2020



	UAB Fortum Klaipeda						sugeneruota: 1.12.2020
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	0.000	0.053	0.074	164.932	0.099	0.480	
2.11	0.000	0.063	0.064	164.401	0.152	0.285	
3.11	0.000	2.784	0.077	163.240	0.110	0.313	
4.11	0.000	6.421	0.064	164.293	0.099	0.436	
5.11	0.000	7.215	0.072	163.921	0.142	0.457	
6.11	0.000	7.760	0.074	164.491	0.163	0.323	
7.11	0.000	7.950	0.092	164.999	0.084	0.477	
8.11	0.000	7.960	0.077	164.530	0.056	0.363	
9.11	0.000	3.011	0.062	164.675	0.137	0.419	
10.11	0.000	0.031	0.051	164.429	0.120	0.524	
11.11	0.000	0.065	0.043	165.055	0.059	0.303	
12.11	0.742	0.063	0.044	164.731	0.105	0.341	
13.11	0.534	0.039	0.043	163.886	0.196	0.235	
14.11	0.000	0.066	0.041	165.051	0.245	0.470	
15.11	0.000	0.018	0.048	163.574	0.143	0.256	
16.11	0.000	0.040	0.050	164.433	0.185	0.287	
17.11	0.000	0.024	0.058	165.628	0.232	0.384	
18.11	15.091	0.081	0.060	164.790	0.152	0.341	
19.11	0.019	0.075	0.051	165.040	0.131	0.426	
20.11	0.000	0.038	0.050	164.562	0.104	0.279	
21.11	X	X	X	X	X	0.466	
22.11	0.000	7.192	0.068	163.309	0.207	0.379	
23.11	0.000	5.800	0.061	164.440	0.150	0.276	
24.11	0.000	0.136	0.060	164.627	0.205	0.266	
25.11	0.000	0.134	0.067	165.086	0.191	0.275	
26.11	0.000	0.072	0.047	162.673	0.118	0.351	
27.11	0.000	0.032	0.054	164.627	0.116	0.359	
28.11	0.000	0.057	0.049	164.686	0.050	0.270	
29.11	0.000	0.052	0.045	162.746	0.096	0.338	
30.11	0.000	3.059	0.056	164.489	0.141	0.302	
min	0.000	0.018	0.041	162.673	0.050	0.235	
max	15.091	7.960	0.092	165.628	0.245	0.524	
MMV	0.549	2.032	0.059	164.428	0.137	0.356	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							