

# Menesine ataskaita: 11.2022



	UAB Gren Klaipeda						sugeneruota: 1.12.2022
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	10.323	7.564	2.525	0.005	0.136	0.020	
2.11	12.381	7.530	3.703	0.008	0.136	0.021	
3.11	11.925	7.571	4.019	0.009	0.130	0.015	
4.11	8.568	7.635	3.950	0.002	0.125	0.006	
5.11	8.091	7.605	3.521	0.002	0.145	0.044	
6.11	11.194	7.521	2.857	0.007	0.144	0.064	
7.11	8.400	7.622	3.921	0.501	0.130	0.010	
8.11	9.141	7.641	5.598	0.000	0.138	0.028	
9.11	8.851	7.635	3.703	0.000	0.129	0.011	
10.11	9.082	7.643	4.196	0.000	0.136	0.013	
11.11	9.028	7.681	4.344	0.001	0.131	0.025	
12.11	12.518	7.583	4.168	0.005	0.139	0.040	
13.11	10.235	7.617	3.567	0.000	0.148	0.023	
14.11	7.817	7.654	4.915	0.015	0.139	0.015	
15.11	8.538	7.695	2.967	0.042	0.134	0.027	
16.11	8.617	7.648	6.261	0.000	0.138	0.003	
17.11	9.123	7.627	5.710	0.000	0.137	0.017	
18.11	9.491	7.578	4.233	0.000	0.133	0.018	
19.11	10.413	7.557	2.824	0.000	0.128	0.022	
20.11	10.775	7.561	2.778	0.000	0.137	0.024	
21.11	10.390	7.585	7.533	0.000	0.212	0.009	
22.11	9.659	7.649	5.158	0.003	0.153	0.001	
23.11	10.116	7.679	4.040	0.004	0.146	0.004	
24.11	X	X	X	X	X	X	
25.11	X	X	X	X	X	X	
26.11	9.076	7.653	4.871	0.232	0.150	0.018	
27.11	8.976	7.641	3.414	0.002	0.145	0.011	
28.11	9.009	7.676	5.555	0.575	0.134	0.009	
29.11	9.045	7.681	5.487	0.103	0.134	0.011	
30.11	8.823	7.709	5.204	0.269	0.137	0.019	
min	7.817	7.521	2.525	0.000	0.125	0.001	
max	12.518	7.709	7.533	0.575	0.212	0.064	
MMV	9.628	7.626	4.407	0.061	0.140	0.018	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 11.2022



	UAB Fortum Klaipeda sugeneruota: 1.12.2022					
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.11	0.030	0.037	144.412	0.002	0.162	215303.87
2.11	0.034	0.066	143.330	0.019	0.135	220051.48
3.11	0.033	0.056	143.672	0.041	0.234	221356.51
4.11	0.023	0.001	144.310	0.000	0.237	220260.45
5.11	0.022	0.000	143.831	0.000	0.228	220347.87
6.11	0.030	0.026	143.486	0.001	0.226	219096.93
7.11	0.024	0.002	143.061	0.000	0.217	219464.62
8.11	0.028	0.010	143.571	0.000	0.192	215987.07
9.11	0.024	0.001	143.769	0.000	0.241	214810.67
10.11	0.025	0.005	143.732	0.000	0.214	214452.89
11.11	0.021	0.000	143.577	0.000	0.238	215524.93
12.11	0.028	0.007	143.877	0.003	0.169	219116.29
13.11	0.021	0.000	143.459	0.000	0.191	216911.64
14.11	0.019	0.000	143.478	0.000	0.536	218128.20
15.11	0.020	0.000	143.986	0.000	0.347	215429.73
16.11	0.019	0.000	143.461	0.000	0.417	226929.79
17.11	0.019	0.000	143.649	0.000	0.334	229055.45
18.11	0.020	0.000	143.445	0.000	0.336	229285.82
19.11	0.019	0.000	143.775	0.000	0.280	228757.20
20.11	0.019	0.000	143.602	0.000	0.231	230228.00
21.11	0.019	0.000	143.633	0.000	0.252	227883.45
22.11	0.019	0.000	143.269	0.000	0.206	226281.82
23.11	0.020	0.000	143.422	0.000	0.254	227159.51
24.11	X	X	X	X	0.298	210952.45
25.11	X	X	X	X	0.238	213003.75
26.11	0.019	0.000	143.830	0.000	0.173	228571.54
27.11	0.019	0.000	143.538	0.000	0.194	227217.51
28.11	0.019	0.000	143.534	0.000	0.212	227232.62
29.11	0.019	0.000	143.228	0.000	0.169	227620.54
30.11	0.020	0.000	143.624	0.000	0.167	221157.42
min	0.019	0.000	143.061	0.000	0.135	210952.45
max	0.034	0.066	144.412	0.041	0.536	230228.00
MMV	0.022	0.007	143.634	0.002	0.244	221585.98
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 11.2022



	UAB Fortum Klaipeda			sugeneruota: 1.12.2022		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.11	46.473	1034.597	6.552	1015.581	1105.707	2.809
2.11	49.905	1032.750	6.355	1013.677	1062.475	4.113
3.11	48.830	1033.880	6.227	1015.669	1059.355	4.475
4.11	43.328	1029.112	6.489	1012.042	1050.194	4.390
5.11	42.304	1028.261	6.532	1010.590	1054.732	3.921
6.11	47.664	1033.272	6.503	1014.250	1098.722	3.175
7.11	42.964	1028.335	6.562	1010.547	1070.363	4.370
8.11	44.133	1028.458	6.544	1009.035	1042.352	6.217
9.11	43.671	1027.261	6.498	1008.766	1044.793	4.117
10.11	44.174	1032.022	6.624	1013.014	1037.584	4.689
11.11	44.035	1038.185	6.515	1019.363	1021.954	4.826
12.11	50.510	1042.543	6.291	1023.547	1053.307	4.633
13.11	46.524	1046.498	6.414	1028.224	1075.656	3.960
14.11	41.891	1041.605	6.547	1024.252	1026.356	5.414
15.11	43.249	1032.134	6.648	1013.802	1031.290	3.306
16.11	43.504	1029.741	6.481	1013.899	1028.339	6.986
17.11	44.578	1027.319	6.356	1011.664	1022.577	6.363
18.11	45.292	1026.146	6.290	1010.452	1048.512	4.701
19.11	46.993	1027.771	6.221	1012.517	1021.027	3.138
20.11	47.587	1026.630	6.090	1010.215	1038.578	3.090
21.11	46.724	1023.687	6.229	1006.401	1012.276	8.361
22.11	45.263	1025.750	6.496	1008.271	1054.943	5.745
23.11	46.410	1026.558	6.466	1010.248	1032.133	4.492
24.11	46.362	1029.791	X	1012.669	1024.009	X
25.11	45.081	1035.778	X	1017.439	1014.940	X
26.11	44.669	1043.209	6.467	1023.763	1017.243	5.426
27.11	44.466	1044.116	6.372	1025.055	1032.438	3.786
28.11	44.507	1042.736	6.422	1024.441	1020.164	6.189
29.11	44.572	1044.579	6.419	1026.610	1005.445	6.108
30.11	44.179	1048.401	6.675	1029.850	1019.741	5.795
min	41.891	1023.687	6.090	1006.401	1005.445	2.809
max	50.510	1048.401	6.675	1029.850	1105.707	8.361
MMV	45.328	1033.704	6.444	1015.863	1040.906	4.898
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 11.2022



	UAB Fortum Klaipeda sugeneruota: 1.12.2022					
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.11	0.006	0.033	0.050	180.515	0.003	0.232
2.11	0.010	0.035	0.056	179.163	0.028	0.192
3.11	0.011	0.024	0.055	179.590	0.058	0.334
4.11	0.002	0.010	0.039	180.387	0.000	0.339
5.11	0.002	0.074	0.036	179.788	0.000	0.326
6.11	0.009	0.106	0.049	179.358	0.001	0.323
7.11	0.626	0.016	0.040	178.827	0.000	0.310
8.11	0.000	0.047	0.047	179.464	0.000	0.275
9.11	0.000	0.018	0.040	179.711	0.000	0.344
10.11	0.000	0.022	0.042	179.665	0.000	0.306
11.11	0.001	0.041	0.035	179.471	0.000	0.340
12.11	0.006	0.067	0.047	179.846	0.004	0.241
13.11	0.000	0.038	0.035	179.324	0.000	0.273
14.11	0.019	0.025	0.032	179.348	0.000	0.765
15.11	0.053	0.045	0.033	179.983	0.000	0.495
16.11	0.000	0.005	0.032	179.327	0.000	0.595
17.11	0.000	0.028	0.032	179.561	0.000	0.477
18.11	0.000	0.030	0.033	179.306	0.000	0.481
19.11	0.000	0.037	0.032	179.718	0.000	0.400
20.11	0.000	0.040	0.032	179.503	0.000	0.330
21.11	0.000	0.015	0.032	179.542	0.000	0.360
22.11	0.004	0.001	0.032	179.087	0.000	0.294
23.11	0.005	0.007	0.033	179.277	0.000	0.363
24.11	X	X	X	X	X	0.426
25.11	X	X	X	X	X	0.340
26.11	0.290	0.030	0.032	179.787	0.000	0.247
27.11	0.003	0.019	0.032	179.423	0.000	0.277
28.11	0.719	0.015	0.032	179.418	0.000	0.303
29.11	0.129	0.018	0.032	179.035	0.000	0.241
30.11	0.336	0.032	0.033	179.530	0.000	0.239
min	0.000	0.001	0.032	178.827	0.000	0.192
max	0.719	0.106	0.056	180.515	0.058	0.765
MMV	0.076	0.030	0.037	179.542	0.003	0.348
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						