

# Menesine ataskaita: 11.2023



	UAB Gren Klaipeda						sugeneruota: 1.12.2023	
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc		
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.		
1.11	9.878	7.704	6.391	2.530	0.074	0.000		
2.11	10.303	7.762	5.041	2.564	0.089	0.000		
3.11	10.191	7.674	6.081	2.796	0.065	0.000		
4.11	9.810	7.672	6.451	2.754	0.075	0.000		
5.11	9.030	7.660	15.793	2.239	0.048	0.000		
6.11	8.572	7.760	12.093	2.536	0.050	0.000		
7.11	8.840	7.745	8.603	3.927	0.038	0.000		
8.11	9.158	7.764	6.673	2.498	0.124	0.000		
9.11	10.560	7.694	6.591	2.426	0.309	0.001		
10.11	11.024	7.695	6.913	3.114	0.224	0.000		
11.11	11.301	7.698	5.881	3.288	0.186	0.000		
12.11	11.063	7.715	5.566	2.888	0.205	0.000		
13.11	9.488	7.754	6.588	2.377	0.341	0.001		
14.11	9.570	7.698	7.306	2.897	0.314	0.000		
15.11	10.552	7.593	4.550	3.441	0.105	0.000		
16.11	10.475	7.648	6.792	3.456	0.009	0.001		
17.11	9.920	7.703	5.370	2.576	0.005	0.000		
18.11	9.299	7.707	5.700	2.255	0.003	0.000		
19.11	9.617	7.736	7.216	2.753	0.005	0.000		
20.11	9.732	7.657	11.117	2.235	0.870	0.000		
21.11	10.215	7.672	11.618	2.258	0.485	0.003		
22.11	10.447	7.711	9.721	2.187	0.249	0.002		
23.11	9.169	7.593	13.696	2.361	0.744	0.000		
24.11	10.134	7.639	6.997	3.022	0.713	0.001		
25.11	10.021	7.618	5.009	2.423	0.834	0.001		
26.11	10.913	7.624	7.286	2.464	0.562	0.000		
27.11	11.664	7.636	6.395	3.386	0.414	0.000		
28.11	11.062	7.665	6.718	3.143	0.340	0.000		
29.11	11.203	7.698	8.302	3.613	0.579	0.000		
30.11	11.455	7.648	7.296	3.047	1.031	0.000		
min	8.572	7.593	4.550	2.187	0.003	0.000		
max	11.664	7.764	15.793	3.927	1.031	0.003		
MMV	10.158	7.685	7.644	2.783	0.303	0.000		
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down								

# Menesine ataskaita: 11.2023



	UAB Gren Klaipeda						sugeneruota: 1.12.2023
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.11	0.075	0.000	143.367	0.000	0.487	188474.31	
2.11	0.076	0.000	143.854	0.000	0.591	190306.92	
3.11	0.073	0.000	143.405	0.000	0.661	190477.12	
4.11	0.069	0.000	143.765	0.000	0.721	188852.73	
5.11	0.072	0.000	143.554	0.000	0.652	183639.70	
6.11	0.068	0.000	143.420	0.000	0.555	184512.39	
7.11	0.071	0.000	143.587	0.000	0.548	185153.31	
8.11	0.072	0.000	143.662	0.000	0.528	188377.85	
9.11	0.077	0.000	143.756	0.000	0.647	190267.20	
10.11	0.081	0.000	143.520	0.000	0.580	191881.87	
11.11	0.076	0.000	143.359	0.000	0.575	192896.01	
12.11	0.077	0.000	143.813	0.000	0.510	194303.64	
13.11	0.075	0.000	143.752	0.000	0.706	189388.32	
14.11	0.080	0.000	143.718	0.000	0.819	189707.64	
15.11	0.090	0.000	143.280	0.000	0.659	190211.75	
16.11	0.082	0.013	143.598	0.007	0.513	191813.48	
17.11	0.080	0.000	143.456	0.000	0.559	188291.10	
18.11	0.071	0.000	143.733	0.000	0.657	188372.37	
19.11	0.073	0.000	143.517	0.000	0.628	190112.81	
20.11	0.078	0.000	143.693	0.076	0.616	187470.87	
21.11	0.081	0.000	143.751	0.089	0.582	188562.29	
22.11	0.086	0.000	143.490	0.000	0.580	190320.56	
23.11	0.080	0.000	148.187	0.000	0.584	170526.95	
24.11	0.081	0.000	143.711	0.000	0.568	192079.56	
25.11	0.080	0.000	143.743	0.000	0.630	191098.04	
26.11	0.085	0.000	143.449	0.000	0.681	191230.70	
27.11	0.095	0.000	143.357	0.000	0.605	190035.51	
28.11	0.089	0.000	143.536	0.000	0.638	191126.51	
29.11	0.081	0.000	143.615	0.000	0.794	190268.76	
30.11	0.084	0.000	143.730	0.000	0.763	190291.43	
min	0.068	0.000	143.280	0.000	0.487	170526.95	
max	0.095	0.013	148.187	0.089	0.819	194303.64	
MMV	0.079	0.000	143.746	0.006	0.621	189001.73	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 11.2023



	UAB Gren Klaipeda			sugeneruota: 1.12.2023		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.11	45.291	1019.701	7.233	1000.817	1016.666	6.900
2.11	46.139	1020.311	6.716	1001.207	1027.755	5.373
3.11	45.779	1010.678	7.039	991.403	1008.738	6.544
4.11	44.941	1005.362	7.105	986.531	990.591	6.977
5.11	43.527	1005.142	7.837	986.370	971.916	19.319
6.11	42.729	1009.422	7.710	989.609	956.802	13.456
7.11	43.322	1022.524	7.432	1003.014	963.399	9.372
8.11	44.010	1024.599	7.234	1005.407	989.229	7.194
9.11	46.589	1025.218	7.298	1005.803	983.744	7.094
10.11	47.490	1020.237	7.072	1001.073	1004.652	7.441
11.11	47.954	1019.921	6.911	1000.818	997.878	6.324
12.11	47.533	1019.545	7.043	1000.290	999.852	5.957
13.11	44.630	1021.291	7.198	1002.411	1006.925	7.149
14.11	44.718	1015.458	7.102	997.189	1005.686	7.902
15.11	46.587	1020.573	7.191	1002.841	1007.482	4.831
16.11	46.600	1031.654	7.200	1013.148	1009.856	7.348
17.11	45.588	1033.580	6.989	1015.648	1031.306	5.749
18.11	44.486	1039.809	7.075	1021.166	1021.344	6.126
19.11	44.990	1032.663	6.919	1014.197	1029.043	7.824
20.11	45.125	1028.336	7.315	1009.917	997.314	12.325
21.11	46.201	1035.519	7.172	1017.639	984.931	12.844
22.11	46.692	1040.230	7.206	1021.770	992.897	10.657
23.11	43.899	1010.247	8.032	989.528	961.506	15.183
24.11	45.511	1000.662	7.091	981.590	1028.105	7.579
25.11	45.488	1008.662	7.381	991.588	1019.929	5.350
26.11	47.203	1018.141	7.300	1001.755	1019.905	7.904
27.11	48.577	1020.152	6.909	1003.699	1013.340	6.914
28.11	47.399	1014.979	6.833	996.662	1021.961	7.277
29.11	47.686	1019.465	6.660	1001.988	1021.733	9.071
30.11	48.169	1018.620	6.761	1000.700	1010.830	7.908
min	42.729	1000.662	6.660	981.590	956.802	4.831
max	48.577	1040.230	8.032	1021.770	1031.306	19.319
MMV	45.829	1020.424	7.164	1001.860	1003.177	8.380
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down						

# Menesine ataskaita: 11.2023



	UAB Gren Klaipeda						sugeneruota: 1.12.2023
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	3.162	0.000	0.074	186.337	0.000	0.300	
2.11	3.204	0.000	0.078	186.793	0.000	0.466	
3.11	3.495	0.000	0.071	186.330	0.000	0.556	
4.11	3.442	0.000	0.064	186.787	0.000	0.643	
5.11	2.798	0.000	0.067	186.777	0.000	0.514	
6.11	3.170	0.000	0.062	186.518	0.000	0.385	
7.11	4.909	0.000	0.068	186.625	0.000	0.393	
8.11	3.122	0.000	0.069	186.669	0.000	0.368	
9.11	3.033	0.001	0.078	186.886	0.000	0.531	
10.11	3.893	0.001	0.086	186.530	0.000	0.435	
11.11	4.110	0.001	0.077	186.286	0.000	0.430	
12.11	3.611	0.000	0.079	186.896	0.000	0.331	
13.11	2.971	0.001	0.075	186.788	0.000	0.626	
14.11	3.622	0.000	0.084	186.715	0.000	0.792	
15.11	4.301	0.001	0.101	186.244	0.000	0.550	
16.11	4.320	0.001	0.087	186.646	0.009	0.340	
17.11	3.219	0.000	0.085	186.360	0.000	0.419	
18.11	2.819	0.001	0.070	186.708	0.000	0.567	
19.11	3.441	0.001	0.074	186.397	0.000	0.524	
20.11	2.793	0.000	0.079	186.781	0.090	0.490	
21.11	2.823	0.005	0.085	186.817	0.110	0.446	
22.11	2.734	0.003	0.094	186.508	0.000	0.441	
23.11	2.951	0.000	0.080	192.710	0.000	0.417	
24.11	3.777	0.002	0.085	186.735	0.000	0.415	
25.11	3.028	0.001	0.083	186.870	0.000	0.501	
26.11	3.080	0.000	0.091	186.514	0.000	0.575	
27.11	4.233	0.000	0.110	186.304	0.000	0.471	
28.11	3.928	0.000	0.099	186.470	0.000	0.524	
29.11	4.517	0.001	0.087	186.520	0.000	0.759	
30.11	3.809	0.000	0.092	186.711	0.000	0.708	
min	2.734	0.000	0.062	186.244	0.000	0.300	
max	4.909	0.005	0.110	192.710	0.110	0.792	
MMV	3.478	0.001	0.081	186.808	0.007	0.497	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							