

Menesine ataskaita: 11.2024



	UAB Gren Klaipeda						sugeneruota: 26.11.2024
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	16.269	7.578	8.102	0.019	0.378	0.002	
2.11	16.023	7.609	7.347	0.013	0.427	0.003	
3.11	16.743	7.555	7.916	0.005	0.454	0.001	
4.11	15.237	7.609	7.692	0.004	0.435	0.007	
5.11	15.561	7.683	7.202	0.000	0.457	0.014	
6.11	16.178	7.572	9.024	0.026	0.352	0.004	
7.11	16.394	7.581	6.467	0.020	0.330	0.001	
8.11	17.223	7.657	6.768	0.011	0.318	0.011	
9.11	17.996	7.550	5.873	0.006	0.368	0.002	
10.11	15.886	7.666	5.603	0.003	0.171	0.005	
11.11	15.651	7.649	6.951	0.006	0.166	0.005	
12.11	14.314	7.608	8.570	0.033	0.226	0.003	
13.11	14.103	7.676	6.278	0.005	0.270	0.000	
14.11	15.552	7.537	6.335	0.020	0.316	0.003	
15.11	15.464	7.474	4.416	0.014	0.197	0.024	
16.11	17.119	7.453	5.788	0.003	0.227	0.002	
17.11	18.272	7.440	6.667	0.000	0.326	0.000	
18.11	17.636	7.474	8.159	0.077	0.237	0.001	
19.11	15.531	7.406	11.241	0.020	0.309	0.007	
20.11	16.270	7.458	8.909	0.006	0.198	0.004	
21.11	13.435	7.509	8.332	0.005	0.160	0.004	
22.11	11.359	7.658	12.107	0.025	0.111	0.007	
23.11	9.817	7.703	8.653	0.000	0.897	0.003	
24.11	10.498	7.728	8.465	0.002	0.766	0.004	
25.11	11.645	7.699	8.099	0.002	0.588	0.004	
min	9.817	7.406	4.416	0.000	0.111	0.000	
max	18.272	7.728	12.107	0.077	0.897	0.024	
MMV	15.220	7.581	7.624	0.013	0.348	0.005	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 11.2024



UAB Gren Klaipeda		sugeneruota: 26.11.2024				
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.11	0.071	0.000	135.724	0.243	0.492	232639.04
2.11	0.078	0.000	136.091	0.120	0.520	225963.93
3.11	0.070	0.000	135.610	0.162	0.482	234703.85
4.11	0.074	0.000	136.005	0.140	0.507	231964.31
5.11	0.071	0.000	135.802	0.176	0.528	229860.75
6.11	0.068	0.000	135.927	0.252	0.514	231019.70
7.11	0.074	0.000	135.788	0.302	0.488	231759.87
8.11	0.071	0.000	135.725	0.365	0.527	232764.17
9.11	0.074	0.000	135.917	0.354	0.555	235267.75
10.11	0.073	0.000	135.949	0.107	0.513	229912.51
11.11	0.076	0.000	135.738	0.052	0.482	228671.20
12.11	0.073	0.000	135.891	0.043	0.452	229978.50
13.11	0.076	0.000	135.819	0.016	0.435	227986.92
14.11	0.079	0.000	135.749	0.064	0.510	230892.10
15.11	0.075	0.000	135.959	0.110	0.497	228970.89
16.11	0.073	0.000	135.689	0.221	0.541	229777.32
17.11	0.078	0.000	135.741	0.275	0.520	235172.75
18.11	0.076	0.000	136.028	0.178	0.508	233099.20
19.11	0.079	0.000	135.644	0.057	0.544	229186.31
20.11	0.082	0.000	135.876	0.108	0.473	229320.31
21.11	0.069	0.000	135.770	0.076	0.527	228075.18
22.11	0.069	0.074	104.541	0.032	0.601	218290.62
23.11	0.063	0.000	100.840	0.001	0.435	226619.73
24.11	0.066	0.000	136.115	0.001	0.583	225642.98
25.11	0.072	0.000	135.669	0.024	0.432	221884.00
min	0.063	0.000	100.840	0.001	0.432	218290.62
max	0.082	0.074	136.115	0.365	0.601	235267.75
MMV	0.073	0.003	133.280	0.139	0.507	229576.98
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 11.2024



	UAB Gren Klaipeda			sugeneruota: 26.11.2024		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.11	55.237	1022.212	6.666	1001.295	1035.950	8.812
2.11	55.059	1037.586	7.053	1018.039	1028.979	7.954
3.11	55.940	1038.371	6.823	1017.528	1031.024	8.614
4.11	54.165	1044.696	7.153	1024.457	1033.602	8.359
5.11	54.496	1046.437	7.016	1024.721	1044.032	7.789
6.11	55.440	1047.975	6.896	1026.433	1018.449	9.854
7.11	55.716	1049.816	7.018	1028.673	1029.233	6.937
8.11	56.813	1054.711	6.620	1034.179	1036.518	7.311
9.11	57.660	1053.245	6.714	1032.449	1037.293	6.281
10.11	54.950	1049.910	6.793	1029.532	1052.517	5.989
11.11	54.680	1048.118	6.868	1027.798	1066.362	7.503
12.11	52.806	1050.909	7.299	1029.804	1047.351	9.370
13.11	52.395	1046.092	7.212	1025.297	1044.235	6.746
14.11	54.393	1034.816	7.016	1013.517	1050.041	6.811
15.11	54.303	1034.605	7.016	1012.604	1056.167	4.651
16.11	56.286	1027.425	6.716	1006.330	1032.887	6.198
17.11	57.375	1014.557	6.452	994.258	1040.198	7.188
18.11	56.615	1012.566	6.509	992.703	1017.793	8.869
19.11	54.060	1014.502	7.228	994.836	1019.957	12.347
20.11	54.775	998.593	6.697	978.634	1042.318	9.693
21.11	50.607	1004.666	6.927	985.336	1042.859	9.099
22.11	48.092	1010.720	7.477	991.193	1025.806	X
23.11	45.352	1024.000	7.179	1003.674	1027.061	9.422
24.11	46.461	1034.455	7.209	1014.261	1023.794	9.235
25.11	48.495	1031.966	7.095	1010.533	1023.601	8.844
min	45.352	998.593	6.452	978.634	1017.793	4.651
max	57.660	1054.711	7.477	1034.179	1066.362	12.347
MMV	53.687	1033.318	6.944	1012.724	1036.321	8.262
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 11.2024



	UAB Gren Klaipeda						sugeneruota: 26.11.2024
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.11	0.024	0.003	0.066	176.823	0.113	0.282	
2.11	0.016	0.006	0.077	177.417	0.045	0.319	
3.11	0.007	0.002	0.064	176.762	0.071	0.266	
4.11	0.005	0.012	0.070	177.291	0.038	0.306	
5.11	0.000	0.024	0.065	177.005	0.062	0.339	
6.11	0.033	0.006	0.061	177.155	0.134	0.318	
7.11	0.025	0.002	0.069	177.038	0.174	0.275	
8.11	0.014	0.018	0.066	176.865	0.274	0.341	
9.11	0.007	0.003	0.070	177.190	0.240	0.374	
10.11	0.003	0.008	0.070	177.130	0.046	0.323	
11.11	0.008	0.009	0.074	176.874	0.007	0.275	
12.11	0.041	0.005	0.068	177.151	0.006	0.228	
13.11	0.006	0.001	0.074	177.011	0.001	0.207	
14.11	0.025	0.005	0.079	176.937	0.006	0.307	
15.11	0.017	0.041	0.073	177.196	0.020	0.289	
16.11	0.004	0.004	0.070	176.847	0.108	0.349	
17.11	0.000	0.000	0.078	176.892	0.160	0.313	
18.11	0.096	0.001	0.074	177.235	0.077	0.298	
19.11	0.025	0.012	0.078	176.883	0.004	0.342	
20.11	0.007	0.007	0.084	177.026	0.020	0.243	
21.11	0.006	0.006	0.063	176.810	0.019	0.338	
22.11	0.031	0.012	0.060	137.338	0.015	0.411	
23.11	0.000	0.004	0.054	132.486	0.000	0.228	
24.11	0.003	0.007	0.058	177.180	0.000	0.444	
25.11	0.003	0.006	0.069	176.637	0.001	0.216	
min	0.000	0.000	0.054	132.486	0.000	0.207	
max	0.096	0.041	0.084	177.417	0.274	0.444	
MMV	0.016	0.008	0.069	173.769	0.066	0.305	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							