

Menesine ataskaita: 12.2014



UAB Fortum Klaipeda		sugeneruota: 1.01.2015				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.12	10.612	10.958	6.430	0.000	0.466	0.548
2.12	10.755	10.915	6.139	0.001	0.458	0.515
3.12	10.790	10.884	5.809	0.455	0.469	0.429
4.12	9.648	11.046	5.977	0.093	0.474	0.396
5.12	9.151	10.992	6.452	0.031	0.493	0.436
6.12	12.355	10.755	7.037	0.343	0.502	0.365
7.12	14.151	10.752	6.118	0.389	0.512	0.401
8.12	10.185	10.763	5.531	0.019	0.497	0.423
9.12	11.565	10.851	6.480	0.028	0.496	0.443
10.12	9.485	10.876	7.497	0.003	0.497	0.387
11.12	9.721	10.769	6.794	0.046	0.502	0.401
12.12	9.525	10.839	7.715	0.209	0.521	0.492
13.12	14.225	10.665	9.186	0.284	0.516	0.440
14.12	12.621	10.797	7.074	0.092	0.502	0.410
15.12	10.015	10.777	5.554	0.050	0.479	0.435
16.12	12.121	10.797	5.144	1.441	0.462	0.527
17.12	11.363	10.855	6.892	1.106	0.468	0.559
18.12	12.447	11.093	6.734	1.310	0.477	0.513
19.12	13.597	11.366	5.347	1.576	0.461	0.510
20.12	11.564	11.181	6.985	0.943	0.478	0.413
21.12	8.964	11.338	6.256	0.234	0.483	0.431
22.12	10.676	11.258	3.618	0.864	0.467	0.463
23.12	13.416	11.074	3.444	1.154	0.454	0.525
24.12	11.261	10.627	4.415	0.994	0.472	0.557
25.12	10.350	10.851	6.775	0.233	0.471	0.582
26.12	10.525	10.781	6.384	0.006	0.489	0.569
27.12	10.540	10.755	6.693	0.021	0.485	0.585
28.12	11.237	10.818	6.266	0.178	0.485	0.587
29.12	11.482	10.746	5.003	0.159	0.484	0.561
30.12	11.684	10.726	7.076	0.049	0.484	0.450
31.12	8.872	10.842	6.389	0.035	0.480	0.533
min	8.872	10.627	3.444	0.000	0.454	0.365
max	14.225	11.366	9.186	1.576	0.521	0.587
MMV	11.124	10.895	6.233	0.398	0.483	0.480
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 12.2014



	UAB Fortum Klaipeda						sugeneruota: 1.01.2015
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.12	0.006	0.367	145.240	0.621	0.561	216622.73	
2.12	0.005	0.382	145.977	0.613	0.594	217552.04	
3.12	0.006	0.388	149.284	0.581	0.505	217065.81	
4.12	0.006	0.347	149.290	0.496	0.521	218378.25	
5.12	0.002	0.337	147.919	0.582	0.593	217851.68	
6.12	0.001	0.314	147.839	0.707	0.403	222014.20	
7.12	0.001	0.318	148.551	0.792	0.374	228562.45	
8.12	0.002	0.315	152.839	0.721	0.528	219241.85	
9.12	0.002	0.325	155.702	0.822	0.275	223767.06	
10.12	0.004	0.351	155.632	0.757	0.599	220005.17	
11.12	0.004	0.339	153.506	0.645	0.452	220870.14	
12.12	0.003	0.308	153.484	0.645	0.498	221700.57	
13.12	0.001	0.270	147.572	0.733	0.342	231108.92	
14.12	0.001	0.318	154.426	0.717	0.405	224537.60	
15.12	0.002	0.320	151.925	0.676	0.576	218365.50	
16.12	0.004	0.318	153.771	0.678	0.376	223450.82	
17.12	0.005	0.399	150.759	0.675	0.351	223904.92	
18.12	0.003	0.391	150.095	0.668	0.405	223412.62	
19.12	0.003	0.368	151.154	0.686	0.475	224585.60	
20.12	0.005	0.327	149.571	0.658	0.486	217862.98	
21.12	0.006	0.337	154.091	0.683	0.472	212659.17	
22.12	0.006	0.318	153.345	0.624	0.555	211665.17	
23.12	0.004	0.311	159.955	0.753	0.477	222072.64	
24.12	0.004	0.351	140.466	0.688	0.533	222272.85	
25.12	0.003	0.347	146.927	0.587	0.658	222414.42	
26.12	0.003	0.379	147.612	0.650	0.489	222398.89	
27.12	0.005	0.383	140.765	0.573	0.610	219972.06	
28.12	0.005	0.375	149.890	0.585	0.412	220173.04	
29.12	0.006	0.384	148.682	0.701	0.678	216132.10	
30.12	0.006	0.356	150.084	0.730	0.470	218439.60	
31.12	0.006	0.372	152.782	0.608	0.472	221240.75	
min	0.001	0.270	140.466	0.496	0.275	211665.17	
max	0.006	0.399	159.955	0.822	0.678	231108.92	
MMV	0.004	0.346	150.292	0.666	0.489	220654.78	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 12.2014



UAB Fortum Klaipeda		sugeneruota: 1.01.2015				
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	
Diena	°C	mbar	Vol%	mbar	°C	
1.12	46.797	1026.196	6.455	1028.432	957.367	
2.12	47.082	1022.276	6.449	1024.611	963.786	
3.12	47.145	1021.947	6.426	1023.610	954.566	
4.12	44.729	1024.511	6.478	1024.558	955.984	
5.12	43.569	1021.326	6.522	1021.555	943.211	
6.12	49.453	1016.655	6.290	1016.563	943.587	
7.12	52.348	1015.301	6.137	1015.350	947.370	
8.12	45.620	1008.344	6.437	1009.648	963.366	
9.12	48.366	1019.460	6.331	1019.619	948.736	
10.12	44.170	1013.830	6.518	1015.677	951.360	
11.12	44.509	1003.583	6.509	1005.056	958.345	
12.12	43.901	995.312	6.461	996.289	930.346	
13.12	52.557	994.542	6.064	994.845	940.058	
14.12	50.139	1009.765	6.191	1010.653	962.023	
15.12	45.120	1008.091	6.403	1010.080	973.208	
16.12	48.892	1004.877	6.181	1005.596	986.395	
17.12	47.506	998.041	6.196	999.290	942.080	
18.12	49.336	1000.080	6.034	1001.199	956.784	
19.12	50.976	993.090	5.802	993.586	972.710	
20.12	47.615	992.320	5.921	994.091	955.706	
21.12	42.704	1001.723	6.024	1002.963	963.341	
22.12	45.951	992.797	5.819	993.533	997.965	
23.12	51.272	993.446	5.796	994.352	1005.565	
24.12	47.105	995.360	6.361	996.875	1011.199	
25.12	45.918	1003.597	6.459	1006.834	970.098	
26.12	46.567	1017.311	6.492	1020.113	961.469	
27.12	46.413	1010.887	6.536	1014.445	978.845	
28.12	47.983	1010.697	6.495	1015.038	984.343	
29.12	48.647	1017.824	6.508	1022.891	994.449	
30.12	48.941	1021.939	6.476	1024.863	961.186	
31.12	42.829	1019.936	6.622	1018.950	971.592	
min	42.704	992.320	5.796	993.533	930.346	
max	52.557	1026.196	6.622	1028.432	1011.199	
MMV	47.231	1008.874	6.303	1010.361	964.744	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						