

Menesine ataskaita: 12.2017



	UAB Fortum Klaipeda						sugeneruota: 1.01.2018
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.12	8.233	8.049	6.213	11.021	0.000	0.330	
2.12	9.886	7.951	4.923	12.281	0.000	0.314	
3.12	8.053	7.947	3.180	1.393	0.000	0.275	
4.12	7.818	7.970	4.372	4.243	0.000	0.282	
5.12	7.435	7.981	4.020	7.010	0.000	0.311	
6.12	7.706	7.963	3.665	12.434	0.000	0.307	
7.12	7.577	8.025	4.273	18.941	0.000	0.354	
8.12	7.467	8.014	5.528	12.964	0.000	0.282	
9.12	7.607	8.047	3.790	30.350	0.000	0.311	
10.12	7.769	8.003	2.802	31.580	0.000	0.397	
11.12	8.219	7.979	2.964	27.144	0.000	0.362	
12.12	7.516	8.019	3.000	31.522	0.000	0.362	
13.12	7.562	8.003	3.705	32.106	0.000	0.384	
14.12	8.392	8.014	4.627	28.926	0.000	0.320	
15.12	9.998	7.968	6.216	33.569	0.000	0.334	
16.12	9.176	8.033	3.648	36.581	0.000	0.339	
17.12	7.858	8.044	3.388	42.962	0.000	0.336	
18.12	7.924	7.983	7.429	27.963	0.000	0.382	
19.12	7.751	7.969	5.739	46.592	0.000	0.344	
20.12	7.568	8.011	3.797	13.301	0.000	0.350	
21.12	7.807	8.001	3.058	16.648	0.000	0.342	
22.12	7.416	8.013	2.993	5.085	0.000	0.401	
23.12	7.407	8.038	3.842	9.642	0.000	0.312	
24.12	7.429	8.053	2.152	34.816	0.000	0.267	
25.12	7.416	8.021	2.277	20.138	0.000	0.231	
26.12	7.456	8.011	3.616	19.711	0.000	0.261	
27.12	7.619	7.996	2.505	35.924	0.000	0.365	
28.12	7.856	8.013	2.764	7.993	0.000	0.338	
29.12	7.469	8.204	2.835	12.935	0.000	0.274	
30.12	7.845	8.260	2.435	11.159	0.000	0.279	
31.12	8.027	8.202	2.789	12.730	0.000	0.280	
min	7.407	7.947	2.152	1.393	0.000	0.231	
max	9.998	8.260	7.429	46.592	0.000	0.401	
MMV	7.911	8.025	3.822	20.988	0.000	0.323	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 12.2017



	UAB Fortum Klaipeda						sugeneruota: 1.01.2018
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.12	0.070	0.003	168.443	0.186	0.725	212861.98	
2.12	0.071	0.000	169.168	0.277	0.675	216722.85	
3.12	0.069	0.000	169.906	0.252	0.733	215013.95	
4.12	0.069	0.001	168.897	0.257	0.678	214667.51	
5.12	0.069	0.001	169.586	0.205	0.650	213704.87	
6.12	0.069	0.001	169.153	0.297	0.698	212285.70	
7.12	0.068	0.002	169.071	0.297	0.842	214228.07	
8.12	0.067	0.015	169.490	0.258	0.997	210825.20	
9.12	0.068	0.000	169.780	0.358	0.937	214593.68	
10.12	0.069	0.000	169.472	0.304	0.801	216853.85	
11.12	0.069	0.000	170.240	0.336	0.582	216706.73	
12.12	0.069	0.000	169.684	0.376	0.842	215442.64	
13.12	0.069	0.003	169.607	0.364	0.744	214770.56	
14.12	0.069	0.003	169.862	0.339	0.677	216306.95	
15.12	0.071	0.006	171.369	0.315	0.812	216306.20	
16.12	0.070	0.000	170.592	0.350	0.955	217558.89	
17.12	0.069	0.000	173.548	0.351	0.639	216267.85	
18.12	0.070	0.028	169.682	0.548	0.782	217746.26	
19.12	0.070	0.017	168.825	0.613	0.627	219366.35	
20.12	0.069	0.000	169.310	0.322	0.637	216751.01	
21.12	0.069	0.003	169.372	0.268	0.873	217221.89	
22.12	0.068	0.000	169.409	0.197	0.693	213562.42	
23.12	0.069	0.000	170.403	0.271	0.711	217156.32	
24.12	0.068	0.000	179.882	0.336	0.912	215730.57	
25.12	0.068	0.000	175.599	0.281	0.720	215007.85	
26.12	0.068	0.002	174.838	0.299	0.778	214765.37	
27.12	0.068	0.000	168.598	0.356	0.661	214949.43	
28.12	0.068	0.002	170.491	0.282	0.613	215894.37	
29.12	0.069	0.001	169.774	0.252	0.609	206957.75	
30.12	0.071	0.000	171.952	0.287	0.871	213724.56	
31.12	0.070	0.000	174.379	0.302	0.592	212426.45	
min	0.067	0.000	168.443	0.186	0.582	206957.75	
max	0.071	0.028	179.882	0.613	0.997	219366.35	
MMV	0.069	0.003	170.662	0.314	0.744	215044.56	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 12.2017



	UAB Fortum Klaipeda			sugeneruota: 1.01.2018		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.12	42.884	1007.146	5.021	1000.451	1048.396	6.223
2.12	45.553	1025.084	4.983	1016.787	1063.211	4.954
3.12	42.551	1021.971	5.025	1014.592	1063.274	3.190
4.12	42.033	1013.921	4.980	1006.753	1064.077	4.400
5.12	41.158	1018.306	5.031	1010.077	1063.846	4.043
6.12	41.619	1015.409	4.862	1007.417	1065.329	3.703
7.12	41.356	1012.238	4.718	1004.257	1068.261	4.278
8.12	41.022	1002.855	4.618	995.736	1107.529	5.516
9.12	41.374	1004.424	4.755	998.181	1067.622	3.826
10.12	41.754	1002.146	4.830	995.799	1093.524	2.812
11.12	42.743	997.483	4.845	991.101	1096.772	2.978
12.12	41.101	998.184	4.982	990.139	1081.749	3.063
13.12	41.371	1010.779	5.010	1004.039	1075.884	3.728
14.12	43.122	996.994	4.957	990.982	1067.430	4.623
15.12	45.733	998.752	4.891	991.808	1071.344	6.226
16.12	44.595	1005.314	4.853	998.731	1082.990	3.671
17.12	42.094	1018.229	4.840	1010.515	1081.337	3.413
18.12	42.484	1029.000	5.142	1021.795	1090.164	7.502
19.12	42.084	1032.176	5.229	1024.017	1088.539	5.831
20.12	41.664	1035.323	5.068	1027.582	1045.686	3.813
21.12	42.136	1025.385	4.933	1018.050	1088.085	3.085
22.12	41.161	1023.451	4.866	1014.931	1057.262	3.013
23.12	41.002	1013.235	4.952	1005.042	1058.671	3.841
24.12	40.928	1006.277	4.740	998.344	1076.011	2.161
25.12	40.992	1010.560	4.793	1002.358	1081.942	2.292
26.12	41.043	1006.475	4.778	998.925	1070.410	3.636
27.12	41.390	1002.306	4.745	995.425	1058.695	2.521
28.12	41.885	998.091	4.720	990.618	1061.830	2.783
29.12	41.075	1005.057	5.095	997.662	1056.179	2.908
30.12	42.038	1011.020	5.362	1004.584	1053.952	2.457
31.12	42.370	1004.718	5.049	998.419	1069.356	2.646
min	40.928	996.994	4.618	990.139	1045.686	2.161
max	45.733	1035.323	5.362	1027.582	1107.529	7.502
MMV	42.075	1011.366	4.925	1004.037	1071.592	3.843
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 12.2017



	UAB Fortum Klaipeda						sugeneruota: 1.01.2018
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.12	11.021	0.330	0.070	168.443	0.186	0.725	
2.12	12.281	0.314	0.071	169.168	0.277	0.675	
3.12	1.393	0.275	0.069	169.906	0.252	0.733	
4.12	4.243	0.282	0.069	168.897	0.257	0.678	
5.12	7.010	0.311	0.069	169.586	0.205	0.650	
6.12	12.434	0.307	0.069	169.153	0.297	0.698	
7.12	18.941	0.354	0.068	169.071	0.297	0.842	
8.12	12.964	0.282	0.067	169.490	0.258	0.997	
9.12	30.350	0.311	0.068	169.780	0.358	0.937	
10.12	31.580	0.397	0.069	169.472	0.304	0.801	
11.12	27.144	0.362	0.069	170.240	0.336	0.582	
12.12	31.522	0.362	0.069	169.684	0.376	0.842	
13.12	32.106	0.384	0.069	169.607	0.364	0.744	
14.12	28.926	0.320	0.069	169.862	0.339	0.677	
15.12	33.569	0.334	0.071	171.369	0.315	0.812	
16.12	36.581	0.339	0.070	170.592	0.350	0.955	
17.12	42.962	0.336	0.069	173.548	0.351	0.639	
18.12	27.963	0.382	0.070	169.682	0.548	0.782	
19.12	46.592	0.344	0.070	168.825	0.613	0.627	
20.12	13.301	0.350	0.069	169.310	0.322	0.637	
21.12	16.648	0.342	0.069	169.372	0.268	0.873	
22.12	5.085	0.401	0.068	169.409	0.197	0.693	
23.12	9.642	0.312	0.069	170.403	0.271	0.711	
24.12	34.816	0.267	0.068	179.882	0.336	0.912	
25.12	20.138	0.231	0.068	175.599	0.281	0.720	
26.12	19.711	0.261	0.068	174.838	0.299	0.778	
27.12	35.924	0.365	0.068	168.598	0.356	0.661	
28.12	7.993	0.338	0.068	170.491	0.282	0.613	
29.12	12.935	0.274	0.069	169.774	0.252	0.609	
30.12	11.159	0.279	0.071	171.952	0.287	0.871	
31.12	12.730	0.280	0.070	174.379	0.302	0.592	
min	1.393	0.231	0.067	168.443	0.186	0.582	
max	46.592	0.401	0.071	179.882	0.613	0.997	
MMV	20.988	0.323	0.069	170.662	0.314	0.744	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							