

# Menesine ataskaita: 12.2020



	UAB Fortum Klaipeda						sugeneruota: 1.01.2021
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.12	13.571	7.516	3.742	0.000	0.241	0.039	
2.12	10.724	7.596	4.493	0.000	0.209	0.050	
3.12	12.084	7.706	6.769	0.000	0.185	0.057	
4.12	14.077	7.587	8.536	0.000	0.180	0.043	
5.12	14.647	7.501	5.464	0.000	0.224	0.029	
6.12	15.437	7.504	4.626	0.000	0.265	0.070	
7.12	13.805	7.484	3.725	0.000	0.255	0.053	
8.12	12.814	7.517	6.292	0.000	0.267	0.046	
9.12	12.025	7.557	4.851	0.000	0.263	0.053	
10.12	12.262	7.580	5.045	0.000	0.290	0.050	
11.12	12.542	7.468	4.252	0.000	0.302	0.038	
12.12	12.121	7.424	5.741	0.000	0.315	0.033	
13.12	15.198	7.466	5.241	0.000	0.376	0.032	
14.12	13.794	7.428	3.790	0.000	0.377	0.012	
15.12	16.092	7.319	5.325	0.000	0.525	0.059	
16.12	15.237	7.280	8.001	0.000	0.455	0.042	
17.12	16.867	7.318	6.335	0.000	0.373	0.009	
18.12	16.737	7.327	5.841	0.000	0.331	0.037	
19.12	17.304	7.368	4.019	0.000	0.317	0.018	
20.12	16.277	7.366	3.399	0.000	0.316	0.019	
21.12	16.025	7.346	5.065	0.000	0.351	0.060	
22.12	15.063	7.341	3.814	0.000	0.546	0.064	
23.12	16.807	7.372	4.709	0.000	0.552	0.044	
24.12	16.828	7.303	4.032	0.000	0.490	0.052	
25.12	16.669	7.339	4.285	0.000	0.443	0.029	
26.12	16.614	7.349	3.746	0.000	0.442	0.022	
27.12	16.695	7.319	3.739	0.000	0.409	0.013	
28.12	16.463	7.340	6.198	0.000	0.389	0.055	
29.12	16.007	7.319	6.284	0.000	0.355	0.096	
30.12	17.918	7.388	4.957	0.000	0.468	0.023	
31.12	16.285	7.372	7.028	0.000	0.432	0.030	
min	10.724	7.280	3.399	0.000	0.180	0.009	
max	17.918	7.706	8.536	0.000	0.552	0.096	
MMV	15.000	7.423	5.140	0.000	0.353	0.041	
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down							

# Menesine ataskaita: 12.2020



	UAB Fortum Klaipeda						sugeneruota: 1.01.2021
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.12	0.024	0.000	131.933	0.103	0.187	219711.95	
2.12	0.026	0.000	132.196	0.039	0.221	212062.75	
3.12	0.025	0.000	131.962	0.056	0.220	216245.06	
4.12	0.028	0.000	131.664	0.062	0.209	218517.26	
5.12	0.028	0.000	132.360	0.125	0.219	220410.32	
6.12	0.028	0.000	133.777	0.125	0.189	222107.18	
7.12	0.027	0.000	145.096	0.054	0.317	219353.06	
8.12	0.027	0.000	132.423	0.068	0.299	217188.43	
9.12	0.027	0.000	131.436	0.029	0.244	212886.29	
10.12	0.025	0.004	131.882	0.017	0.299	214838.67	
11.12	0.026	0.000	131.608	0.005	0.234	216153.98	
12.12	0.026	0.000	131.983	0.018	0.186	215381.07	
13.12	0.026	0.000	132.200	0.037	0.223	221687.93	
14.12	0.024	0.000	131.067	0.027	0.211	218254.85	
15.12	0.028	0.000	131.223	0.066	0.245	220433.39	
16.12	0.029	0.000	131.895	0.086	0.202	218418.37	
17.12	0.031	0.000	131.777	0.154	0.219	222825.17	
18.12	0.038	0.000	131.935	0.102	0.205	222097.37	
19.12	0.035	0.000	131.865	0.102	0.223	223044.31	
20.12	0.027	0.001	132.105	0.086	0.225	220615.01	
21.12	0.027	0.000	130.658	0.121	0.204	218717.64	
22.12	0.026	0.000	132.225	0.090	0.264	216630.17	
23.12	0.031	0.000	131.733	0.125	X	222712.85	
24.12	0.032	0.000	132.085	0.134	X	220844.95	
25.12	0.032	0.000	131.780	0.098	X	220639.39	
26.12	0.032	0.000	131.709	0.085	X	220092.23	
27.12	0.033	0.000	131.901	0.088	X	219180.43	
28.12	0.029	0.000	131.846	0.075	X	220916.62	
29.12	0.029	0.000	131.828	0.120	0.178	218923.17	
30.12	0.039	0.000	131.694	0.121	0.194	225271.23	
31.12	0.030	0.000	131.732	0.117	0.185	219984.31	
min	0.024	0.000	130.658	0.005	0.178	212062.75	
max	0.039	0.004	145.096	0.154	0.317	225271.23	
MMV	0.029	0.000	132.309	0.082	0.257	219230.56	
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down							

# Menesine ataskaita: 12.2020



	UAB Fortum Klaipeda			sugeneruota: 1.01.2021		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.12	52.166	1035.633	5.936	1021.390	1012.174	4.152
2.12	47.685	1038.305	6.475	1025.272	1016.721	4.993
3.12	49.864	1028.907	6.322	1015.016	1014.410	7.531
4.12	52.770	1021.803	6.082	1006.845	989.310	9.454
5.12	53.702	1025.599	6.018	1009.480	996.413	6.091
6.12	54.843	1030.222	5.822	1015.601	1033.227	5.149
7.12	52.220	1028.259	5.953	1015.159	1065.579	4.134
8.12	50.862	1030.016	6.436	1017.435	987.660	6.976
9.12	49.698	1033.040	6.408	1019.988	982.202	5.387
10.12	50.122	1029.382	6.445	1015.403	995.259	5.596
11.12	50.551	1025.226	6.240	1010.103	1021.551	4.725
12.12	49.545	1024.311	6.188	1009.254	988.055	6.378
13.12	54.433	1027.456	5.864	1012.931	1004.146	5.828
14.12	52.512	1031.029	6.209	1015.742	1000.596	4.215
15.12	55.720	1030.944	5.937	1016.066	1027.873	5.925
16.12	54.671	1031.522	6.061	1015.379	1000.562	8.898
17.12	56.859	1037.335	5.777	1021.360	1029.221	7.039
18.12	56.598	1034.258	5.888	1018.699	1018.770	6.505
19.12	57.395	1036.467	5.714	1021.695	1015.841	4.469
20.12	56.100	1037.168	5.862	1023.427	1034.271	3.790
21.12	55.681	1035.466	5.860	1021.193	983.166	5.628
22.12	54.300	1025.804	6.123	1011.314	1018.250	4.233
23.12	56.625	1022.771	5.771	1006.866	1024.133	5.239
24.12	56.494	1014.129	5.744	1000.769	1027.578	4.491
25.12	56.389	1018.465	5.789	1004.508	1018.372	4.767
26.12	56.367	1024.189	5.830	1009.722	1023.318	4.167
27.12	56.335	1020.498	5.840	1007.055	1003.735	4.158
28.12	55.882	1011.411	5.828	997.277	992.791	6.916
29.12	55.300	1006.109	5.827	990.887	991.532	6.994
30.12	57.717	1015.655	5.568	1000.828	1011.759	5.516
31.12	55.864	1020.048	5.793	1005.839	981.524	7.788
min	47.685	1006.109	5.568	990.887	981.524	3.790
max	57.717	1038.305	6.475	1025.272	1065.579	9.454
MMV	54.041	1026.820	5.987	1012.340	1010.002	5.713
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						

# Menesine ataskaita: 12.2020



	UAB Fortum Klaipeda						sugeneruota: 1.01.2021
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.12	0.000	0.064	0.041	164.916	0.147	0.267	
2.12	0.000	0.084	0.043	165.245	0.056	0.316	
3.12	0.000	0.095	0.041	164.952	0.080	0.315	
4.12	0.000	0.072	0.047	164.580	0.088	0.299	
5.12	0.000	0.048	0.046	165.450	0.179	0.313	
6.12	0.000	0.116	0.046	167.221	0.178	0.270	
7.12	0.000	0.088	0.045	181.370	0.077	0.454	
8.12	0.000	0.077	0.046	165.529	0.098	0.428	
9.12	0.000	0.088	0.045	164.295	0.042	0.349	
10.12	0.000	0.083	0.042	164.852	0.024	0.428	
11.12	0.000	0.063	0.044	164.510	0.006	0.334	
12.12	0.000	0.054	0.043	164.979	0.026	0.265	
13.12	0.000	0.053	0.043	165.250	0.053	0.318	
14.12	0.000	0.020	0.040	163.834	0.038	0.302	
15.12	0.000	0.099	0.047	164.028	0.094	0.350	
16.12	0.000	0.070	0.048	164.869	0.123	0.289	
17.12	0.000	0.016	0.051	164.721	0.219	0.313	
18.12	0.000	0.061	0.063	164.918	0.145	0.293	
19.12	0.000	0.031	0.059	164.831	0.145	0.319	
20.12	0.000	0.032	0.045	165.131	0.123	0.322	
21.12	0.000	0.100	0.045	163.322	0.173	0.291	
22.12	0.000	0.106	0.043	165.281	0.129	0.377	
23.12	0.000	0.073	0.052	164.666	0.179	X	
24.12	0.000	0.086	0.053	165.106	0.191	X	
25.12	0.000	0.048	0.053	164.725	0.140	X	
26.12	0.000	0.037	0.053	164.636	0.122	X	
27.12	0.000	0.022	0.055	164.876	0.126	X	
28.12	0.000	0.092	0.048	164.807	0.108	X	
29.12	0.000	0.160	0.048	164.785	0.172	0.254	
30.12	0.000	0.039	0.065	164.617	0.172	0.277	
31.12	0.000	0.051	0.050	164.665	0.167	0.264	
min	0.000	0.016	0.040	163.322	0.006	0.254	
max	0.000	0.160	0.065	181.370	0.219	0.454	
MMV	0.000	0.069	0.048	165.386	0.117	0.366	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							