

# Menesine ataskaita: 12.2023



	UAB Gren Klaipeda						sugeneruota: 1.01.2024
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.12	9.987	7.595	8.025	2.727	0.250	0.000	
2.12	10.296	7.664	5.887	2.793	0.070	0.000	
3.12	10.794	7.665	6.888	2.544	0.070	0.001	
4.12	X	X	X	X	X	X	
5.12	10.243	7.765	9.430	3.015	0.353	0.000	
6.12	11.690	7.774	11.980	2.519	0.439	0.000	
7.12	11.242	7.776	11.687	2.875	0.360	0.001	
8.12	11.660	7.716	8.694	2.899	0.421	0.000	
9.12	11.530	7.679	8.403	3.537	0.282	0.002	
10.12	10.689	7.746	6.888	2.345	0.313	0.001	
11.12	10.300	7.684	6.661	2.886	0.244	0.000	
12.12	9.846	7.718	9.020	2.681	0.215	0.002	
13.12	12.666	7.504	9.061	2.513	1.320	1.029	
14.12	9.904	7.691	6.987	3.703	0.322	0.000	
15.12	10.692	7.751	6.988	3.627	0.259	0.004	
16.12	9.599	7.680	4.880	2.287	0.299	0.003	
17.12	10.930	7.670	5.846	2.533	0.330	0.001	
18.12	10.732	7.637	4.932	2.446	0.248	0.001	
19.12	8.854	7.735	5.802	2.096	0.205	0.000	
20.12	9.673	7.763	8.477	2.235	0.313	0.002	
21.12	9.418	7.700	7.591	2.358	0.076	0.002	
22.12	9.566	7.652	8.054	3.128	0.010	0.001	
23.12	9.638	7.662	6.960	2.587	0.019	0.001	
24.12	10.605	7.671	8.512	2.760	0.061	0.002	
25.12	10.562	7.600	9.043	2.919	0.135	0.000	
26.12	8.968	7.686	6.524	2.237	0.093	0.000	
27.12	9.796	7.672	6.008	2.189	0.165	0.000	
28.12	9.759	7.643	5.803	2.395	0.166	0.001	
29.12	9.261	7.723	6.157	2.407	0.102	0.000	
30.12	9.411	7.724	7.094	2.069	0.081	0.000	
31.12	9.194	7.717	7.002	2.044	0.099	0.000	
min	8.854	7.504	4.880	2.044	0.010	0.000	
max	12.666	7.776	11.980	3.703	1.320	1.029	
MMV	10.260	7.690	7.574	2.645	0.245	0.034	
- = Out of op < = <2/3      X = no daily classing      N = No Data M = Maintenance                      S = Fault D = >DLV                                  A = Start-up/shut down							

# Menesine ataskaita: 12.2023



	UAB Gren Klaipeda						sugeneruota: 1.01.2024
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.12	0.081	0.000	143.511	0.000	0.605	190202.81	
2.12	0.084	0.000	143.639	0.000	0.519	189648.56	
3.12	0.089	0.000	143.074	0.000	0.606	193660.76	
4.12	X	X	X	X	0.631	180909.37	
5.12	0.082	0.000	143.780	0.000	0.622	190486.37	
6.12	0.087	0.000	143.922	0.000	0.594	185500.43	
7.12	0.088	0.000	143.179	0.000	0.526	190211.62	
8.12	0.098	0.000	143.827	0.000	0.615	189026.93	
9.12	0.094	0.000	143.408	0.000	0.562	189272.39	
10.12	0.085	0.000	143.678	0.000	0.631	189165.00	
11.12	0.085	0.000	143.522	0.000	0.674	187503.10	
12.12	0.080	0.000	143.619	0.000	0.534	184005.01	
13.12	0.089	0.021	143.412	0.013	0.811	188785.14	
14.12	0.087	0.000	143.803	0.000	0.607	186020.67	
15.12	0.087	0.000	143.253	0.000	0.531	194368.95	
16.12	0.081	0.000	143.793	0.000	0.585	184669.57	
17.12	0.088	0.000	143.479	0.000	0.619	193433.00	
18.12	0.081	0.000	143.654	0.000	0.604	191928.45	
19.12	0.073	0.000	143.791	0.000	0.719	187034.43	
20.12	0.086	0.000	143.495	0.000	0.800	189332.54	
21.12	0.077	0.000	143.778	0.000	0.740	188255.37	
22.12	0.073	0.000	143.618	0.000	0.708	188326.50	
23.12	0.078	0.000	143.497	0.000	0.619	189517.76	
24.12	0.088	0.000	143.671	0.000	0.705	195172.92	
25.12	0.094	0.000	143.409	0.001	0.544	192596.82	
26.12	0.080	0.000	143.832	0.000	0.631	188234.56	
27.12	0.082	0.000	143.546	0.000	0.566	190019.07	
28.12	0.078	0.000	143.635	0.002	X	189120.39	
29.12	0.075	0.000	143.672	0.001	0.622	188677.75	
30.12	0.078	0.000	143.430	0.000	0.599	189009.25	
31.12	0.081	0.000	143.750	0.000	0.591	188986.67	
min	0.073	0.000	143.074	0.000	0.519	180909.37	
max	0.098	0.021	143.922	0.013	0.811	195172.92	
MMV	0.084	0.001	143.594	0.001	0.644	189131.67	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							

# Menesine ataskaita: 12.2023



	UAB Gren Klaipeda			sugeneruota: 1.01.2024		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.12	45.509	1017.173	7.198	997.819	1006.864	8.742
2.12	46.198	1024.614	7.050	1005.633	1017.143	6.326
3.12	47.068	1028.526	7.047	1009.970	1023.659	7.466
4.12	46.872	1032.274	X	1013.261	988.070	X
5.12	46.231	1036.899	7.088	1017.768	991.033	10.336
6.12	48.816	1037.452	6.764	1020.649	985.365	13.218
7.12	47.986	1040.950	6.927	1022.365	986.945	12.844
8.12	48.718	1039.003	7.099	1021.203	1009.795	9.477
9.12	48.394	1033.746	7.027	1015.559	1005.934	9.154
10.12	46.814	1027.734	6.871	1008.680	1036.275	7.464
11.12	45.990	1018.494	7.146	999.363	1030.195	7.208
12.12	45.310	1021.224	7.249	1001.259	996.834	9.861
13.12	74.398	1025.160	6.944	1005.515	1023.195	9.897
14.12	45.569	1031.084	7.086	1012.504	1023.617	7.566
15.12	47.116	1040.101	6.865	1020.346	1018.225	7.572
16.12	45.030	1041.836	7.599	1021.121	1031.030	X
17.12	47.542	1035.983	7.111	1015.693	1031.076	6.297
18.12	47.075	1033.346	7.060	1013.712	1018.564	5.249
19.12	43.448	1023.918	7.406	1004.513	1020.158	6.220
20.12	44.919	1014.304	7.093	995.760	1028.944	9.263
21.12	44.281	998.683	7.148	980.714	1013.565	8.302
22.12	44.373	982.715	6.864	964.979	1008.969	8.774
23.12	44.641	994.739	6.983	976.730	1029.895	7.538
24.12	46.496	1009.633	7.041	991.349	1002.079	9.320
25.12	46.355	1001.545	7.104	981.971	1004.007	9.872
26.12	43.572	1012.425	7.446	993.526	1013.113	7.038
27.12	45.317	1026.444	7.279	1007.419	1026.288	6.472
28.12	45.235	1025.871	7.321	1006.920	1023.309	6.239
29.12	44.139	1018.270	7.114	998.456	1022.347	6.636
30.12	44.429	1018.251	6.962	999.282	1026.966	7.716
31.12	44.162	1028.858	7.418	1010.296	1008.090	7.574
min	43.448	982.715	6.764	964.979	985.365	5.249
max	74.398	1041.836	7.599	1022.365	1036.275	13.218
MMV	46.839	1023.266	7.109	1004.334	1014.567	8.236
- = Out of op < = <2/3                      X = no daily classing                      N = No Data M = Maintenance                                      S = Fault D = >DLV    A = Start-up/shut down						

# Menesine ataskaita: 12.2023



	UAB Gren Klaipeda						sugeneruota: 1.01.2024
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.12	3.408	0.000	0.085	186.507	0.000	0.473	
2.12	3.491	0.000	0.090	186.633	0.000	0.352	
3.12	3.179	0.002	0.100	185.944	0.000	0.479	
4.12	X	X	X	X	X	0.476	
5.12	3.769	0.000	0.086	186.821	0.000	0.508	
6.12	3.149	0.000	0.096	186.968	0.000	0.466	
7.12	3.593	0.001	0.097	186.060	0.000	0.365	
8.12	3.624	0.000	0.113	186.962	0.000	0.488	
9.12	4.422	0.003	0.106	186.400	0.000	0.412	
10.12	2.931	0.001	0.093	186.641	0.000	0.520	
11.12	3.607	0.001	0.093	186.519	0.000	0.575	
12.12	3.351	0.003	0.083	186.656	0.000	0.370	
13.12	3.142	1.715	0.098	186.449	0.016	0.733	
14.12	4.628	0.001	0.096	186.832	0.000	0.485	
15.12	4.534	0.007	0.096	186.103	0.000	0.378	
16.12	2.859	0.004	0.084	186.989	0.000	0.427	
17.12	3.167	0.002	0.097	186.488	0.000	0.496	
18.12	3.057	0.001	0.085	186.681	0.000	0.477	
19.12	2.621	0.000	0.071	186.876	0.000	0.644	
20.12	2.794	0.003	0.094	186.433	0.000	0.764	
21.12	2.947	0.003	0.078	186.795	0.000	0.670	
22.12	3.910	0.001	0.073	186.504	0.000	0.624	
23.12	3.234	0.002	0.081	186.395	0.000	0.494	
24.12	3.450	0.003	0.098	186.688	0.000	0.617	
25.12	3.648	0.001	0.107	186.376	0.000	0.376	
26.12	2.796	0.000	0.083	186.945	0.000	0.509	
27.12	2.737	0.000	0.087	186.569	0.000	0.418	
28.12	2.994	0.002	0.079	186.694	0.000	X	
29.12	3.008	0.001	0.075	186.641	0.000	0.506	
30.12	2.586	0.000	0.080	186.292	0.000	0.475	
31.12	2.555	0.000	0.085	186.845	0.000	0.456	
min	2.555	0.000	0.071	185.944	0.000	0.352	
max	4.628	1.715	0.113	186.989	0.016	0.764	
MMV	3.306	0.057	0.090	186.596	0.001	0.530	
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data							