

Menesine ataskaita: 01.2025



UAB Gren Klaipeda		sugeneruota: 1.02.2025				
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.01	13.379	7.655	7.936	0.004	0.208	0.022
2.01	12.571	7.679	5.945	0.009	0.181	0.019
3.01	11.627	7.737	6.608	0.003	0.078	0.033
4.01	10.994	7.711	6.453	0.000	0.042	0.020
5.01	10.576	7.674	5.465	0.008	0.017	0.012
6.01	10.727	7.687	6.687	0.007	0.008	0.068
7.01	12.447	7.597	4.960	0.014	0.168	0.016
8.01	11.511	7.706	9.182	0.003	0.076	0.042
9.01	11.748	7.644	6.987	0.001	0.109	0.021
10.01	10.567	7.693	6.244	0.000	0.041	0.024
11.01	10.832	7.629	8.544	0.007	0.103	0.038
12.01	10.323	7.729	6.895	0.006	0.023	0.039
13.01	11.446	7.753	6.248	0.005	0.119	0.020
14.01	11.959	7.724	6.069	0.002	0.705	0.016
15.01	11.173	7.705	10.124	0.007	0.030	0.017
16.01	12.004	7.725	7.595	0.054	0.080	0.041
17.01	11.971	7.766	7.092	0.068	0.092	0.028
18.01	13.837	7.633	7.076	0.005	0.305	0.036
19.01	12.978	7.668	5.124	0.010	0.260	0.022
20.01	12.357	7.666	6.752	0.044	0.230	0.029
21.01	11.721	7.680	6.683	0.005	0.168	0.067
22.01	12.664	7.648	7.585	0.012	0.288	0.039
23.01	11.776	7.694	13.558	0.946	0.198	0.052
24.01	11.374	7.726	10.913	0.529	0.102	0.026
25.01	13.258	7.649	6.516	0.013	0.378	0.015
26.01	13.270	7.626	10.155	0.026	0.710	0.007
27.01	14.878	7.567	6.651	0.003	0.526	0.012
28.01	16.948	7.534	9.198	0.015	0.469	0.004
29.01	17.945	7.498	7.160	0.341	0.502	0.001
30.01	15.506	7.551	8.975	0.142	0.397	0.023
31.01	15.399	7.535	9.558	0.018	0.481	0.032
min	10.323	7.498	4.960	0.000	0.008	0.001
max	17.945	7.766	13.558	0.946	0.710	0.068
MMV	12.573	7.661	7.579	0.074	0.229	0.027
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 01.2025



	UAB Gren Klaipeda						sugeneruota: 1.02.2025
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h	
1.01	0.075	0.000	135.404	0.050	0.703	231764.20	
2.01	0.073	0.000	136.058	0.084	0.483	231540.70	
3.01	0.072	0.000	135.703	0.002	0.499	231870.67	
4.01	0.067	0.003	135.921	0.004	0.512	229923.42	
5.01	0.068	0.000	135.699	0.001	0.501	229599.50	
6.01	0.067	0.000	135.850	0.000	0.438	227738.35	
7.01	0.071	0.000	135.586	0.060	0.451	232825.14	
8.01	0.072	0.000	135.705	0.028	0.507	233062.18	
9.01	0.077	0.000	135.707	0.004	0.484	232662.51	
10.01	0.072	0.000	136.203	0.004	0.482	230809.60	
11.01	0.075	0.000	135.613	0.011	0.546	233033.43	
12.01	0.069	0.000	135.393	0.000	0.485	232330.79	
13.01	0.071	0.000	135.653	0.012	0.469	232655.70	
14.01	0.078	0.000	136.101	0.027	0.440	233565.75	
15.01	0.078	0.000	135.818	0.010	0.458	234002.51	
16.01	0.078	0.000	135.589	0.026	0.502	232076.56	
17.01	0.075	0.000	135.310	0.024	0.449	231519.29	
18.01	0.082	0.000	135.853	0.056	0.422	235276.48	
19.01	0.078	0.000	135.589	0.028	0.518	235559.18	
20.01	0.073	0.000	135.499	0.026	0.468	236400.89	
21.01	0.072	0.000	135.914	0.008	0.440	236123.39	
22.01	0.073	0.000	135.491	0.027	0.460	236883.35	
23.01	0.072	0.000	135.425	0.016	0.476	235571.79	
24.01	0.080	0.000	135.937	0.026	0.466	233267.07	
25.01	0.088	0.000	136.255	0.013	0.451	237137.20	
26.01	0.083	0.029	135.163	0.050	0.455	236836.42	
27.01	0.082	0.000	135.353	0.110	0.493	236779.00	
28.01	0.082	0.000	135.410	0.201	0.456	239151.25	
29.01	0.083	0.000	135.882	0.173	0.498	238763.45	
30.01	0.077	0.000	135.923	0.213	0.537	237498.39	
31.01	0.077	0.000	135.592	0.330	0.468	239535.01	
min	0.067	0.000	135.163	0.000	0.422	227738.35	
max	0.088	0.029	136.255	0.330	0.703	239535.01	
MMV	0.075	0.001	135.697	0.052	0.485	234056.67	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 01.2025



	UAB Gren Klaipeda			sugeneruota: 1.02.2025		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.01	50.850	1018.577	6.788	998.162	1018.381	8.650
2.01	49.289	1011.937	6.601	992.319	1028.551	6.383
3.01	48.293	1013.981	6.672	994.727	1011.993	7.143
4.01	47.583	1023.104	7.107	1004.166	1011.056	6.964
5.01	46.956	1025.422	7.237	1005.562	1002.479	5.844
6.01	47.003	1016.026	7.156	996.540	995.505	7.249
7.01	49.095	1017.023	6.905	994.606	1014.379	5.290
8.01	47.962	1016.394	7.090	995.368	999.177	10.033
9.01	48.569	1019.848	7.109	999.654	989.821	7.570
10.01	46.491	1010.854	7.108	990.688	995.982	6.765
11.01	47.092	1016.532	7.457	996.791	986.618	9.328
12.01	46.619	1036.771	7.103	1017.365	995.846	7.421
13.01	48.549	1052.684	7.125	1031.701	989.729	6.733
14.01	49.013	1039.014	7.134	1017.311	995.565	6.528
15.01	48.025	1042.422	7.230	1020.626	996.950	11.128
16.01	49.198	1047.036	7.103	1025.640	999.604	8.249
17.01	49.198	1047.481	7.034	1026.109	993.994	7.678
18.01	52.135	1046.509	6.988	1024.833	1005.042	7.669
19.01	50.751	1043.947	6.770	1023.355	1019.297	5.485
20.01	49.922	1041.864	6.908	1021.220	1005.188	7.315
21.01	48.793	1035.345	7.005	1015.077	1000.967	7.201
22.01	50.147	1033.985	7.014	1012.805	1019.628	8.264
23.01	48.828	1026.370	6.849	1006.425	994.015	15.007
24.01	48.039	1028.823	7.065	1007.505	1008.187	11.941
25.01	50.956	1026.290	7.020	1004.728	1024.952	7.025
26.01	50.828	1026.788	7.023	1005.270	1021.362	11.116
27.01	52.919	1022.944	6.804	1001.181	1015.806	7.152
28.01	55.902	1021.900	6.602	999.812	995.511	10.061
29.01	57.117	1020.626	6.362	999.233	1020.492	7.757
30.01	54.136	1030.675	6.829	1009.802	1010.087	9.801
31.01	54.027	1034.744	7.046	1013.774	1001.506	10.450
min	46.491	1010.854	6.362	990.688	986.618	5.290
max	57.117	1052.684	7.457	1031.701	1028.551	15.007
MMV	49.816	1028.900	6.976	1008.142	1005.409	8.232
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 01.2025



	UAB Gren Klaipeda						sugeneruota: 1.02.2025
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.01	0.005	0.037	0.074	176.296	0.010	0.607	
2.01	0.011	0.032	0.072	177.016	0.047	0.293	
3.01	0.003	0.054	0.071	176.534	0.000	0.321	
4.01	0.000	0.033	0.060	176.923	0.002	0.334	
5.01	0.010	0.020	0.062	176.664	0.000	0.319	
6.01	0.009	0.113	0.062	176.836	0.000	0.224	
7.01	0.017	0.026	0.067	176.515	0.021	0.239	
8.01	0.003	0.071	0.069	176.677	0.008	0.322	
9.01	0.001	0.036	0.078	176.698	0.000	0.288	
10.01	0.000	0.039	0.070	177.258	0.000	0.289	
11.01	0.009	0.063	0.073	176.651	0.003	0.372	
12.01	0.007	0.065	0.064	176.216	0.000	0.306	
13.01	0.007	0.033	0.068	176.618	0.004	0.278	
14.01	0.002	0.026	0.078	177.216	0.007	0.228	
15.01	0.009	0.029	0.079	176.847	0.000	0.257	
16.01	0.068	0.069	0.079	176.561	0.007	0.322	
17.01	0.085	0.047	0.074	176.181	0.003	0.247	
18.01	0.006	0.060	0.085	176.957	0.010	0.197	
19.01	0.013	0.037	0.080	176.499	0.002	0.347	
20.01	0.055	0.048	0.071	176.395	0.001	0.275	
21.01	0.007	0.112	0.069	176.919	0.000	0.232	
22.01	0.015	0.065	0.071	176.442	0.002	0.253	
23.01	1.182	0.086	0.070	176.249	0.001	0.286	
24.01	0.661	0.043	0.083	176.951	0.008	0.269	
25.01	0.016	0.025	0.097	177.443	0.000	0.234	
26.01	0.032	0.012	0.088	176.066	0.028	0.239	
27.01	0.004	0.020	0.084	176.324	0.051	0.289	
28.01	0.019	0.006	0.085	176.443	0.093	0.227	
29.01	0.426	0.001	0.086	177.018	0.066	0.288	
30.01	0.178	0.039	0.077	177.089	0.146	0.351	
31.01	0.022	0.053	0.075	176.742	0.283	0.245	
min	0.000	0.001	0.060	176.066	0.000	0.197	
max	1.182	0.113	0.097	177.443	0.283	0.607	
MMV	0.093	0.045	0.075	176.685	0.026	0.290	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							