

Menesine ataskaita: 02.2025



	UAB Gren Klaipeda						sugeneruota: 11.02.2025
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.02	11.358	7.765	7.036	0.004	0.138	0.017	
2.02	11.798	7.720	6.835	0.007	0.115	0.009	
3.02	11.701	7.653	5.339	0.004	0.128	0.012	
4.02	10.857	7.791	6.665	0.001	0.031	0.018	
5.02	11.117	7.779	8.643	0.265	0.036	0.025	
6.02	10.753	7.775	8.333	0.026	0.026	0.045	
7.02	10.703	7.801	7.211	0.002	0.027	0.050	
8.02	10.681	7.794	8.677	0.003	0.008	0.034	
9.02	10.714	7.767	6.222	0.128	0.016	0.007	
10.02	11.779	7.710	6.011	0.485	0.060	0.039	
min	10.681	7.653	5.339	0.001	0.008	0.007	
max	11.798	7.801	8.677	0.485	0.138	0.050	
MMV	11.147	7.755	7.098	0.093	0.058	0.026	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 02.2025



	UAB Gren Klaipeda						sugeneruota: 11.02.2025
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.		Nm3/h
1.02	0.068	0.000	135.678	0.016	0.553		232042.12
2.02	0.070	0.000	135.698	0.025	0.464		232437.98
3.02	0.074	0.000	135.944	0.009	0.444		233269.07
4.02	0.070	0.000	135.956	0.003	0.440		231930.37
5.02	0.067	0.000	135.662	0.005	0.468		233113.50
6.02	0.068	0.000	135.788	0.002	0.431		232468.93
7.02	0.074	0.000	135.606	0.006	0.495		230706.39
8.02	0.069	0.019	135.427	0.016	0.505		223145.95
9.02	0.066	0.000	135.507	0.002	0.410		222519.89
10.02	0.067	0.000	135.560	0.016	X		231578.56
min	0.066	0.000	135.427	0.002	0.410		222519.89
max	0.074	0.019	135.956	0.025	0.553		233269.07
MMV	0.069	0.002	135.682	0.010	0.466		230321.34
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 02.2025



	UAB Gren Klaipeda			sugeneruota: 11.02.2025		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.02	48.010	1040.934	6.886	1021.061	1029.898	7.625
2.02	49.123	1040.544	6.853	1020.185	1036.876	7.389
3.02	48.938	1041.777	7.187	1021.350	1025.166	5.685
4.02	47.639	1046.322	7.211	1024.846	1007.174	7.226
5.02	47.895	1049.089	7.144	1027.236	1016.492	9.435
6.02	47.564	1057.013	7.078	1035.183	1016.367	9.092
7.02	47.352	1062.925	7.111	1042.637	1012.026	7.804
8.02	47.466	1059.630	6.878	1039.887	995.077	9.469
9.02	47.485	1056.090	6.743	1035.955	1010.252	6.711
10.02	49.284	1055.783	6.845	1037.185	1017.453	6.489
min	47.352	1040.544	6.743	1020.185	995.077	5.685
max	49.284	1062.925	7.211	1042.637	1036.876	9.469
MMV	48.076	1051.011	6.993	1030.553	1016.679	7.693
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 02.2025



	UAB Gren Klaipeda						sugeneruota: 11.02.2025
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.02	0.005	0.028	0.064	176.562	0.004	0.406	
2.02	0.008	0.016	0.067	176.596	0.001	0.272	
3.02	0.005	0.019	0.072	177.020	0.000	0.235	
4.02	0.002	0.031	0.066	176.996	0.000	0.232	
5.02	0.331	0.041	0.061	176.615	0.001	0.278	
6.02	0.032	0.075	0.064	176.732	0.000	0.231	
7.02	0.003	0.083	0.072	176.510	0.002	0.327	
8.02	0.003	0.056	0.065	176.204	0.015	0.347	
9.02	0.159	0.012	0.061	176.259	0.000	0.209	
10.02	0.606	0.064	0.061	176.418	0.000	X	
min	0.002	0.012	0.061	176.204	0.000	0.209	
max	0.606	0.083	0.072	177.020	0.015	0.406	
MMV	0.116	0.043	0.065	176.590	0.002	0.279	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							