

Menesine ataskaita: 02.2025



	UAB Gren Klaipeda						sugeneruota: 24.02.2025
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc	
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	
1.02	11.358	7.765	7.036	0.004	0.138	0.017	
2.02	11.798	7.720	6.835	0.007	0.115	0.009	
3.02	11.701	7.653	5.339	0.004	0.128	0.012	
4.02	10.857	7.791	6.665	0.001	0.031	0.018	
5.02	11.117	7.779	8.643	0.265	0.036	0.025	
6.02	10.753	7.775	8.333	0.026	0.026	0.045	
7.02	10.703	7.801	7.211	0.002	0.027	0.050	
8.02	10.681	7.794	8.677	0.003	0.008	0.034	
9.02	10.714	7.767	6.222	0.128	0.016	0.007	
10.02	11.779	7.710	6.011	0.485	0.060	0.039	
11.02	11.938	7.731	7.531	0.593	0.073	0.039	
12.02	12.332	7.798	10.395	0.840	0.101	0.037	
13.02	X	X	X	X	X	X	
14.02	11.103	7.696	8.630	0.003	0.033	0.035	
15.02	10.900	7.697	6.840	0.001	0.011	0.063	
16.02	11.522	7.760	7.573	0.016	0.030	0.037	
17.02	10.998	7.735	5.901	0.008	0.015	0.033	
18.02	10.873	7.759	7.593	0.007	0.008	0.051	
19.02	10.722	7.826	6.819	0.004	0.005	0.025	
20.02	11.455	7.767	10.750	0.003	0.016	0.017	
21.02	10.863	7.786	9.017	0.155	0.007	0.081	
22.02	11.503	7.788	10.416	0.006	0.017	0.068	
23.02	11.679	7.710	8.346	0.011	0.013	0.031	
min	10.681	7.653	5.339	0.001	0.005	0.007	
max	12.332	7.826	10.750	0.840	0.138	0.081	
MMV	11.264	7.752	7.917	0.120	0.043	0.035	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							

Menesine ataskaita: 02.2025



	UAB Gren Klaipeda sugeneruota: 24.02.2025					
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.02	0.068	0.000	135.678	0.016	0.553	232042.12
2.02	0.070	0.000	135.698	0.025	0.464	232437.98
3.02	0.074	0.000	135.944	0.009	0.444	233269.07
4.02	0.070	0.000	135.956	0.003	0.440	231930.37
5.02	0.067	0.000	135.662	0.005	0.468	233113.50
6.02	0.068	0.000	135.788	0.002	0.431	232468.93
7.02	0.074	0.000	135.606	0.006	0.495	230706.39
8.02	0.069	0.019	135.427	0.016	0.505	223145.95
9.02	0.066	0.000	135.507	0.002	0.410	222519.89
10.02	0.067	0.000	135.560	0.016	X	231578.56
11.02	0.064	0.000	135.950	0.014	X	234938.51
12.02	0.065	0.000	135.594	0.009	0.421	234255.64
13.02	X	X	X	X	0.429	223474.12
14.02	0.072	0.000	135.632	0.019	0.395	234200.35
15.02	0.073	0.000	135.933	0.003	0.429	233924.54
16.02	0.073	0.000	135.664	0.011	0.425	236478.14
17.02	0.074	0.000	135.607	0.011	0.409	231825.56
18.02	0.070	0.000	135.634	0.001	0.425	232335.89
19.02	0.074	0.000	135.567	0.001	X	232416.64
20.02	0.079	0.000	135.948	0.013	X	235304.07
21.02	0.073	0.000	135.819	0.008	2.226	229693.00
22.02	0.072	0.000	135.716	0.016	2.320	234954.06
23.02	0.077	0.000	135.832	0.013	2.348	234868.12
min	0.064	0.000	135.427	0.001	0.395	222519.89
max	0.079	0.019	135.956	0.025	2.348	236478.14
MMV	0.071	0.001	135.734	0.010	0.771	231820.79
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 02.2025



	UAB Gren Klaipeda			sugeneruota: 24.02.2025		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.02	48.010	1040.934	6.886	1021.061	1029.898	7.625
2.02	49.123	1040.544	6.853	1020.185	1036.876	7.389
3.02	48.938	1041.777	7.187	1021.350	1025.166	5.685
4.02	47.639	1046.322	7.211	1024.846	1007.174	7.226
5.02	47.895	1049.089	7.144	1027.236	1016.492	9.435
6.02	47.564	1057.013	7.078	1035.183	1016.367	9.092
7.02	47.352	1062.925	7.111	1042.637	1012.026	7.804
8.02	47.466	1059.630	6.878	1039.887	995.077	9.469
9.02	47.485	1056.090	6.743	1035.955	1010.252	6.711
10.02	49.284	1055.783	6.845	1037.185	1017.453	6.489
11.02	49.480	1056.462	7.106	1037.489	1001.167	8.201
12.02	50.017	1049.604	6.724	1030.072	1010.061	11.446
13.02	49.318	1039.340	X	1019.615	1015.209	X
14.02	47.985	1039.028	7.171	1018.103	1021.827	9.418
15.02	47.596	1038.500	7.099	1017.303	1010.634	7.386
16.02	48.631	1039.236	6.888	1018.956	1018.623	8.236
17.02	47.798	1039.010	7.032	1017.085	1035.431	6.347
18.02	47.668	1041.252	7.008	1020.076	1013.830	8.259
19.02	47.469	1048.709	6.944	1027.128	1038.436	7.377
20.02	48.654	1053.092	7.010	1031.994	1008.476	11.817
21.02	47.544	1050.334	7.401	1029.575	1015.959	9.823
22.02	48.605	1047.233	7.137	1025.142	1018.589	11.408
23.02	48.950	1046.436	7.121	1024.031	1018.120	9.106
min	47.352	1038.500	6.724	1017.085	995.077	5.685
max	50.017	1062.925	7.401	1042.637	1038.436	11.817
MMV	48.281	1047.755	7.030	1027.048	1017.094	8.606
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down						

Menesine ataskaita: 02.2025



	UAB Gren Klaipeda						sugeneruota: 24.02.2025
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc	
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.02	0.005	0.028	0.064	176.562	0.004	0.406	
2.02	0.008	0.016	0.067	176.596	0.001	0.272	
3.02	0.005	0.019	0.072	177.020	0.000	0.235	
4.02	0.002	0.031	0.066	176.996	0.000	0.232	
5.02	0.331	0.041	0.061	176.615	0.001	0.278	
6.02	0.032	0.075	0.064	176.732	0.000	0.231	
7.02	0.003	0.083	0.072	176.510	0.002	0.327	
8.02	0.003	0.056	0.065	176.204	0.015	0.347	
9.02	0.159	0.012	0.061	176.259	0.000	0.209	
10.02	0.606	0.064	0.061	176.418	0.000	X	
11.02	0.742	0.065	0.055	177.011	0.000	X	
12.02	1.050	0.061	0.059	176.451	0.000	0.213	
13.02	X	X	X	X	X	0.179	
14.02	0.004	0.059	0.069	176.585	0.001	0.167	
15.02	0.001	0.105	0.072	176.932	0.000	0.219	
16.02	0.020	0.062	0.071	176.551	0.001	0.216	
17.02	0.010	0.055	0.072	176.500	0.001	0.191	
18.02	0.008	0.085	0.067	176.517	0.000	0.217	
19.02	0.005	0.041	0.073	176.402	0.000	X	
20.02	0.004	0.028	0.082	176.951	0.000	X	
21.02	0.194	0.135	0.071	176.903	0.000	2.852	
22.02	0.008	0.113	0.069	176.703	0.000	2.994	
23.02	0.014	0.052	0.077	176.853	0.001	3.034	
min	0.001	0.012	0.055	176.204	0.000	0.167	
max	1.050	0.135	0.082	177.020	0.015	3.034	
MMV	0.150	0.058	0.068	176.675	0.001	0.722	
- = Out of op < = <2/3 X = no daily classing N = No Data M = Maintenance S = Fault D = >DLV A = Start-up/shut down							