

Menesine ataskaita: 04.2025[illegible]

Menesine ataskaita: 04.2025

	UAB Gren Klaipeda				sugeneruota: 1.05.2025	
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.04	0.084	0.000	136.490	0.167	0.649	231480.32
2.04	0.089	0.000	135.359	0.274	0.655	230683.06
3.04	0.084	0.000	135.914	0.407	0.693	229533.01
4.04	0.091	0.000	137.272	0.216	0.806	227163.89
5.04	0.091	0.000	139.246	0.126	0.805	223596.51
6.04	0.074	0.000	139.263	0.017	0.763	223024.04
7.04	0.084	0.000	139.411	0.052	0.737	223530.85
8.04	0.069	0.000	139.818	0.189	0.829	222397.64
9.04	0.063	0.000	139.290	0.397	0.741	221919.76
10.04	0.064	0.000	139.173	0.159	0.797	225118.20
11.04	0.071	0.000	135.403	0.400	0.745	225423.14
12.04	0.063	0.000	135.596	0.345	0.831	221199.92
13.04	0.065	0.000	135.357	0.701	0.673	228233.43
14.04	0.064	0.000	135.800	0.713	0.697	230794.85
15.04	0.064	0.000	135.218	0.709	0.754	213091.75
16.04	0.063	0.000	135.336	0.827	0.734	223785.06
17.04	0.059	0.000	136.034	0.826	0.792	219258.31
18.04	0.058	0.000	135.305	0.890	0.737	220755.20
19.04	0.058	0.000	135.358	0.902	0.730	228576.98
20.04	0.060	0.000	135.461	0.894	0.906	226217.54
21.04	0.060	0.000	135.715	0.857	0.500	226476.26
22.04	0.058	0.000	135.407	0.911	X	226815.26
23.04	0.060	0.000	135.494	0.895	0.423	222667.42
24.04	0.062	0.000	135.887	1.027	0.717	224531.60
25.04	0.060	0.000	135.502	0.954	1.010	224292.48
26.04	0.057	0.000	135.348	0.858	0.953	221047.20
27.04	0.058	0.000	135.258	0.931	0.990	225731.92
28.04	0.061	0.000	135.854	0.955	0.830	227653.18
29.04	0.059	0.000	135.609	0.679	0.888	228984.51
30.04	0.073	0.000	135.178	0.400	1.018	231193.29
min	0.057	0.000	135.178	0.017	0.423	213091.75
max	0.091	0.000	139.818	1.027	1.018	231480.32
MMV	0.067	0.000	136.378	0.589	0.763	225172.59
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data						

Menesine ataskaita: 04.2025

	UAB Gren Klaipeda			sugeneruota: 1.05.2025		
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.04	55.523	1044.614	7.408	1023.246	1089.173	3.530
2.04	56.169	1047.760	7.542	1025.857	1075.705	1.958
3.04	56.137	1046.672	7.185	1024.201	1106.923	1.239
4.04	55.469	1036.520	7.385	1016.133	1088.384	0.881
5.04	53.556	1030.132	7.435	1011.430	1082.627	0.678
6.04	48.037	1037.420	7.326	1018.203	1090.544	2.645
7.04	49.721	1038.242	7.362	1017.323	1073.265	3.010
8.04	50.416	1041.946	7.773	1020.798	1089.032	2.395
9.04	50.367	1034.729	7.551	1013.366	1101.141	4.177
10.04	49.970	1034.100	7.282	1013.336	1072.617	4.318
11.04	51.870	1026.824	7.835	1004.374	1096.066	4.037
12.04	49.229	1032.260	7.834	1010.584	1069.728	5.487
13.04	53.717	1033.209	7.278	1008.665	1095.203	5.208
14.04	54.746	1029.398	7.229	1007.844	1089.630	7.002
15.04	52.176	1034.076	7.657	1011.843	1072.822	6.624
16.04	52.030	1032.396	7.654	1011.171	1095.439	5.504
17.04	51.183	1034.996	7.534	1011.118	1076.275	6.112
18.04	52.628	1030.517	7.263	1007.405	1094.781	4.792
19.04	54.116	1027.608	7.109	1007.220	1119.611	4.913
20.04	52.802	1028.314	7.638	1007.015	1102.189	5.724
21.04	53.181	1028.706	7.561	1008.453	1088.203	6.559
22.04	53.748	1032.713	7.247	1012.664	1089.594	5.275
23.04	51.226	1037.667	7.954	1015.478	1071.557	7.276
24.04	52.106	1034.481	7.726	1013.405	1084.188	5.270
25.04	52.342	1037.336	7.693	1017.927	1067.087	6.804
26.04	51.118	1044.592	7.628	1024.292	1088.911	5.133
27.04	53.461	1049.743	7.303	1028.507	1093.560	4.898
28.04	52.819	1046.254	7.351	1024.100	1071.209	5.454
29.04	51.124	1038.689	7.305	1016.057	1090.247	4.705
30.04	52.814	1037.095	7.087	1015.935	1051.627	6.159
min	48.037	1026.824	7.087	1004.374	1051.627	0.678
max	56.169	1049.743	7.954	1028.507	1119.611	7.276
MMV	52.460	1036.300	7.471	1014.933	1085.912	4.592

- = Out of op < = <2/3
M = Maintenance
D = >DLV

X = no daily classing
S = Fault
A = Start-up/shut down

N = No Data

Menesine ataskaita: 04.2025

	UAB Gren Klaipeda			sugeneruota: 1.05.2025		
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.04	1.963	0.015	0.086	178.072	0.076	0.497
2.04	0.000	0.005	0.093	176.724	0.148	0.499
3.04	0.017	0.004	0.085	177.281	0.307	0.567
4.04	0.003	0.017	0.097	179.054	0.113	0.725
5.04	0.017	0.053	0.097	181.502	0.033	0.729
6.04	0.007	0.031	0.072	181.258	0.003	0.699
7.04	0.000	0.006	0.087	181.507	0.013	0.654
8.04	0.001	0.008	0.060	182.211	0.124	0.773
9.04	0.019	0.020	0.051	181.449	0.323	0.650
10.04	0.000	0.053	0.055	181.196	0.064	0.741
11.04	0.007	0.027	0.063	176.707	0.308	0.635
12.04	0.004	0.002	0.051	176.844	0.284	0.777
13.04	0.024	0.004	0.055	176.504	0.702	0.542
14.04	0.007	0.027	0.052	177.096	0.717	0.571
15.04	0.016	0.057	0.052	176.404	0.709	0.656
16.04	0.024	0.056	0.050	176.546	0.869	0.627
17.04	0.004	0.033	0.044	177.344	0.872	0.723
18.04	0.021	0.031	0.042	176.377	0.960	0.642
19.04	0.013	0.022	0.043	176.460	0.975	0.626
20.04	0.001	0.072	0.045	176.731	0.958	0.874
21.04	0.006	0.036	0.044	177.043	0.909	0.280
22.04	0.012	0.009	0.042	176.560	0.985	X
23.04	0.000	0.059	0.045	176.830	0.956	0.167
24.04	0.010	0.038	0.047	177.274	1.137	0.600
25.04	0.017	0.018	0.045	176.783	1.039	1.032
26.04	0.000	0.020	0.040	176.506	0.913	0.960
27.04	0.007	0.009	0.042	176.363	1.013	1.015
28.04	0.022	0.034	0.047	177.113	1.046	0.781
29.04	0.010	0.013	0.045	176.717	0.677	0.872
30.04	0.029	0.021	0.070	176.163	0.314	1.062
min	0.000	0.002	0.040	176.163	0.003	0.167
max	1.963	0.072	0.097	182.211	1.137	1.062
MMV	0.075	0.027	0.058	177.821	0.585	0.675

- = Out of op < = <2/3
M = Maintenance
D = >DLV

X = no daily classing
S = Fault
A = Start-up/shut down

N = No Data