

Menesine ataskaita: 06.2025



	UAB Gren Klaipeda			sugeneruota: 1.07.2025		
	KLAIP_L1 H2O Day_Conc	KLAIP_L1 CO2 Day_Conc	KLAIP_L1 CO Day_Conc	KLAIP_L1 SO2 Day_Conc	KLAIP_L1 NH3 Day_Conc	KLAIP_L1 HCL Day_Conc
Diena	Vol%	Vol%	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.06	14.459	7.504	14.626	0.000	1.855	0.037
2.06	15.547	7.446	9.096	0.010	2.598	0.032
3.06	13.261	7.637	5.854	0.015	1.248	0.073
4.06	14.144	7.618	8.798	0.000	0.651	0.058
5.06	14.871	7.584	8.988	0.406	0.521	0.111
6.06	13.472	7.565	12.097	0.016	0.349	0.072
7.06	16.651	7.515	7.827	0.010	0.521	0.010
8.06	16.158	7.522	7.022	0.135	0.426	0.017
9.06	15.608	7.558	6.096	0.008	0.489	0.016
10.06	15.359	7.599	4.240	0.024	0.464	0.017
11.06	16.424	7.554	6.354	0.267	0.525	0.008
12.06	15.123	7.638	8.843	0.227	0.596	0.023
13.06	15.450	7.669	6.845	0.014	0.881	0.035
14.06	16.123	7.578	8.231	0.000	1.271	0.014
15.06	16.154	7.536	9.145	0.011	1.083	0.018
16.06	16.352	7.542	6.441	0.011	1.033	0.024
17.06	15.740	7.716	4.489	0.000	0.928	0.037
18.06	15.873	7.609	5.453	0.006	0.752	0.018
19.06	15.543	7.638	5.198	0.033	0.657	0.014
20.06	16.602	7.642	5.383	0.174	0.880	0.002
21.06	16.417	7.643	7.516	0.198	0.943	0.010
22.06	16.966	7.574	6.119	0.050	1.151	0.002
23.06	16.624	7.609	8.685	0.203	1.058	0.009
24.06	16.832	7.535	5.972	0.286	0.860	0.023
25.06	17.605	7.543	5.242	0.519	0.891	0.020
26.06	15.420	7.564	11.291	0.229	0.710	0.056
27.06	16.533	7.535	10.436	0.423	1.134	0.008
28.06	16.195	7.606	10.175	0.501	1.241	0.021
29.06	14.923	7.584	13.700	0.058	2.621	0.033
30.06	X	-	-	-	-	-
min	13.261	7.446	4.240	0.000	0.349	0.002
max	17.605	7.716	14.626	0.519	2.621	0.111
MMV	15.716	7.581	7.918	0.133	0.971	0.028

- = Out of op < = <2/3
M = Maintenance
D = >DLV

X = no daily classing
S = Fault
A = Start-up/shut down

N = No Data

Menesine ataskaita: 06.2025



	UAB Gren Klaipeda				sugeneruota: 1.07.2025	
	KLAIP_L1 HF Day_Conc	KLAIP_L1 CH4 Day_Conc	KLAIP_L1 NOx Day_Conc	KLAIP_L1 TOC Day_Conc	KLAIP_L1 DULKES Day_Conc	KLAIP_L1 SRAUTAS Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	Nm3/h
1.06	0.089	0.000	135.976	0.137	0.785	226905.37
2.06	0.077	0.000	136.746	0.220	0.766	237829.37
3.06	0.076	0.000	135.574	0.207	0.777	231133.51
4.06	0.081	0.000	135.960	0.223	0.881	233438.87
5.06	0.080	0.000	135.345	0.264	0.958	233938.07
6.06	0.074	0.000	135.354	0.237	0.878	208060.76
7.06	0.073	0.000	135.490	0.417	0.783	238492.76
8.06	0.070	0.000	135.721	0.354	0.882	236818.32
9.06	0.072	0.000	135.662	0.274	0.919	233768.76
10.06	0.085	0.000	135.687	0.268	0.942	234545.81
11.06	0.084	0.000	136.044	0.268	0.740	238024.85
12.06	0.088	0.000	135.604	0.139	0.810	233936.51
13.06	0.074	0.000	135.847	0.432	0.795	235156.20
14.06	0.062	0.000	135.613	1.016	0.775	234248.67
15.06	0.059	0.000	135.485	1.013	0.751	236650.23
16.06	0.063	0.000	135.577	0.858	0.779	236258.64
17.06	0.076	0.000	135.552	0.272	0.891	233963.68
18.06	0.079	0.000	135.809	0.308	0.782	234537.12
19.06	0.086	0.000	135.690	0.200	0.862	228276.32
20.06	0.073	0.000	135.503	0.197	0.837	237524.23
21.06	0.079	0.000	135.753	0.340	0.868	226966.57
22.06	0.073	0.000	135.927	0.469	0.931	237513.43
23.06	0.074	0.000	135.445	0.442	0.914	237831.37
24.06	0.076	0.000	135.507	0.485	0.957	231425.14
25.06	0.071	0.000	135.623	0.595	0.902	239715.14
26.06	0.076	0.001	135.868	0.788	0.945	229306.39
27.06	0.078	0.000	134.889	0.714	0.942	230304.35
28.06	0.080	0.000	135.565	0.455	0.833	230045.56
29.06	0.072	0.000	136.055	0.350	0.789	191675.23
30.06	-	-	-	-	-	X
min	0.059	0.000	134.889	0.137	0.740	191675.23
max	0.089	0.001	136.746	1.016	0.958	239715.14
MMV	0.076	0.000	135.684	0.412	0.851	231040.89
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data						

Menesine ataskaita: 06.2025



	UAB Gren Klaipeda				sugeneruota: 1.07.2025	
	KLAIP_L1 Kamino_T Day_Conc	KLAIP_L1 Kamino_P Day_Conc	KLAIP_L1 O2 Day_Conc	KLAIP_L1 Atmosf_P Day_Conc	KLAIP_L1 Degimo_T Day_Conc	KLAIP_L1 CO_10Min Day_Conc
Diena	°C	mbar	Vol%	mbar	°C	Nm3/h
1.06	53.144	1037.449	7.663	1013.998	986.753	16.173
2.06	54.416	1029.270	7.373	1008.587	1012.554	9.887
3.06	51.453	1034.104	7.533	1011.900	1019.009	6.288
4.06	52.749	1034.418	6.805	1010.932	1035.635	9.634
5.06	53.697	1028.459	6.751	1007.163	1046.027	9.839
6.06	51.657	1028.063	7.020	1006.243	1026.748	13.342
7.06	55.914	1029.368	6.593	1006.969	1057.252	8.534
8.06	55.268	1026.011	6.684	1004.304	1048.138	7.611
9.06	54.577	1025.423	6.719	1005.662	1033.055	6.560
10.06	54.403	1035.916	6.904	1013.852	1045.153	4.466
11.06	55.590	1029.752	6.778	1008.391	1019.913	6.830
12.06	54.099	1037.117	6.957	1015.766	1033.532	9.652
13.06	54.621	1046.194	7.133	1023.511	1015.634	7.386
14.06	55.422	1046.095	7.269	1023.765	1025.430	8.962
15.06	55.466	1041.425	7.175	1018.045	1025.302	9.994
16.06	55.626	1034.127	6.881	1012.779	1029.984	6.952
17.06	54.879	1035.742	7.084	1014.260	1035.632	4.742
18.06	55.031	1033.186	7.050	1011.554	1020.081	5.803
19.06	54.617	1031.389	7.038	1009.527	1027.599	5.531
20.06	55.923	1037.939	6.997	1015.581	1024.055	5.747
21.06	55.588	1038.063	6.990	1016.106	1004.814	7.841
22.06	56.368	1036.458	6.898	1014.403	1024.821	6.550
23.06	55.814	1028.813	6.967	1005.605	1009.207	9.443
24.06	55.967	1018.543	6.889	998.431	1029.174	6.393
25.06	56.829	1021.012	6.915	999.490	1042.727	5.576
26.06	54.393	1032.835	7.536	1009.855	1026.404	12.418
27.06	55.708	1028.118	7.316	1006.724	1008.850	11.473
28.06	55.345	1033.561	7.084	1011.593	973.667	11.148
29.06	53.431	1029.801	8.163	1007.755	942.502	20.822
30.06	X	X	X	X	-	-
min	51.453	1018.543	6.593	998.431	942.502	4.466
max	56.829	1046.194	8.163	1023.765	1057.252	20.822
MMV	54.718	1032.701	7.111	1010.775	1021.941	8.777
- = Out of op < = <2/3 M = Maintenance D = >DLV X = no daily classing S = Fault A = Start-up/shut down N = No Data						

Menesine ataskaita: 06.2025



	UAB Gren Klaipeda				sugeneruota: 1.07.2025	
	KLAIP_L1 SO2_97% Day_Conc	KLAIP_L1 HCL_97% Day_Conc	KLAIP_L1 HF_97% Day_Conc	KLAIP_L1 NOx_97% Day_Conc	KLAIP_L1 TOC_97% Day_Conc	KLAIP_L1 DULKES_97% Day_Conc
Diena	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.	mg/m3iN.
1.06	0.000	0.062	0.094	177.406	0.026	0.699
2.06	0.012	0.053	0.075	178.332	0.084	0.670
3.06	0.018	0.122	0.074	176.775	0.067	0.698
4.06	0.000	0.097	0.084	177.044	0.083	0.868
5.06	0.507	0.185	0.082	176.288	0.129	0.975
6.06	0.019	0.120	0.071	176.316	0.115	0.858
7.06	0.013	0.017	0.070	176.523	0.326	0.711
8.06	0.169	0.029	0.064	176.819	0.244	0.857
9.06	0.010	0.026	0.068	176.724	0.144	0.913
10.06	0.030	0.028	0.090	176.806	0.134	0.947
11.06	0.334	0.014	0.088	177.276	0.136	0.645
12.06	0.283	0.038	0.094	176.705	0.027	0.754
13.06	0.017	0.059	0.070	177.096	0.358	0.728
14.06	0.000	0.024	0.049	176.895	1.124	0.689
15.06	0.014	0.029	0.044	176.697	1.122	0.655
16.06	0.013	0.041	0.052	176.718	0.917	0.701
17.06	0.000	0.061	0.073	176.723	0.150	0.864
18.06	0.007	0.029	0.078	177.043	0.185	0.703
19.06	0.041	0.023	0.091	176.869	0.083	0.818
20.06	0.217	0.003	0.069	176.682	0.073	0.782
21.06	0.247	0.017	0.079	176.989	0.276	0.829
22.06	0.062	0.003	0.069	177.205	0.391	0.921
23.06	0.254	0.015	0.069	176.600	0.355	0.892
24.06	0.358	0.039	0.073	176.662	0.412	0.952
25.06	0.649	0.033	0.064	176.865	0.558	0.866
26.06	0.287	0.094	0.071	177.290	0.812	0.929
27.06	0.529	0.013	0.076	176.036	0.713	0.921
28.06	0.626	0.035	0.080	176.775	0.370	0.774
29.06	0.073	0.056	0.066	177.481	0.225	0.698
30.06	-	-	-	-	-	-
min	0.000	0.003	0.044	176.036	0.026	0.645
max	0.649	0.185	0.094	178.332	1.124	0.975
MMV	0.166	0.047	0.073	176.882	0.333	0.804

- = Out of op < = <2/3
M = Maintenance
D = >DLV

X = no daily classing
S = Fault
A = Start-up/shut down

N = No Data