



Menesine ataskaita: 12/2025

	UAB Gren Klaipeda			sugenerouta: 12/31/2025		
	Klaip L1 H ₂ O	Klaip L1 CO ₂	Klaip L1 CO	Klaip L1 SO ₂	Klaip L1 NH ₃	Klaip L1 HCl
	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc
Diena	Vol%	Vol%	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/12/	12.46	7.82	3.89	8.91	1.18	0.11
02/12/	12.02	7.77	4.75	6.02	1.19	0.11
03/12/	12.15	7.78	3.93	9.70	1.19	0.11
04/12/	13.23	7.76	23.65	15.23	1.18	0.11
05/12/	13.63	7.82	4.73	8.99	1.19	0.12
06/12/	16.44	7.68	3.44	4.53	1.21	0.12
07/12/	14.13	7.76	3.31	4.85	1.19	0.12
08/12/	12.24	7.78	2.74	4.24	1.20	0.11
09/12/	14.29	7.73	4.29	3.23	1.40	0.12
10/12/	15.57	7.63	1.39	2.87	1.70	0.12
11/12/	15.60	7.70	2.31	2.19	1.50	0.12
12/12/	16.59	7.78	3.91	3.04	1.36	0.12
13/12/	12.33	7.75	2.78	2.45	1.21	0.11
14/12/	17.86	7.62	2.53	2.40	1.47	0.12
15/12/	14.61	7.69	2.67	2.45	1.30	0.12
16/12/	13.79	7.83	3.69	2.24	1.24	0.11
17/12/	11.33	7.87	6.61	2.46	1.16	0.11
18/12/	13.30	7.84	4.42	2.38	1.22	0.11
19/12/	11.96	7.80	5.49	2.28	1.19	0.11
20/12/	16.79	7.71	1.92	3.42	1.28	0.12
21/12/	17.95	7.68	1.29	3.12	1.35	0.12
22/12/	15.88	7.73	1.58	2.56	1.30	0.12
23/12/	12.07	7.79	4.52	4.19	1.19	0.11
24/12/	13.67	7.84	7.03	4.86	1.19	0.11
25/12/	11.15	7.78	1.55	2.86	1.17	0.11
26/12/	17.36	7.77	1.67	3.77	1.31	0.12
27/12/	17.25	7.70	1.65	3.12	1.35	0.12
28/12/	11.90	7.86	1.64	2.77	1.19	0.11
29/12/	11.28	7.86	2.06	2.27	1.17	0.11
30/12/	12.31	7.78	3.82	4.56	1.18	0.11
min	11.15	7.62	1.29	2.19	1.16	0.11
max	17.95	7.87	23.65	15.23	1.70	0.12
MMV	14.04	7.76	3.98	4.26	1.27	0.12

- = out of operation = < 2/3

M = Maintenance

G = > LV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Menesine ataskaita: 12/2025

	UAB Gren Klaipeda			sugenerouta: 12/31/2025		
	Klaip L1 HF Day Conc	Klaip L1 CH ₄ Day Conc	Klaip L1 NO _x Day Conc	Klaip L1 TOC Day Conc	Klaip L1 Dulkes Day Conc	Klaip L1 Srtas Day Conc
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Nm ³ /h
01/12/	0.07	0.00	132.15	0.32	0.05	223468.23
02/12/	0.08	0.00	132.46	0.31	0.05	222939.43
03/12/	0.08	0.00	132.41	0.29	0.05	223952.50
04/12/	0.08	0.35	131.10	0.35	0.04	223155.37
05/12/	0.08	0.00	133.27	0.35	0.05	221101.92
06/12/	0.08	0.00	133.43	0.41	0.06	224679.21
07/12/	0.08	0.00	132.94	0.33	0.06	224996.61
08/12/	0.08	0.00	132.50	0.33	0.06	222451.17
09/12/	0.08	0.00	133.34	0.35	0.07	219789.86
10/12/	0.08	0.00	133.46	0.38	0.08	227820.73
11/12/	0.08	0.00	133.16	0.49	0.10	243324.13
12/12/	0.08	0.02	133.87	0.42	0.14	226699.20
13/12/	0.07	0.00	132.76	0.29	0.11	226012.79
14/12/	0.08	0.00	133.86	0.39	0.06	226725.54
15/12/	0.08	0.00	132.72	0.28	0.07	224014.22
16/12/	0.07	0.00	132.77	0.29	0.09	223934.12
17/12/	0.08	0.00	131.18	0.38	0.09	224703.01
18/12/	0.08	0.00	131.54	0.39	0.10	223242.38
19/12/	0.07	0.00	132.73	0.33	0.10	222588.84
20/12/	0.08	0.00	133.24	0.38	0.08	223658.49
21/12/	0.08	0.00	133.93	0.35	0.07	224468.03
22/12/	0.08	0.00	133.48	0.39	0.06	222756.55
23/12/	0.07	0.00	131.17	0.29	0.11	222745.44
24/12/	0.07	0.00	128.63	0.24	0.12	226649.95
25/12/	0.07	0.00	132.41	0.27	0.09	222339.39
26/12/	0.08	0.00	134.00	0.33	0.07	224617.86
27/12/	0.08	0.00	133.96	0.39	0.07	222316.47
28/12/	0.07	0.00	132.56	0.34	0.09	219116.90
29/12/	0.07	0.00	132.11	0.32	0.09	219801.08
30/12/	0.08	0.00	132.18	0.27	0.08	221248.24
min	0.07	0.00	128.63	0.24	0.04	219116.90
max	0.08	0.35	134.00	0.49	0.14	243324.13
MMV	0.08	0.01	132.64	0.34	0.08	224177.26

- = out of operation = < 2/3

M = Maintenance

G = > LV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Mensina ataskaita: 12/2025

	UAB Gren Klaipeda				sugenerouta: 12/31/2025	
	Klaip L1 Kamino T Day Conc	Klaip L1 Kamino P Day Conc	Klaip L1 O ₂ Day Conc	Klaip L1 Atmosf P Day Conc	Klaip L1 Degimo T Day Conc	Klaip L1 CO 10 Day Conc
	Diena	°C	mbar	Vol%	mbar	°C
01/12/	47.15	1037.13	5.94	1013.91	1027.06	4.33
02/12/	46.57	1040.49	5.98	1019.00	1020.31	5.29
03/12/	46.82	1041.25	6.00	1018.58	1053.79	4.38
04/12/	48.18	1038.66	5.89	1015.47	1041.39	24.95
05/12/	48.38	1038.61	5.97	1015.42	1054.99	5.35
06/12/	52.51	1035.43	5.75	1012.90	1067.71	3.83
07/12/	49.52	1033.26	5.88	1011.79	1063.86	3.69
08/12/	46.73	1032.41	6.00	1010.41	1074.94	3.05
09/12/	49.88	1030.76	5.93	1007.50	1050.98	4.77
10/12/	44.23	1032.63	5.83	1009.76	1075.47	1.55
11/12/	27.93	1031.40	5.83	1009.03	1081.16	2.57
12/12/	52.80	1037.13	5.78	1015.39	1061.78	4.33
13/12/	47.20	1041.25	6.03	1021.23	1071.58	3.10
14/12/	54.42	1037.44	5.71	1014.47	1051.22	2.82
15/12/	50.29	1036.00	5.96	1013.72	1070.13	2.98
16/12/	49.08	1038.74	5.83	1017.15	1067.71	4.11
17/12/	45.57	1036.86	5.98	1015.84	1027.77	7.37
18/12/	48.27	1040.78	5.84	1018.98	1048.82	4.92
19/12/	46.60	1040.24	5.88	1017.81	1036.82	6.10
20/12/	53.27	1037.54	5.63	1014.50	1070.44	2.14
21/12/	54.76	1039.38	5.57	1016.39	1073.91	1.44
22/12/	51.88	1042.67	5.70	1020.75	1064.62	1.76
23/12/	46.91	1046.46	5.90	1027.88	1048.60	5.04
24/12/	49.41	1056.83	5.67	1036.37	1038.59	7.79
25/12/	45.48	1054.83	5.89	1032.38	1086.78	1.72
26/12/	53.94	1047.21	5.61	1023.42	1100.82	1.85
27/12/	53.78	1035.27	5.72	1012.54	1089.67	1.83
28/12/	46.28	1032.26	6.02	1010.75	1095.00	1.83
29/12/	45.37	1023.71	6.02	1002.69	1062.24	2.30
30/12/	46.99	1020.31	5.95	1001.24	1069.99	4.24
min	27.93	1020.31	5.57	1001.24	1020.31	1.44
max	54.76	1056.83	6.03	1036.37	1100.82	24.95
MMV	48.34	1037.90	5.86	1015.91	1061.60	4.38
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



- = out of operation = < 2/3
M = Maintenance
G = > LV D = > DLV