



Menesine ataskaita: 01/2026

	UAB Gren Klaipeda			sugenerouta: 1/9/2026		
	Klaip L1 H ₂ O	Klaip L1 CO ₂	Klaip L1 CO	Klaip L1 SO ₂	Klaip L1 NH ₃	Klaip L1 HCl
	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc
Diena	Vol%	Vol%	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/01/	14.51	7.78	6.64	3.83	1.19	0.11
02/01/	12.08	7.74	2.03	3.53	1.18	0.11
03/01/	13.56	7.67	2.44	3.37	1.20	0.11
04/01/	12.71	7.73	3.42	2.92	1.20	0.11
05/01/	12.91	7.74	3.82	2.60	1.22	0.11
06/01/	13.93	7.71	3.98	2.69	1.25	0.11
07/01/	14.55	7.66	5.32	2.67	1.21	0.12
08/01/	15.60	7.70	6.19	2.64	1.22	0.12
min	12.08	7.66	2.03	2.60	1.18	0.11
max	15.60	7.78	6.64	3.83	1.25	0.12
MMV	13.73	7.72	4.24	3.03	1.21	0.11

- = out of operation = < 2/3

M = Maintenance

G = > LV

D = > DLV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Menesine ataskaita: 01/2026

	UAB Gren Klaipeda			sugenerouta: 1/9/2026		
	Klaip L1 HF	Klaip L1 CH ₄	Klaip L1 NO _x	Klaip L1 TOC	Klaip L1 Dulkes	Klaip L1 Srutas
	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Nm ³ /h
01/01/	0.08	0.03	126.48	0.34	0.09	230376.92
02/01/	0.08	0.00	132.56	0.29	0.08	223694.61
03/01/	0.08	0.00	132.32	0.32	0.00	226795.17
04/01/	0.08	0.00	132.74	0.32	0.00	226989.19
05/01/	0.07	0.00	132.64	0.24	0.00	228859.39
06/01/	0.08	0.00	132.27	0.26	0.02	229619.16
07/01/	0.08	0.00	132.78	0.31	0.05	230904.77
08/01/	0.08	0.00	132.53	0.33	0.09	228836.20
min	0.07	0.00	126.48	0.24	0.00	223694.61
max	0.08	0.03	132.78	0.34	0.09	230904.77
MMV	0.08	0.00	131.79	0.30	0.04	228259.43

- = out of operation = < 2/3

M = Maintenance

G = > LV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Mensina ataskaita: 01/2026

	UAB Gren Klaipeda				sugenerouta: 1/9/2026	
	Klaip L1 Kamino T Day Conc	Klaip L1 Kamino P Day Conc	Klaip L1 O ₂ Day Conc	Klaip L1 Atmosf P Day Conc	Klaip L1 Degimo T Day Conc	Klaip L1 CO 10 Day Conc
Diena	°C	mbar	Vol%	mbar	°C	mg/Nm ³
01/01/	49.89	1012.45	5.63	991.13	1065.75	7.34
02/01/	46.34	1001.51	5.89	979.16	1097.88	2.25
03/01/	48.55	1006.19	5.82	984.95	1073.35	2.72
04/01/	47.45	1014.33	5.89	993.58	1044.49	3.79
05/01/	47.98	1028.02	5.92	1006.74	1043.81	4.25
06/01/	49.52	1031.96	5.83	1011.64	1058.10	4.44
07/01/	50.36	1034.03	5.85	1013.05	1025.96	5.93
08/01/	51.66	1031.48	5.87	1013.33	1041.08	6.87
min	46.34	1001.51	5.63	979.16	1025.96	2.25
max	51.66	1034.03	5.92	1013.33	1097.88	7.34
MMV	48.97	1020.00	5.84	999.20	1056.30	4.70

- = out of operation = < 2/3

M = Maintenance

G = > LV

D = > DLV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Menesine ataskaita: 01/2026

	UAB Gren Klaipeda			sugenerouta: 1/9/2026		
	Klaip L1 SO ₂ 97% Day Conc	Klaip L1 HCl 97% Day Conc	Klaip L1 HF 97% Day Conc	Klaip L1 NO _x 97% Day Conc	Klaip L1 TOC 97% Day Conc	Klaip L1 Dulkes 97% Day Conc
	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
Diena						
01/01/	4.08	0.16	0.11	135.20	0.42	0.12
02/01/	3.88	0.17	0.11	145.69	0.37	0.10
03/01/	3.65	0.16	0.11	142.96	0.39	0.00
04/01/	3.18	0.17	0.11	144.83	0.40	0.00
05/01/	2.83	0.17	0.11	144.40	0.30	0.00
06/01/	2.89	0.16	0.11	142.29	0.32	0.03
07/01/	2.86	0.17	0.11	141.82	0.37	0.06
08/01/	2.78	0.17	0.11	139.81	0.40	0.10
min	2.78	0.16	0.11	135.20	0.30	0.00
max	4.08	0.17	0.11	145.69	0.42	0.12
MMV	3.27	0.16	0.11	142.12	0.37	0.05

- = out of operation = < 2/3
M = Maintenance
G = > LV

X = no daily classing
F = Fault
R = Replacement

N = No Data
A = Startup / shutdown

D = > DLV