



Menesine ataskaita: 01/2026

	UAB Gren Klaipeda			sugenerouta: 1/30/2026		
	Klaip L1 H ₂ O	Klaip L1 CO ₂	Klaip L1 CO	Klaip L1 SO ₂	Klaip L1 NH ₃	Klaip L1 HCl
	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc
Diena	Vol%	Vol%	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/01/	14.51	7.78	6.64	3.83	1.19	0.11
02/01/	12.08	7.74	2.03	3.53	1.18	0.11
03/01/	13.56	7.67	2.44	3.37	1.20	0.11
04/01/	12.71	7.73	3.42	2.92	1.20	0.11
05/01/	12.91	7.74	3.82	2.60	1.22	0.11
06/01/	13.93	7.71	3.98	2.69	1.25	0.11
07/01/	14.55	7.66	5.32	2.67	1.21	0.12
08/01/	15.60	7.70	6.19	2.64	1.22	0.12
09/01/	16.62	7.81	13.69	2.27	1.24	0.12
10/01/	15.02	7.74	8.81	2.25	1.21	0.12
11/01/	14.71	7.72	6.28	2.70	1.23	0.12
12/01/	15.55	7.73	5.54	2.72	1.26	0.12
13/01/	16.82	7.71	11.34	2.41	1.27	0.12
14/01/	17.00	7.70	7.50	2.50	1.33	0.12
15/01/	14.94	7.85	8.95	2.46	1.27	0.12
16/01/	14.80	7.88	9.88	2.75	1.27	0.12
17/01/	15.98	7.82	6.20	2.81	1.27	0.12
18/01/	16.34	7.80	9.03	2.19	1.32	0.12
19/01/	16.85	7.78	9.11	2.87	1.40	0.12
20/01/	17.34	7.69	11.82	2.54	1.61	0.12
21/01/	17.08	7.71	20.01	2.67	1.53	0.12
22/01/	14.85	6.59	21.75	2.53	1.48	0.15
23/01/	16.21	7.58	12.15	3.04	1.94	0.12
24/01/	17.09	7.56	7.96	3.22	2.19	0.12
25/01/	17.07	7.52	7.59	2.75	3.04	0.12
26/01/	15.05	7.49	9.72	3.01	2.00	0.12
27/01/	14.84	7.45	8.35	2.74	2.18	0.12
28/01/	15.29	7.48	6.26	3.01	2.93	0.12
29/01/	17.74	7.52	5.86	3.42	2.50	0.12
min	12.08	6.59	2.03	2.19	1.18	0.11
max	17.74	7.88	21.75	3.83	3.04	0.15
MMV	15.42	7.65	8.31	2.80	1.56	0.12

- = out of operation = < 2/3

M = Maintenance

G = > LV

D = > DLV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Menesine ataskaita: 01/2026

	UAB Gren Klaipeda			sugenerouta: 1/30/2026		
	Klaip L1 HF Day Conc	Klaip L1 CH ₄ Day Conc	Klaip L1 NO _x Day Conc	Klaip L1 TOC Day Conc	Klaip L1 Dulkes Day Conc	Klaip L1 Srutas Day Conc
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	Nm ³ /h
01/01/	0.08	0.03	126.48	0.34	0.09	230376.92
02/01/	0.08	0.00	132.56	0.29	0.08	223694.61
03/01/	0.08	0.00	132.32	0.32	0.00	226795.17
04/01/	0.08	0.00	132.74	0.32	0.00	226989.19
05/01/	0.07	0.00	132.64	0.24	0.00	228859.39
06/01/	0.08	0.00	132.27	0.26	0.02	229619.16
07/01/	0.08	0.00	132.78	0.31	0.05	230904.77
08/01/	0.08	0.00	132.53	0.33	0.09	228836.20
09/01/	0.08	0.00	132.97	0.35	0.06	229594.67
10/01/	0.08	0.00	131.30	0.35	0.09	232044.88
11/01/	0.08	0.00	133.11	0.39	0.02	231896.81
12/01/	0.08	0.00	132.83	0.43	0.03	233643.45
13/01/	0.08	0.02	129.03	0.35	0.05	231801.07
14/01/	0.08	0.00	131.16	0.29	0.04	230980.30
15/01/	0.08	0.00	131.36	0.28	0.03	230629.49
16/01/	0.08	0.00	131.94	0.29	0.04	230861.48
17/01/	0.08	0.00	130.93	0.37	0.04	232612.72
18/01/	0.08	0.00	130.86	0.38	0.04	234100.93
19/01/	0.08	0.00	132.69	0.31	0.05	229256.66
20/01/	0.08	0.00	132.11	0.33	0.04	226413.91
21/01/	0.08	0.02	118.46	0.35	0.04	228325.46
22/01/	0.08	0.23	109.43	0.43	0.06	219902.19
23/01/	0.08	0.01	131.46	0.27	0.05	233779.38
24/01/	0.08	0.00	132.18	0.42	0.05	237219.17
25/01/	0.08	0.01	133.82	0.41	0.04	237875.82
26/01/	0.08	0.00	131.54	0.33	0.06	235655.11
27/01/	0.08	0.00	133.09	0.29	0.05	235491.92
28/01/	0.08	0.00	133.28	0.29	0.05	230530.48
29/01/	0.08	0.00	133.78	0.34	0.03	229875.01
min	0.07	0.00	109.43	0.24	0.00	219902.19
max	0.08	0.23	133.82	0.43	0.09	237875.82
MMV	0.08	0.01	130.79	0.33	0.04	230640.22

- = out of operation = < 2/3

M = Maintenance

G = > LV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown



Mensina ataskaita: 01/2026

	UAB Gren Klaipeda			sugenerouta: 1/30/2026		
	Klaip L1 Kamino T Day Conc	Klaip L1 Kamino P Day Conc	Klaip L1 O ₂ Day Conc	Klaip L1 Atmosf P Day Conc	Klaip L1 Degimo T Day Conc	Klaip L1 CO 10 Day Conc
	Diena	°C	mbar	Vol%	mbar	°C
01/01/	49.89	1012.45	5.63	991.13	1065.75	7.34
02/01/	46.34	1001.51	5.89	979.16	1097.88	2.25
03/01/	48.55	1006.19	5.82	984.95	1073.35	2.72
04/01/	47.45	1014.33	5.89	993.58	1044.49	3.79
05/01/	47.98	1028.02	5.92	1006.74	1043.81	4.25
06/01/	49.52	1031.96	5.83	1011.64	1058.10	4.44
07/01/	50.36	1034.03	5.85	1013.05	1025.96	5.93
08/01/	51.66	1031.48	5.87	1013.33	1041.08	6.87
09/01/	52.85	1026.75	5.77	1007.20	1004.35	15.00
10/01/	50.79	1022.83	5.88	1002.01	1043.55	9.80
11/01/	50.41	1026.92	5.84	1006.03	1058.86	7.00
12/01/	51.59	1034.71	5.81	1013.48	1057.90	6.17
13/01/	53.11	1036.09	5.70	1016.70	1053.20	12.57
14/01/	53.28	1035.76	5.75	1015.17	1037.75	8.33
15/01/	50.86	1039.76	5.91	1017.48	1044.20	9.96
16/01/	50.78	1046.72	5.87	1025.23	1025.04	10.90
17/01/	52.31	1052.63	5.73	1031.61	1040.84	6.90
18/01/	52.81	1056.48	5.68	1035.77	1011.74	10.04
19/01/	53.40	1052.69	5.77	1032.23	1008.34	10.12
20/01/	53.97	1045.72	5.67	1025.05	1001.56	13.16
21/01/	53.55	1033.38	5.59	1013.89	1043.84	22.12
22/01/	53.43	1032.68	5.86	1011.86	1012.08	24.17
23/01/	52.03	1036.53	6.10	1014.95	1017.04	13.47
24/01/	53.30	1036.24	5.97	1016.71	1005.94	8.86
25/01/	53.30	1035.56	6.02	1013.22	1005.03	8.44
26/01/	50.78	1026.79	6.03	1005.13	1015.26	10.79
27/01/	50.56	1025.36	6.16	1003.97	983.38	9.30
28/01/	51.11	1023.37	6.13	1003.22	986.84	6.98
29/01/	54.13	1029.05	5.63	1009.75	990.37	6.52
min	46.34	1001.51	5.59	979.16	983.38	2.25
max	54.13	1056.48	6.16	1035.77	1097.88	24.17
MMV	51.38	1031.59	5.85	1010.84	1030.95	9.22
- = out of operation = < 2/3 X = no daily classing N = No Data M = Maintenance F = Fault A = Startup / shutdown G = > LV D = > DLV R = Replacement						



	UAB Gren Klaipeda			sugenerouta: 1/30/2026		
	Klaip L1	Klaip L1	Klaip L1	Klaip L1	Klaip L1	Klaip L1
	SO ₂ 97%	HCl 97%	HF 97%	NO _x 97%	TOC 97%	Dulkes 97%
	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc	Day Conc
Diena	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³	mg/Nm ³
01/01/	4.08	0.16	0.11	135.20	0.42	0.12
02/01/	3.88	0.17	0.11	145.69	0.37	0.10
03/01/	3.65	0.16	0.11	142.96	0.39	0.00
04/01/	3.18	0.17	0.11	144.83	0.40	0.00
05/01/	2.83	0.17	0.11	144.40	0.30	0.00
06/01/	2.89	0.16	0.11	142.29	0.32	0.03
07/01/	2.86	0.17	0.11	141.82	0.37	0.06
08/01/	2.78	0.17	0.11	139.81	0.40	0.10
09/01/	2.37	0.17	0.11	138.60	0.42	0.07
10/01/	2.39	0.17	0.11	139.47	0.42	0.11
11/01/	2.87	0.16	0.11	141.90	0.47	0.02
12/01/	2.87	0.16	0.11	140.21	0.52	0.03
13/01/	2.51	0.16	0.11	134.17	0.41	0.06
14/01/	2.59	0.16	0.11	136.07	0.34	0.05
15/01/	2.61	0.17	0.11	139.66	0.34	0.04
16/01/	2.93	0.17	0.11	140.50	0.35	0.05
17/01/	2.95	0.16	0.11	137.48	0.44	0.05
18/01/	2.29	0.16	0.11	136.85	0.45	0.05
19/01/	2.99	0.16	0.11	137.92	0.37	0.06
20/01/	2.63	0.16	0.11	136.51	0.39	0.05
21/01/	2.77	0.16	0.11	122.79	0.41	0.05
22/01/	2.62	0.22	0.12	113.37	0.56	0.07
23/01/	3.19	0.17	0.11	137.69	0.33	0.06
24/01/	3.34	0.17	0.11	137.00	0.50	0.06
25/01/	2.85	0.17	0.11	138.71	0.48	0.04
26/01/	3.19	0.17	0.11	139.67	0.40	0.07
27/01/	2.92	0.17	0.11	141.66	0.35	0.06
28/01/	3.19	0.17	0.11	141.12	0.35	0.06
29/01/	3.52	0.16	0.10	137.55	0.40	0.03
min	2.29	0.16	0.10	113.37	0.30	0.00
max	4.08	0.22	0.12	145.69	0.56	0.12
MMV	2.96	0.17	0.11	138.18	0.40	0.05

- = out of operation = < 2/3

M = Maintenance

G = > LV

D = > DLV

X = no daily classing

F = Fault

R = Replacement

N = No Data

A = Startup / shutdown